

Address	Device Type	Message	Address	Type	Component Message	Usage
001:001-001	FP-11	SMOKE GARAGE P2 ELEV E001 LOBBY	1	SmokePhoto		Alarm
001:001-002	FP-11	SMOKE GARAGE P2 EMR P203	1	SmokePhoto		Alarm
001:001-006	FPT-11	HEAT GARAGE P2 EMR P203	1	Thermal		Alarm
001:001-009	TRI-60R	RELAY PRI GARAGE P2 EMR P203	1	Switch1		Relay
001:001-010	TRI-60R	RELAY ALT GARAGE P2 EMR P203	1	Switch1		Relay
001:001-012	TRI-60R	RELAY HAT GARAGE P2 EMR P203	1	Switch1		Relay
001:001-014	TRI-60	TAMP GARAGE P2 ELEV E001 EMR	1	Switch1		Supervisory
001:001-015	TRI-60	TAMP GARAGE P2 ELEV E001 PIT	1	Switch1		Supervisory
001:001-021	TRI-60R	ELEV SHUNT POWER LOST	1	Switch1		Supervisory
001:002-001	FP-11	SMOKE GARAGE P1 ELEV E001 LOBBL	1	SmokePhoto		Alarm
001:002-002	FP-11	SMOKE GARAGE P1 ELEC RM P108	1	SmokePhoto		Alarm
001:002-003	FP-11	SMOKE GAGAGE LVL ELEV LOBBY	1	SmokePhoto		Alarm
001:002-004	FP-11	SMOKE GARAGE LVL ELEV SHAFT	1	SmokePhoto		Alarm
001:002-005	FPT-11	HEAT 2ND LVL ELEV SHAFT	1	Thermal		Alarm
001:002-006	FP-11	SMOKE ELEV TOP OF SHAFT	1	SmokePhoto		Alarm
001:002-007	TRI-60	TAMP WS. ELEV TOP OF SHAFT	1	Switch1		Supervisory
001:002-008	TRI-60D	MAIN FLOW P1 SPRKLER RM P109	1	Switch1		Alarm
001:002-009	TRI-60D	MAIN TAMP P1 SPRKLER RM P109	1	Switch1		Supervisory
001:002-010	TRI-60D	FLOW GARAGE P1 NORTH P2 DRY SYS	1	Switch1		Alarm
001:002-011	TRI-60D	TAMP GARAGE P1 NORTH P2 DRY SYS	1	Switch1		Supervisory
001:002-012	TRI-60D	FLOW GARAGE P1 SOUTH P2 DRY SYS	1	Switch1		Alarm
001:002-013	TRI-60D	TAMP GARAGE P1 SOUTH P2 DRY SYS	1	Switch1		Supervisory
001:002-014	TRI-60D	FLOW GARAGE P1 NORTH P1 DRY SYS	1	Switch1		Alarm
001:002-015	TRI-60D	TAMP GARAGE P1 NORTH P1 DRY SYS	1	Switch1		Supervisory
001:002-016	TRI-60D	FLOW GARAGE P1 SOUTH P1 DRY SYS	1	Switch1		Alarm
001:002-017	TRI-60D	TAMP GARAGE P1 SOUTH P1 DRY SYS	1	Switch1		Supervisory
001:002-018	TRI-60	HI/LO GARAGE P1 SPRKLER RM 109	1	Switch1		Supervisory
001:002-019	TRI-60R	ALARM FROM DC BLDG D CRTHSE	1	Switch1		Supervisory
001:002-020	TRI-60R	TRBL/SUPV FROM BLDG D CRTHSE	1	Switch1		Trouble
001:002-022	TRI-60R	RELAY GAR P1 ALARM TO SECURITY	1	Switch1		Relay
001:002-025	TRI-60D	P1 LVL CO DET	1	Switch1		Supervisory
001:002-026	TRI-60D	P2 LVL CO DET	1	Switch1		Supervisory
001:002-027	TRI-60	HEAT TRACE PANEL FAULT	1	Switch1		Supervisory

001:002-030	MSI-1	PULL GARAGE ENTRANCE	1	Switch1		Alarm
-------------	-------	----------------------	---	---------	--	-------

Address	Module Type	Message	Submodule Address	Submodule Type
001:010	PSC-12	PSC-12 DC COURT GARAGR		
001:009	NIC-C(HNet)	NIC @ DC COURT GARAGE		
001:005	ZIC-4A	ZIC-4A @ DC COURT GARAGE		
001:001	MLC loop	MLC loop @ address 1		
001:002	MLC loop	MLC loop @ address 2		
001:253	PMI-D	PMI-D @ DC COURT GARAGE		
001:004	RPM	RPM DC COURT GARAGE		
001:003	SSD	SSD @ address 3		

[illegible]

Project	Version	Revision		
DC COURT GARAGE MIGRATION	14.4.16	71		

HFP-11	0	FP-11	7
HFPT-11	0	MSI-1	1
HCP	0	TRI-60D	12
HMS-S/D/M/SA	0	TRI-60R	7
HMS-2S	0	TRI-60	5
HTRI-D	0	FPT-11	2
HTRI-S	0	ICP-25	0
HTRI-R	0	ICP-70	0
HTRI-M	0	ID-60I	0
HZM	0	ID-60IA	0
FDOOTC441	0	ID-60IAH	0
FDOOT441	0	ID-60IB	0
FDOT421	0	ID-60IBH	0
FDO421	0	ID-60P	0
FDCIO A	0	ID-60PD	0
FDCIO B	0	ID-60PT	0
ILED	0	ID-60T	0
ILED-XC/XW	0	ILI-1	0
XTRI-D	0	ILI-1A	0
XTRI-M	0	ILI-1AH	0
XTRI-R	0	ILI-1B	0
XTRI-S	0	ILI-1BH	0
TSM-1X	0	ILI-1H	0
PAD5 Main Card	0	ILP-1	0
PAD5 NAC Exp Card	0	ILP-2	0
FDT421	0	ILPT-1	0
VDetector	0	MSI-2	0
VScanner	0		0
XMS-S/D/M/SA	0		0
XMS-2S	0		0

<u>Group level</u>	<u>Group Name</u>	<u>Group Message</u>
--------------------	-------------------	----------------------