

Address	Device	Type	Message	Pass	Fail	Comment
001:021-001	FDO421	Alarm	SMOK PARK LVL Z2 ELEV 6 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:021-002	FDO421	Alarm	SMOK PARK LVL Z2 MECH RM	X		
001:021-003	FDO421	Alarm	SMOK PARK LVL Z2 MECH RM	X		
001:021-004	FDO421	Alarm	SMOK PARK LVL Z2 NORTH MECH RM	X		
001:021-005	FDO421	Alarm	SMOK PARK LVL Z1 STAIR 1	X		
001:021-006	FDO421	Alarm	SMOK PARK LVL Z2 STAIR 2	X		
001:021-007	XTRI-D	Alarm/SUPV	FS/TS SW.GARAGE LVL.Z2 EMR #6	X		Test with Schindler 3/19/2023, ASME A17
001:021-009	XTRI-D	Alarm/SUPV	FS/TS SW.GARAGE LVL.Z2 ELEV 6 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:021-011	XTRI-R	Status	RELAY PARK LVL Z1 AHU 28	X		
001:021-012	XTRI-R	Status	RELAY PARK LVL Z1 RAF 28	X		
001:021-015	FDO421	Alarm	DUCT PARK LVL Z2 GARAGE AHU#1	X		
001:021-016	XTRI-R	Status	RELAY PARK LVL Z2 GARAGE AHU-1	X		
001:021-017	FDO421	Alarm	DUCT PARK LVL Z2 GARAGE RAF-1	X		
001:021-018	XTRI-R	Status	RELAY PARK LVL Z2 GARAGE RAF-1	X		
001:021-021	XTRI-R	Status	RELAY PARK LVL Z2 ELEV 6 PRI.	X		Test with Schindler 3/19/2023, ASME A17
001:021-022	XTRI-R	Status	RELAY PARK LVL Z2 ELEV 6 ALT.	X		Test with Schindler 3/19/2023, ASME A17
001:021-023	XTRI-R	Trouble	RELAY PARK LVL Z2 ELEV 6 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:021-024	XTRI-R	Status	RELAY PARK LVL Z2 ELEV 6 FIREHAT	X		Test with Schindler 3/19/2023, ASME A17
001:021-025	XTRI-R	Status	RELAY PARK LVL Z2 ELEV 6 FIREHAT	X		Test with Schindler 3/19/2023, ASME A17
001:021-029	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z2 NORTH GARAGE	X		
001:021-030	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z2 STAIR 2	X		
001:021-031	FDO421	Alarm	SMOK PARK LVL Z1 NORTH MECH RM	X		
001:021-032	FDO421	Alarm	SMOK PARK LVL Z1 MECH RM	X		
001:021-033	FDO421	Alarm	SMOK PARK LVL Z1 MECH RM	X		
001:021-045	FDO421	Alarm	DUCT PARK LVL Z1 MECH RM AHU6	X		
001:021-046	XTRI-R	Status	RELAY PARK LVL Z1 MECH RM AHU6	X		
001:021-059	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z1 STAIR 1	X		
001:021-060	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z1 STAIR 1	X		
001:022-007	FDO421	Alarm	SMOK C LVL Z1 HOUSEKEEPING C-AA	X		
001:022-009	FDO421	Alarm	SMOK C LVL Z1 STAIR 1	X		
001:022-010	FDO421	Alarm	SMOK C LVL Z1 ELEC CLOSET A	X		

001:022-011	FDO421	Alarm	SMOK C LVL Z1 FOOD SVC OFFICE	X		
001:022-016	FDO421	Alarm	SMOK C LVL Z1 CORR	X		
001:022-018	FDO421	Alarm	DUCT C LVL Z1 C MECH AHU-40	X		
001:022-019	XTRI-R	Status	RELAY C LVL Z1 C MECH AHU-40	X		
001:022-020	FDO421	Alarm	SMOK C LVL Z1 RM C300	X		
001:022-021	FDO421	Alarm	SMOK C LVL Z1 RM C300	X		
001:022-022	FDO421	Alarm	SMOKE C LVL Z1 RM C300 ELEC RM	X		
001:022-023	FDO421	Alarm	DUCT C LVL Z1 RM C301 CRAC2	X		
001:022-024	XTRI-R	Status	RELAY C LVL Z1 RM C301 CRAC2	X		
001:022-025	FDO421	Alarm	DUCT C LVL Z1 RM C301 CRAC1	X		
001:022-026	XTRI-R	Status	RELAY C LVL Z1 RM C301 CRAC1	X		
001:022-027	FDO421	Alarm	DUCT C LVL Z1 AHU5	X		
001:022-028	XTRI-R	Status	RELAY C LVL Z1 AHU5	X		
001:022-029	FDO421	Alarm	DUCT C LVL Z1 RAF5	X		
001:022-030	XTRI-R	Status	RELAY C LVL Z1 RAF5	X		
001:022-031	FDO421	Alarm	SMOK C LVL Z1 USMS ADT RM C-240	X		
001:022-032	FDO421	Alarm	SMOK C LVL Z1 IT ROOM 301	X		
001:022-033	FDO421	Alarm	SMOKE C LVL Z1 RM C301	X		
001:022-034	FDO421	Alarm	SMOK C LVL Z1 IT ROOM	X		
001:022-035	XTRI-S	Supervisory	SUPER C LVL Z1 IT ROOM FM200	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-038	FDO421	Alarm	SMOK C LVL Z1 IT RM FM200	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-036	XTRI-D	Alarm/TRBL	ALARM TRBL C LVL Z1 IT ROOM FM200	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-040	XTRI-D	Alarm/SUPV	PREALARM FS/TS C LVL Z1IT RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-042	XTRI-S	Supervisory	PREALARM HI/LO C LVL Z1IT RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-043	XTRI-R	Status	PREALARM SOLENOID C LVL Z1IT RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:022-059	XMS-S/D/M/SA	Alarm	PULL C LVL Z1 STAIR 1	X		
001:022-060	XMS-S/D/M/SA	Alarm	PULL C LVL Z2 STAIR 1	X		
001:023-002	FDO421	Alarm	SMOK C LVL Z2 ELEV PIT	X		Test with Schindler 3/19/2023, ASME A17
001:023-003	FDO421	Alarm	SMOK C LVL Z2 STOR CLOSET C331	X		
001:023-004	FDO421	Alarm	SMOK C LVL Z2 CAFE	X		
001:023-007	FDO421	Alarm	SMOK C LVL Z2 CORR	X		
001:023-008	FDO421	Alarm	SMOK C LVL Z3 HEALTH CARE C330	X		

001:023-009	FDO421	Alarm	SMOK C LVL Z2 STORAGE M 309	X		
001:023-010	FDO421	Alarm	SMOK C LVL Z2 ELEV 6 SERVICE ELE	X		Test with Schindler 3/19/2023, ASME A17
001:023-012	FDO421	Alarm	SMOK C LVL Z2 STOR CLOSET C310	X		
001:023-013	XTRI-R	Status	RELAY C LVL Z2 RAF20		X	NOT CONNECTED TO THE UNIT/BMS
001:023-014	FDO421	Alarm	DUCT C LVL Z2 RAF20	X		
001:023-015	FDO421	Alarm	DUCT C LVL Z2 RAF24	X		
001:023-017	FDO421	Alarm	DUCT C LVL Z2 AHU24	X		
001:023-018	XTRI-R	Status	RELAY C LVL Z2 AHU/RAF 24		X	NOT CONNECTED TO THE UNIT/BMS
001:023-021	XTRI-S	Supervisory	TAMPER C Z2 ELEV 6 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:023-022	FDO421	Alarm	DUCT C LCL Z3 MECH RM AHU 22	X		
001:023-023	XTRI-R	Status	RELAY C LVL Z3 MECH RM RAF 22	X		
001:023-024	FDO421	Alarm	DUCT C LVL Z3 MECH RM RAF 22	X		
001:023-025	XTRI-R	Status	RELAY C LVL Z3 MECH RM AHU 22	X		
001:023-026	FDO421	Alarm	SMOK C LVL Z3 PUB CORR.C10.10	X		
001:023-030	XMS-S/D/M/SA	Alarm	PULL C LVL Z2 STAIR 2	X		
001:023-032	FDO421	Alarm	SMOK C LVL Z3 MECH RM	X		
001:023-033	FDO421	Alarm	SMOK C LVL Z3 STORAGE ROOM	X		
001:023-036	FDO421	Alarm	SMOK C LVL Z3 ENG CORR	X		
001:023-039	FDO421	Alarm	SMOK C LVL Z3 PUB CORR.C10.10	X		
001:023-040	FDO421	Alarm	SMOK C LVL Z3 PUB CORR.C10.10	X		
001:023-041	FDO421	Alarm	SMOK C LVL Z3 CORR COMM CLOSET	X		
001:023-042	FDO421	Alarm	SMOK C LVL Z3 CORR	X		
001:023-043	FDO421	Alarm	SMOK C LVL Z3 CORR	X		
001:023-044	FDO421	Alarm	SMOK C LVL Z3 ESCALATOR LOBBY	X		
001:023-045	FDO421	Alarm	SMOK C LVL Z3 ESCALATOR LOBBY	X		
001:023-046	FDO421	Alarm	SMOK C LVL Z3 CORR	X		
001:023-055	XTRI-R	Status	RELAY C LVL Z3 DOOR RLS	X		
001:023-056	XTRI-R	Status	RELAY C LVL Z3 DOOR RLS	X		
001:023-057	FDO421	Alarm	DUCT C LVL Z2 AHU20	X		
001:023-058	XTRI-R	Status	RELAY C LVL Z2 AHU20		X	NOT CONNECTED TO THE UNIT/BMS
001:024-001	FDO421	Alarm	SMOK JM LVL Z1 CORR	X		
001:024-002	FDO421	Alarm	SMOK JM LVL Z1 ELEC CLOSET A	X		
001:024-003	FDO421	Alarm	SMOK JM LVL Z1 CLOSET JM-BB	X		
001:024-004	FDO421	Alarm	SMOK JM LVL Z1 CLOSET	X		

001:024-005	FDO421	Alarm	SMOK JM LVL Z1 COMM CLOSET A	X		
001:024-008	FDO421	Alarm	SMOK JM LVL FAMILY CORT RM JM342	X		
001:024-009	FDO421	Alarm	SMO JM LVL FAMILY CORT JM340E	X		
001:024-010	FDO421	Alarm	SMOK JM LVL Z1 STAIR 1	X		
001:024-011	FDO421	Alarm	SMOK JM LVL Z2 STAIR 2	X		
001:024-014	FDO421	Alarm	SMO JM LVL FAMILY CORT RM JM3400	X		
001:024-015	FDO421	Alarm	SMO JM LVL FAMILY CORT RM JM340A	X		
001:024-016	FDO421	Alarm	SMO JM LVL FAMILY CORT RM JM340B	X		
001:024-017	FDO421	Alarm	DUCT JM LEV FAMILY CORT AHU #30	X		
001:024-018	XTRI-R	Status	JM LEV FAMILY CORT AHU#10 SHUTDOWN	X		
001:024-019	FDO421	Alarm	SMO JM LVL FAMILY CORT RM JM340E	X		
001:024-020	XMS-S/D/M/SA	Alarm	PULL JM LVL Z1 STAIR 1	X		
001:024-022	FDO421	Alarm	SMOK JM LVL Z2 ELEC CLOSET A-1	X		
001:024-023	FDO421	Alarm	SMOK JM LVL Z2 COMM CLOSET D	X		
001:024-026	FDO421	Alarm	DUCT JM LEV FAMILY CORT JM300A	X		
001:024-027	XTRI-R	Status	DAMP JM LEV FAMILY COURT JM300A	X		
001:024-028	FDO421	Alarm	DUCT JM LVL Z3 PUB CORR /JM 300A	X		
001:024-029	XTRI-R	Status	DAMP JM LVL Z3 PUB CORR /JM 300A	X		
001:024-030	FDO421	Alarm	DUCT JM LEV FAMILY CORT AHU #30	X		
001:024-031	XTRI-R	Status	JM LEV FAMILY CORT AHU #30 SHUTDOWN	X		
001:024-032	XTRI-R	Status	RLY JM LEV FAMILY CORTDOOR JM300	X		
001:024-040	XMS-S/D/M/SA	Alarm	PULL JM LVL Z2 STAIR 2	X		
001:024-061	TSM-1X	Status	KS JM LEV FAMILY CORT AHU #30	X		
001:024-062	TSM-1X	Status	KS JM LEV FAMILY CORT JM300A	X		
001:024-063	TSM-1X	Status	KS JM LVL Z3 PUB CORR /JM 300A	X		
001:024-064	TSM-1X	Status	KS JM LEV FAMILY CORT AHU #30	X		
001:031-001	FDO421	Alarm	SMOKE PARK LVL Z3 SOUTH MECH RM	X		
001:031-002	FDO421	Alarm	SMOKE PARK LVL Z3 SOUTH MECH RM	X		
001:031-003	FDO421	Alarm	SMOKE PARK LVL Z3 SOUTH MECH RM	X		
001:031-004	FDO421	Alarm	SMOKE PARK LVL Z3 EMR EL 1&2	X		
001:031-005	FDO421	Alarm	SMOKE PARK LVL Z1 SUB STA A	X		
001:031-006	FDO421	Alarm	SMOKE PARK LVL Z1 SUB STA A	X		
001:031-007	FDO421	Alarm	SMOKE PARK LVL Z1 STORAGE STAIR	X		
001:031-008	FDO421	Alarm	SMOKE PARK LVL Z1 EMR EL 3&4	X		

001:031-009	FDO421	Alarm	SMOKE PARK LVL Z1 STAIR 3	X		
001:031-010	FDO421	Alarm	SMOKE PARK LVL Z2 STAIR 4	X		
001:031-012	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 3&4	X		Test with Schindler 3/19/2023, ASME A17
001:031-013	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 1&2	X		Test with Schindler 3/19/2023, ASME A17
001:031-014	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 3/4	X		Test with Schindler 3/19/2023, ASME A17
001:031-016	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 3/4	X		Test with Schindler 3/19/2023, ASME A17
001:031-017	XTRI-R	Status	RELAY PARK LVL Z3 ELEV 1,2,3,4	X		Test with Schindler 3/19/2023, ASME A17
001:031-018	XTRI-R	Status	ALT RCLL PARK LVL Z3 ELEV 1,2,3,	X		Test with Schindler 3/19/2023, ASME A17
001:031-019	XTRI-R	Status	REL PARK LVL Z3 ELEV 1-2 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:031-020	XTRI-R	Status	REL PARK LVL Z3 ELEV 1,2,3,4 FIR	X		Test with Schindler 3/19/2023, ASME A17
001:031-021	FDO421	Alarm	DUCT PARK LVL Z1 AHU 28	X		
001:031-022	FDO421	Alarm	DUCT PARK LVL Z1 RAF 28	X		
001:031-023	XTRI-D	Alarm/SUPV	FS/TS GARAGE LVL.Z3 EMR 3&4	X		Test with Schindler 3/19/2023, ASME A17
001:031-025	FDO421	Alarm	DUCT PARK LVL Z3 RAF11 MECH RM	X		
001:031-026	XTRI-R	Status	RELAY PARK LVL Z3 MECH RM RAF11	X		
001:031-027	FDO421	Alarm	DUCT PARK LVL Z3 AHU11 GARAGE	X		
001:031-028	XTRI-R	Status	DUCT RELAY PARK LVL Z3 GAR AHU11	X		
001:031-029	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z1 STAIR NO 3	X		
001:031-030	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z1 STAIR NO 3	X		
001:031-031	FDO421	Alarm	SMOKE PARK LVL Z2 MECH. RM	X		
001:031-032	FDO421	Alarm	SMOKE PARK LVL Z2 CLOSET STAIR 4	X		
001:031-033	FDO421	Alarm	SMOKE PARK LVL Z2 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:031-034	XTRI-R	Trouble	RLY PARK LVL Z3 EMR EL 3/4 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:031-035	FDO421	Alarm	DUCT PARK LVL Z3 AHU11 GARAGE	X		
001:031-036	XTRI-R	Status	RELAY PARK LVL Z2 MECH RM AHU12	X		
001:031-037	FDO421	Alarm	DUCT PARK LVL Z3 RAF12 MECH RM	X		
001:031-038	XTRI-R	Status	RELAY PARK LVL Z3 MECH RM RAF12	X		
001:031-039	XTRI-D	Alarm/SUPV	FS/TS GARAGE LVL.Z3 EMR 1&2	X		Test with Schindler 3/19/2023, ASME A17
001:031-040	FDO421	Alarm	SMOKE PARKING LVL Z1 ELEC CLST	X		
001:031-041	XTRI-D	SUPV/SUPV	TAMPER PARK LVL Z2 MECH FIREPUMP	X		Test with BFPE 11/12/2022, NFPA 25
001:031-042	FDO421	Alarm	SMOKE PARKING LVL Z1 ELEC CLST	X		
001:031-043	XTRI-D	SUPV/SUPV	TAMPER PARK LVL Z2 MECH FIREPUMP	X		Test with BFPE 11/12/2022, NFPA 25
001:031-045	XTRI-D	Supervisory	TAMPER PARK LVL Z2 MECH FIREPUMP	X		Test with BFPE 11/12/2022, NFPA 25
001:031-046	FDO421	Alarm	SMOKE PARKING LVL Z1 ELEC CLST	X		

001:031-047	XTRI-D	Trouble	FIRE PUMP FAULT PARK LVL Z2 MECH	X		Test with BFPE 11/12/2022, NFPA 25
001:031-048	FDO421	Alarm	SMOKE PARKING LVL Z1 ELEC CLST	X		
001:031-049	XTRI-R	Supervisory	FIRE PUMP RUN PARK LVL Z2 MECH	X		Test with BFPE 11/12/2022, NFPA 25
001:031-050	XTRI-S	Supervisory	TAMPER PARK LVL Z2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:031-051	XTRI-S	Supervisory	TAMPER PARK LVL Z2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:031-052	XTRI-S	Supervisory	TAMPER PARK LVL Z2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:031-053	XTRI-D	Alarm/SUPV	HI/LOW AIR FLOW SW.WEST PARK Z2	X		Test with BFPE 11/3/2022, NFPA 25
001:031-055	XTRI-D	Alarm/SUPV	HI/LOW AIR FLOW SW.EAST PARK Z2	X		Test with BFPE 11/3/2022, NFPA 25
001:031-057	XTRI-S	Alarm	FLOW SW. ATRIUM PARK ZN-2	X		Test with BFPE 11/3/2022, NFPA 25
001:031-058	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z3 MECH CLOSET A	X		
001:031-059	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z2 STAIR 4	X		
001:031-060	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z2 STAIR 4	X		
001:033-001	FDO421	Alarm	SMOK C LVL Z1 COMM CLOSET C	X		
001:033-002	FDO421	Alarm	SMOK C LVL Z1 USMS ELEC C-226A	X		
001:033-003	FDO421	Alarm	SMOK C LVL Z1 ELEC CLOSET B	X		
001:033-004	FDO421	Alarm	SMOK C LVL Z1 USMS I.T.RM C-226	X		
001:033-005	FDO421	Alarm	SMOK C LVL Z1 STAIR 3	X		
001:033-006	FDO421	Alarm	SMOK C LVL Z2 STAIR 4	X		
001:033-007	FDO421	Alarm	SMOK C LVL Z3 STAIR 5	X		
001:033-008	FDO421	Alarm	SMOK C LVL Z2 U.S MARSHAL DVR RM	X		
001:033-012	XTRI-S	Supervisory	TAMPER C LVL STAIR #5	X		Test with BFPE 11/3/2022, NFPA 25
001:033-015	XTRI-D	Alarm/SUPV	FS/TS C LVL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:033-020	XMS-S/D/M/SA	Alarm	PULL C LVL Z1 CORRIDOR BY STAIR	X		
001:033-021	FDO421	Alarm	SMOK C LVL Z2 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:033-024	FDO421	Alarm	SMOK C LVL Z2 CORRIDOR/STAIR 4	X		
001:033-025	FDO421	Alarm	SMOK C LVL Z2 CAFE	X		
001:033-028	FDO421	Alarm	SMOK C LVL Z3 C-185/STAIR #5	X		
001:033-029	FDO421	Alarm	SMOK C LVL Z3 C-185	X		
001:033-030	FDO421	Alarm	SMOK C LVL Z3 PSA C-205	X		
001:033-031	FDO421	Alarm	SMOK C LVL Z3 C-185/STAIR #5	X		
001:033-032	FDO421	Alarm	SMOK C LVL Z3 PMSV C-185A	X		
001:033-033	XTRI-D	Alarm/SUPV	FS/TS C LVL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:033-038	XMS-S/D/M/SA	Alarm	PULL C LVL Z2 CAFE	X		
001:033-040	XMS-S/D/M/SA	Alarm	PULL C LVL Z2 STAIR 4	X		

001:033-041	FDO421	Alarm	SMOK C LVL Z3 ELEV 1/4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:033-042	FDO421	Alarm	SMOK C LVL Z3 CORR	X		
001:033-043	FDO421	Alarm	SMOK C LVL Z3 CORR	X		
001:033-044	FDO421	Alarm	SMOK C LVL Z3 LAWYER LNG C175	X		
001:033-045	FDO421	Alarm	SMOK C LVL Z3 CORRIDOR	X		
001:033-046	FDO421	Alarm	SMOK C LVL Z3 US ATTORNEYS C185	X		
001:033-047	FDO421	Alarm	SMOK C LVL Z3 COMM ROOM I	X		
001:033-048	FDO421	Alarm	SMOK C LVL Z3 ELEC CLOSET E	X		
001:033-049	FDO421	Alarm	SMOK C LVL Z3 CLOSET	X		
001:033-050	FDO421	Alarm	SMOK C LVL Z3 COMM ROOM I	X		
001:033-053	XTRI-R	Status	RELAY C LVL Z3 DOOR RLS	X		
001:033-056	XMS-S/D/M/SA	Alarm	PULL C LVL Z3 STAIR 5	X		
001:034-001	FDO421	Alarm	SMOK JM LVL Z1 COMM CLOSET B	X		
001:034-002	FDO421	Alarm	SMOK JM LVL Z1 SOUTH SEC CORR	X		
001:034-003	FDO421	Alarm	SMOK JM LVL Z1 SOUTH SEC CORR	X		
001:034-004	FDO421	Alarm	SMOK JM LVL Z1 ELEC CLOSET B	X		
001:034-005	FDO421	Alarm	SMOK JM LVL Z1 COMM CLOSET C	X		
001:034-006	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:034-007	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:034-008	FDO421	Alarm	SMOK JM LVL Z1 STAIR 3	X		
001:034-009	FDO421	Alarm	SMOK JM LVL Z2 STAIR 4	X		
001:034-010	FDO421	Alarm	SMOK JM LVL Z1 S.SEC COR CELL1/2	X		
001:034-011	FDO421	Alarm	SMOK JM LVL Z2 S.SEC COR CELL3/4	X		
001:034-012	FDO421	Alarm	SMOK JM LVL Z4 S.SEC COR CELL5/6	X		
001:034-020	XMS-S/D/M/SA	Alarm	PULL JM LVL Z1 STAIR 3	X		
001:034-021	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:034-022	FDO421	Alarm	SMOK JM LVL Z6 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:034-025	XTRI-D	Alarm/SUPV	FS/TS JM LVL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:034-027	XTRI-D	Alarm/SUPV	FS/TS JM LVL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:034-040	XMS-S/D/M/SA	Alarm	PULL JM LVL Z2 STAIR 4	X		
001:034-041	FDO421	Alarm	SMOK JM LVL Z3 ELEV 1/4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:034-044	FDO421	Alarm	SMOK JM LVL Z3 COMM CLOSET K	X		

001:034-046	FDO421	Alarm	SMOK JM LVL Z3 COMM CLOSET H	X		
001:034-048	FDO421	Alarm	SMOK JM LVL Z3 STAIR 5	X		
001:034-049	FDO421	Alarm	SMOK JM LVL Z3 ESCALATOR LOBBY	X		
001:034-050	FDO421	Alarm	SMOK JM LVL Z3 ESCALATOR LOBBY	X		
001:034-051	FDO421	Alarm	SMOK JM LVL Z3 ESCALATOR LOBBY	X		
001:034-053	FDO421	Alarm	SMOK JM LVL Z3 ELEC CLOSET E	X		
001:034-055	XTRI-R	Status	RELAY JM LVL Z3 DOOR RLS	X		
001:034-056	XTRI-R	Status	RELAY JM LVL Z3 DOOR RLS	X		
001:034-060	XMS-S/D/M/SA	Alarm	PULL JM LVL Z3 STAIR 5	X		
001:042-001	FDO421	Alarm	SMOK C LVL Z4 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:042-002	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:042-003	FDO421	Alarm	SMOK C LVL Z4 OFFICE C215	X		
001:042-004	FDO421	Alarm	SMOK C LVL Z4 OFFICE C225	X		
001:042-005	FDO421	Alarm	SMOK C LVL Z4 OFFICE C225	X		
001:042-009	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:042-010	FDO421	Alarm	SMOKE C LVL Z4 CORR	X		
001:042-011	FDO421	Alarm	SMOK C LVL Z4 CLOSET	X		
001:042-012	FDO421	Alarm	SMOK C LVL Z4 CLOSET	X		
001:042-014	FDO421	Alarm	SMOK C LVL Z4 CLOSET	X		
001:042-015	FDO421	Alarm	SMOK JM LV Z1 SOUTH PRISONER COR	X		
001:042-016	FDO421	Alarm	SMOK JM LV Z2 SOUTH PRISONER COR	X		
001:042-017	FDO421	Alarm	SMOK JM LV Z4 SOUTH PRISONER COR	X		
001:042-018	FDO421	Alarm	SMOK JM LV Z5 SOUTH PRISONER COR	X		
001:042-019	FDO421	Alarm	SMOK JM LV Z5 ELEV 11 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:042-020	FDO421	Alarm	SMOK JM LV Z3 SOUTH PRISONER COR	X		
001:042-021	XTRI-R	Supervisory	VLV TAMP C LVL Z4 STAIR-8 RISER	X		Test with BFPE 11/3/2022, NFPA 25
001:042-025	FDO421	Alarm	SMOK JM LVL Z4 CLOSET SOUTH CORR	X		
001:042-026	XTRI-R	Status	RELAY JM LVL Z4 DOOR RLS	X		
001:042-027	XTRI-R	Status	RELAY JM LVL Z4 DOOR RLS	X		
001:042-028	FDO421	Alarm	SMOK C LVL Z4 STAIR 8	X		
001:042-029	XMS-S/D/M/SA	Alarm	PULL C LVL Z4 STAIR 8	X		
001:042-031	FDO421	Alarm	SMOK JM LVL Z6 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17

001:042-032	FDO421	Alarm	SMOK JM LVL Z4 SOUTH SEC CORR	X		
001:042-033	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:042-034	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:042-035	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:042-036	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:042-037	FDO421	Alarm	SMOK JM LVL Z6 SOUTH SEC CORR	X		
001:042-038	FDO421	Alarm	SMOK JM LVL Z5 CLOSET	X		
001:042-039	FDO421	Alarm	SMOK JM LVL Z5 CLOSET	X		
001:042-047	FDO421	Alarm	SMOK JM LVL Z5 COMM CLOSET JM101	X		
001:042-049	FDO421	Alarm	SMOK JM LVL Z6 STAIR 8	X		
001:042-050	FDO421	Alarm	SMOK JM LVL Z6 STAIR 9	X		
001:042-051	XTRI-D	Alarm/SUPV	FLOW/TAMP JM LVL Z4 STAIR 9	X		Test with BFPE 11/3/2022, NFPA 25
001:042-053	FDO421	Alarm	JM LVL Z4 SMOKE HOLDING CELL CR-7/8	X		
001:042-054	FDO421	Alarm	SMOK JM LVL Z4 CORR	X		
001:042-055	FDO421	Alarm	SMOK JM LVL Z4 CORR	X		
001:042-056	FDO421	Alarm	SMOK JM LVL Z4 CORR	X		
001:042-057	FDO421	Alarm	SMOK JM LVL Z4 CORR	X		
001:042-058	XMS-S/D/M/SA	Alarm	PULL JM LVL Z5 ENTRY LOBBY	X		
001:042-060	XMS-S/D/M/SA	Alarm	PULL JM LVL Z6 STAIR 8	X		
001:041-001	FDO421	Alarm	SMOK PARK LVL Z4 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:041-002	FDO421	Alarm	SMOK PARK LVL Z4 EMR ELEV 12	X		
001:041-003	FDO421	Alarm	SMOK PARK LVL Z4 STORAGE STAIR 8	X		
001:041-004	FDO421	Alarm	SMOK PARK LVL Z4 SOUTH MECH RM	X		
001:041-005	FDO421	Alarm	SMOK PARK LVL Z4 SOUTH MECH RM	X		
001:041-006	FDO421	Alarm	SMOK PARK LVL Z4 SOUTH SUB STA B	X		
001:041-007	FDO421	Alarm	SMOK PARK LVL Z4 STAIR 8	X		
001:041-008	FDO421	Alarm	SMOK PARK LVL Z5 STAIR 9	X		
001:041-009	FDO421	Alarm	SMOK PARK LVL Z4 SOUTH SUB STA B	X		
001:041-011	FDT421	Alarm	HEAT PARK LVL Z4 EMR ELEV 12	X		Test with Schindler 3/19/2023, ASME A17
001:041-015	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 12 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:041-016	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 12 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:041-017	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 12 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:041-018	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 12 HAT	X		Test with Schindler 3/19/2023, ASME A17
001:041-019	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 1/2	X		Test with Schindler 3/19/2023, ASME A17

001:041-020	FDT421	Alarm	HEAT PARK LVL Z3 EMR EL 1/2	X		Test with Schindler 3/19/2023, ASME A17
001:041-021	FDO421	Alarm	DUCT PARK LVL Z4 GARAGE RAF13	X		
001:041-022	XTRI-R	Status	RELAY PARK LVL Z4 GARAGE RAF13	X		
001:041-023	FDO421	Alarm	DUCT PARK LVL Z4 MECH RM AHU13	X		
001:041-024	XTRI-R	Status	RELAY PARK LVL Z4 MECH RM AHU13	X		
001:041-028	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z4 SOUTH MECH RM	X		
001:041-029	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z4 STAIR 8	X		
001:041-030	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z4 STAIR 8	X		
001:041-031	FDO421	Alarm	SMOK PARK LVL Z5 SOUTH MECH RM	X		
001:041-032	FDO421	Alarm	SMOK PARK LVL Z5 SOUTH MECH RM	X		
001:041-033	FDO421	Alarm	SMOK PARK LVL Z5 CLOSET	X		
001:041-034	XTRI-D	Alarm/SUPV	FS/TS PARK LVL.Z 2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:041-036	XTRI-D	Alarm/SUPV	FS/TS PARK LVL.Z 2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:041-038	XTRI-D	Alarm/SUPV	FS/TS PARK LVL.Z 2 MECH RM SOUTH	X		Test with BFPE 11/3/2022, NFPA 25
001:041-041	FDO421	Alarm	DUCT PARK LVL Z5 RAF14 GARAGE	X		
001:041-042	XTRI-R	Status	RELAY PARK LVL Z5 GARAGE RAF14	X		
001:041-043	FDO421	Alarm	DUCT PARK LVL Z5 AHU14 MECH RM	X		
001:041-044	XTRI-R	Status	RELAY PARK LVL Z5 MECH RM AHU14	X		
001:041-045	FDO421	Alarm	DUCT PARK LVL Z4 AHU29	X		
001:041-046	XTRI-R	Status	RELAY PARK LVL Z4 AHU#29	X		
001:041-047	FDO421	Alarm	DUCT PARK LVL Z4 RAF 29	X		
001:041-048	XTRI-R	Status	RELAY RAF 29	X		
001:041-051	XTRI-S	Supervisory	TAMP SW.BULD 501 C ST OUTSIDE BA	X		Test with BFPE 11/3/2022, NFPA 25
001:041-052	XTRI-D	Supervisory	TAMP SW.BULD 501 C ST OUTSIDE BA	X		Test with BFPE 11/3/2022, NFPA 25
001:041-054	XTRI-D	Alarm/SUPV	FS/TS GARAGE LVL.Z4 EMR #12	X		Test with Schindler 3/19/2023, ASME A17
001:041-056	XTRI-D	Alarm/SUPV	FS/TS GARAGE LVL.Z5 EMR #12 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:041-058	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 SOUTH MECH RM	X		
001:041-059	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 STAIR 9	X		
001:041-060	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 STAIR 9	X		
001:052-001	FDO421	Alarm	SMOK C LVL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:052-002	FDO421	Alarm	SMOK C LVL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:052-003	FDO421	Alarm	SMOK C LVL Z4 ELEC CLST C 10.11E	X		

001:052-004	FDO421	Alarm	SMOK C LVL Z4 ELEC CLST C 10.11E	X		
001:052-005	FDO421	Alarm	SMOK C LVL Z4 ARR.CRT SEC.CORR.	X		
001:052-006	FDO421	Alarm	SMOK C LVL Z4 MECH RM	X		
001:052-007	FDO421	Alarm	SMOK C LVL Z4 MECH RM	X		
001:052-008	FDO421	Alarm	SMOK C LVL Z4 MECH RM	X		
001:052-009	FDO421	Alarm	SMOK C LVL Z4 MECH RM	X		
001:052-010	FDO421	Alarm	SMOK C LVL Z4 ARR.CRT INTAK STOR	X		
001:052-011	FDO421	Alarm	SMOK C LVL Z4 PRETRAIL SERV	X		
001:052-012	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:052-013	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:052-014	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:052-015	FDO421	Alarm	SMOK C LVL Z4 CORR	X		
001:052-016	FDO421	Alarm	SMOK C LVL Z4 PRETRAIL SERV	X		
001:052-017	FDO421	Alarm	SMOK C LVL Z4 C.S.O.STORE C105	X		
001:052-018	XTRI-R	Status	REL JM LVL Z4 SECURE CORR DR REL	X		
001:052-019	XTRI-R	Status	REL C LVL Z4 SECURE CORR DR REL	X		
001:052-020	XTRI-R	Status	RELAY C LVL Z4 DOOR RELEASE	X		
001:052-021	FDO421	Alarm	DUCT C LVL Z4 MECH RM RAF10	X		
001:052-022	XTRI-R	Status	RELAY C LVL Z4 MECH RM RAF10	X		
001:052-023	FDO421	Alarm	DUCT C LVL Z4 MECH RM AHU10	X		
001:052-024	XTRI-R	Status	RELAY C LVL Z4 MECH RM AHU10	X		
001:052-025	FDO421	Alarm	DUCT C LVL Z4 MECH RM AHU 8	X		
001:052-026	XTRI-R	Status	RELAY C LVL Z4 MECH RM AHU8	X		
001:052-027	FDO421	Alarm	DUCT C LVL Z4 MECH RM AHU9	X		
001:052-028	XTRI-R	Status	RELAY C LVL Z4 MECH RM AHU9	X		
001:052-029	FDO421	Alarm	DUCT C LVL Z4 MECH RM RAF9	X		
001:052-030	XTRI-R	Status	RELAY C LVL Z4 MECH RM RAF9	X		
001:052-031	FDO421	Alarm	SMOK JM LVL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:052-032	FDO421	Alarm	SMOK JM LVL Z4 NORTH SEC CORR	X		
001:052-033	FDO421	Alarm	SMOK JM LVL Z4 NORTH SEC CORR	X		
001:052-034	FDO421	Alarm	SMOK JM LVL Z4 COMM CLOSET G	X		
001:052-035	FDO421	Alarm	SD JM LEV Z4 EVID STORAGE RM 405	X		
001:052-036	FDO421	Alarm	C LVL Z5 US MARSHAL S CLOSET	X		
001:052-037	FDO421	Alarm	SMOK JM LVL Z4 ELEC CLOSET C	X		

001:052-038	FDO421	Alarm	SMOK JM LVL Z4 COMM CLOSET E	X		
001:052-039	XTRI-R	Status	DOOR C LVL Z5 US MARSHAL S CLOSE	X		
001:052-040	FDO421	Alarm	SMO JM LEV FAMILY CORT JM340F	X		
001:052-041	XTRI-R	Status	RELAY PARK LVL Z4 MECH RM AHU	X		
001:052-042	FDO421	Alarm	SD C LVL Z4 ARR.CRT STOR C10.03	X		
001:052-043	FDO421	Alarm	SMOK C LVL Z4 ARR.CRT CRIM DIV.	X		
001:052-044	FDO421	Alarm	SMOK C LVL Z5 U.S. MARSHALS	X		
001:052-045	FDO421	Alarm	SMOK C LVL Z5 U.S. MARSHALS	X		
001:052-046	FDO421	Alarm	DUCT C LVL Z5 U.S. MARSHALS	X		
001:052-047	FDO421	Alarm	DUCT C LVL Z5 U.S. MARSHALS	X		
001:052-048	XTRI-R	Status	REL C LVL Z5 AHU 7	X		
001:052-049	XTRI-R	Status	REL C ST Z5 RAF 7	X		
001:052-050	FDO421	Alarm	SMOK C LVL Z4 ARR.CRT SEC.CORR.	X		
001:052-051	XTRI-D	Alarm/SUPV	FLOW/TAMP C LEVEL Z4 STAIR 6	X		Test with BFPE 11/3/2022, NFPA 25
001:052-053	FDO421	Alarm	SMOK C LVL Z4 STAIR 6	X		
001:052-054	FDO421	Alarm	SMOKE JM LVL Z4 STAIR 6	X		
001:052-055	FDO421	Alarm	DUCT C LVL Z4 RAF 8	X		
001:052-056	XTRI-R	Status	RELAY C LVL Z4 RAF 8	X		
001:052-057	FDO421	Alarm	SMOK C LVL Z4 ARR.CRT A/V CLST.	X		
001:052-058	XMS-S/D/M/SA	Alarm	PULL JM LVL Z4 STAIR 6	X		
001:052-060	XMS-S/D/M/SA	Alarm	PULL C LVL Z4 STAIR 6	X		
001:051-001	FDO421	Alarm	SMOK PK LVL Z3 NORTH STORAGE RM	X		
001:051-002	FDO421	Alarm	SMOK PK LVL Z3 CORR LOADING DOCK	X		
001:051-003	FDO421	Alarm	SMOK PK LVL Z4 STAIR 6	X		
001:051-005	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 7 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:051-006	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 7 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:051-007	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 7 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:051-008	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 7 FIREHAT	X		Test with Schindler 3/19/2023, ASME A17
001:051-009	FDO421	Alarm	SMOK PARK LVL ELEC CLOS BY SUB C	X		
001:051-011	FDO421	Alarm	SMOK PARK LVL N MECH P008	X		
001:051-013	FDO421	Alarm	SMOK PARK LVL SUB STA C	X		
001:051-014	FDO421	Alarm	SMOK PARK LVL SUB STA C	X		

001:051-015	XMS-S/D/M/SA	Alarm	PULL PK LVL Z3 LOADING DOCK	X		
001:051-016	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 8 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:051-017	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 8 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:051-018	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 8 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:051-019	XTRI-R	Status	RMT RLY PK LVL Z4 ELEV 8 FIREHAT	X		Test with Schindler 3/19/2023, ASME A17
001:051-020	XTRI-R	Status	DOOR RELAY PK LVL Z4	X		
001:051-026	FDO421	Alarm	SMOK PK LVL Z3 ELEV 7 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-027	FDO421	Alarm	SMOK PK LVL Z3 ELEV 7 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-028	FDO421	Alarm	SMOK PK LVL Z4 GEN RM P 009	X		
001:051-029	FDT421	Alarm	HEAT PK LVL Z4 ELEV 7 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-030	FDT421	Alarm	HEAT PK LVL Z4 ELEV 8 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-031	FDO421	Alarm	SMOK PK LVL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:051-032	FDO421	Alarm	SMOK PK LVL Z4 ELEV 7 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-033	FDO421	Alarm	SMOK PK LVL Z4 NORTH MECH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-034	FDO421	Alarm	SMOK PK LVL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:051-035	FDO421	Alarm	SMOK PK LVL Z4 ELEV 8 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-036	FDO421	Alarm	SMOK PK LVL Z4 CORR STAIR 6	X		
001:051-037	FDO421	Alarm	PK LVL Z4 SMOKE NORTH TELEPHONE	X		
001:051-038	FDO421	Alarm	PK LVL Z4 SMK NORTH MECH RM P008	X		
001:051-039	FDT421	Alarm	HEAT PK LVL Z4 ELEV 8 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-040	FDO421	Alarm	SMOK PK LVL Z5 NORTH MECH RM 4-B	X		
001:051-041	FDT421	Alarm	HEAT PK LVL Z4 ELEV 7 MCH RM	X		Test with Schindler 3/19/2023, ASME A17
001:051-044	XTRI-R	Status	PK LVL Z4 MECH RM AHU-21 SHUTDWN		X	NOT CONNECTED TO THE UNIT/BMS
001:051-045	FDO421	Alarm	DUCT AHU-21 PARK LVL Z4 MECH RM	X		
001:051-046	XTRI-D	Alarm	PRE-ACT GARAGE LVL.Z4	X		
001:051-048	XTRI-D	Trouble	PRE-ACT HI/LO GARAGE LVL.Z4	X		
001:051-050	XTRI-R	Alarm	PRE-ACTION ACTIVATION GARAGE Z4	X		
001:051-052	XTRI-D	Alarm/SUPV	FLOW/TAMP SW.GARAGE LVL.Z4 EMR #7	X		Test with Schindler 3/19/2023, ASME A17
001:051-054	XTRI-D	Alarm/SUPV	FLOW/TAMP SW.GARAGE LVL.Z4 EMR #8	X		Test with Schindler 3/19/2023, ASME A17
001:051-058	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z4 SALLYPORT ENT	X		
001:051-059	XMS-S/D/M/SA	Alarm	PULL PK LVL Z4 STAIR 6	X		
001:051-060	XMS-S/D/M/SA	Alarm	PULL PK LVL Z4 NORTH GARAGE	X		

001:062-001	FDO421	Alarm	SMOK JM LV Z4 NORTH PRISONER COR	X		
001:062-002	FDO421	Alarm	SMOK JM LV Z4 NORTH PRISONER COR	X		
001:062-003	FDO421	Alarm	SMOK JM LV Z5 NORTH PRISONER COR	X		
001:062-004	FDO421	Alarm	SMOK JM LV Z5 NORTH PRISONER COR	X		
001:062-005	FDO421	Alarm	SMOK JM LV Z5 N.PRIS ELV9 LBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-006	FDO421	Alarm	SMOK JM LV Z5 ELEV 9 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-007	FDO421	Alarm	SMOK JM LV Z5 ELEV 10 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-008	FDO421	Alarm	SMOK JM LV Z5 N.PRIS ELV10 LBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-009	XTRI-S	Supervisory	TAMP JM LV Z5 N.PRIS ELV10 LBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-010	FDO421	Alarm	JM LVL Z4 SMOKE HOLDING CELL 14/	X		
001:062-021	XTRI-D	Alarm/SUPV	FS/TS C LVL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:062-023	XTRI-D	Alarm/SUPV	FS/TS C LVL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:062-028	XMS-S/D/M/SA	Alarm	PULL JM LVL Z5 STAIR 7	X		
001:062-031	FDO421	Alarm	SMOK JM LVL Z5 FIRE PANEL CLOSET	X		
001:062-032	FDO421	Alarm	SMOK JM LVL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:062-033	FDO421	Alarm	SMOK JM LVL Z4 NORTH SEC CORR	X		
001:062-034	FDO421	Alarm	SMOK JM LVL Z4 NORTH SEC CORR	X		
001:062-035	FDO421	Alarm	SMOK JM LVL Z5 NORTH SEC CORR	X		
001:062-036	FDO421	Alarm	SMOK JM LVL Z5 STORAGE RM 411	X		
001:062-037	FDO421	Alarm	SMOK JM LVL Z5 NORTH SEC CORR	X		
001:062-041	FDO421	Alarm	SMOK JM LVL Z5 ELEC CLST STAIR 7	X		
001:062-050	XMS-S/D/M/SA	Alarm	PULL JM LVL Z5 VESTIBULE	X		
001:062-053	XTRI-D	Alarm/SUPV	FS/TS JM LVL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:062-055	XTRI-D	Alarm/SUPV	FS/TS JM LVL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:071-001	FDO421	Alarm	SMOK PARK LVL Z5 ELEV 10 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:071-002	FDO421	Alarm	SMOK PARK LVL Z5 ELEV 9 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:071-003	FDO421	Alarm	SMOK PARK LVL Z5 SALLYPORT	X		
001:071-004	FDO421	Alarm	SMOK PARK LVL Z5 SALLYPORT	X		
001:071-005	FDO421	Alarm	SMOK PARK LVL Z5 SALLYPORT	X		
001:071-006	FDO421	Alarm	SMOK PARK LVL Z5 SALLYPORT	X		
001:071-007	FDO421	Alarm	SMOK PARK LVL Z5 EMR ELEV 10	X		Test with Schindler 3/19/2023, ASME A17
001:071-009	XMS-S/D/M/SA	Alarm	PULL C LVL Z5 ADULT HOLD CTRL RM	X		
001:071-010	FDO421	Alarm	SMOK PARK LVL Z5 ELEV 10 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:071-011	FDT421	Alarm	HEAT PARK LVL Z5 ELEV 10 PIT	X		Test with Schindler 3/19/2023, ASME A17

001:071-012	FDO421	Alarm	SMOK C LVL Z5 ADLT HOLD COR P10A	X		
001:071-013	FDO421	Alarm	SMOK PARK LVL Z5 STAIR 7	X		
001:071-014	FDT421	Alarm	HEAT PARK LVL Z5 EMR ELEV 10	X		Test with Schindler 3/19/2023, ASME A17
001:071-015	XTRI-D	Alarm/SUPV	FS/TS PARK LVL.Z 5 ELE 9,10 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:071-017	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD COR P10	X		
001:071-018	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD COR P10	X		
001:071-019	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD SEC RM	X		
001:071-021	XTRI-D	Alarm/SUPV	FS/TS CST LVL Z5 STAIR 9	X		Test with BFPE 11/3/2022, NFPA 25
001:071-027	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD COR P10	X		
001:071-028	FDO421	Alarm	SMOK C LVL Z5 ADULT ARRAIGN HOLD	X		
001:071-029	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD COR P10	X		
001:071-031	FDO421	Alarm	SMOK C LVL Z5 ELEV 9 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:071-032	FDO421	Alarm	SMOK C LVL Z5 ELEV 10 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:071-033	XTRI-D	Alarm/SUPV	FS/TS GARAGE LVL.Z5 STAIR #7	X		Test with BFPE 11/3/2022, NFPA 25
001:071-035	FDO421	Alarm	SMOK C LVL Z5 ADULT HOLD ELEC RM	X		
001:071-038	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z4 MECH RM C110	X		
001:071-039	FDO421	Alarm	SMOK C LVL Z5 USMS E IT CLOSET	X		
001:071-041	FDO421	Alarm	SMOK C LVL Z5 ELEV 11 LOBBY			Test with Schindler 3/19/2023, ASME A17
001:071-043	FDO421	Alarm	SMOK C LVL Z4 MECH RM C110	X		
001:071-044	FDO421	Alarm	SMOK C LVL Z5 MECH RM C110	X		
001:071-045	XTRI-R	Status	RELAY PARK LVL Z5 ELEV 10	X		Test with Schindler 3/19/2023, ASME A17
001:071-046	XTRI-R	Status	RELAY PARK LVL Z5 ELEV 10	X		Test with Schindler 3/19/2023, ASME A17
001:071-047	XTRI-R	Trouble	RELAY PARK LVL Z5 SHUNT TRIP	X		Test with Schindler 3/19/2023, ASME A17
001:071-048	XTRI-R	Status	RELAY PARK LVL Z5 FIRE HAT	X		Test with Schindler 3/19/2023, ASME A17
001:071-049	XTRI-D	Alarm/SUPV	FS/TS C LVL Z5 STAIR 9	X		Test with BFPE 11/3/2022, NFPA 25
001:071-051	FDO421	Alarm	SMOK PARK LVL Z5 ELEV 9 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:071-052	FDT421	Alarm	HEAT PARK LVL Z5 ELEV 9 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:071-053	FDO421	Alarm	SMOK C LVL Z5 MECH RM C110	X		
001:071-054	XTRI-M	Supervisory	SALLY PORT CARBON MONOXIDE DET	X		
001:071-055	XTRI-M	Supervisory	SALLY PORT CARBON MONOXIDE DET	X		
001:071-056	FDO421	Alarm	SMOK C LVL Z5 MECH RM C110	X		
001:071-057	FDO421	Alarm	SMOK C LVL Z5 MECH RM C110 CLST	X		
001:071-058	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5/ SECURITY BOOTH	X		
001:071-059	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 EMR ELEV 9/10	X		

001:071-060	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 STAIR 7	X		
001:071-030	FDO421	Alarm	SMK C-Z5 USMSE ROOM C-614	X		
001:071-020	XTRI-R	Status	DOOR C LVL Z5 US MARSHAL E CLST	X		
001:074-001	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12A	X		
001:074-002	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P15	X		
001:074-003	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P15	X		
001:074-004	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P16	X		
001:074-005	FDO421	Alarm	SMK C ST LVL Z-5 GRP HLDNG M-36A	X		
001:074-006	FDO421	Alarm	SMK C ST LVL Z5 MALE CELL BLK W3	X		
001:074-007	FDO421	Alarm	SMK C ST LVL Z5 MALE CELL BLK W3	X		
001:074-008	FDO421	Alarm	SMK C ST LVL Z-5 GRP HLDNG M-35A	X		
001:074-009	FDO421	Alarm	SMOKE C ST LVL Z-5 HOLDING M-33A	X		
001:074-010	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12	X		
001:074-011	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12	X		
001:074-012	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W2A	X		
001:074-013	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W2B	X		
001:074-014	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W2B	X		
001:074-015	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W2A	X		
001:074-016	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P16	X		
001:074-017	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P16	X		
001:074-018	FDO421	Alarm	SMK C LV Z5 ADULT HLDNG CORR P16	X		
001:074-019	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W1A	X		
001:074-020	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W1B	X		
001:074-021	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W1B	X		
001:074-022	FDO421	Alarm	SMK C ST LV Z5 MALE CELL BLK W1A	X		
001:074-023	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12	X		
001:074-024	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12	X		
001:074-025	FDO421	Alarm	SMOKE C ST LVL Z-5 CORR P-12	X		
001:074-026	FDO421	Alarm	SD C LVL Z5 GROUP HOLDING VESTIB	X		
001:074-027	FDO421	Alarm	SD C LVL Z4 HOLDING CELL	X		
001:074-028	FDO421	Alarm	SD C LVL Z4 HOLDING CELL	X		
001:074-029	FDO421	Alarm	SD C LVL Z4 FEMALE CELL BLK W4	X		
001:074-030	FDO421	Alarm	SD C LVL Z4 FEMALE CELL BLK W4	X		
001:074-031	FDO421	Alarm	SD C LVL Z4 FEMALE CELL BLK W4	X		

001:074-033	FDO421	Alarm	SD C LVL Z5 CORRIDOR P10A	X		
001:074-034	FDO421	Alarm	SD C LVL Z5 CORRIDOR P10A	X		
001:074-035	FDO421	Alarm	SD C LVL Z5 VESTIBILE P5	X		
001:074-036	FDO421	Alarm	SD C LVL Z4 CORRIDOR P4	X		
001:074-037	FDO421	Alarm	SD C LVL Z4 CORRIDOR P4	X		
001:074-038	FDO421	Alarm	SD C LVL Z4 CORRIDOR P3	X		
001:074-039	FDO421	Alarm	SD C LVL Z4 SECURE VESTIBILE CS3	X		
001:074-040	FDO421	Alarm	SD C LVL Z4 PUBLIC VESTIBILE CS1	X		
001:074-041	FDO421	Alarm	SD C LVL Z5 CORRIDOR P6	X		
001:074-042	FDO421	Alarm	SD C LVL Z5 CORRIDOR P6	X		
001:074-043	FDO421	Alarm	SD C LVL Z5 CORRIDOR P6	X		
001:074-044	FDO421	Alarm	SD C LVL Z5 CORRIDOR P6	X		
001:072-005	FDO421	Alarm	SD C LVL Z5 ADULT HOLD CELL F10A	X		
001:072-006	FDO421	Alarm	SD C LVL Z5 FEMALE CELL BLK K1-5	X		
001:072-007	FDO421	Alarm	SD C LVL Z5 ADULT HOLD CELL F10A	X		
001:072-008	FDO421	Alarm	SD C LVL Z5 FEMALE CELL BLK K1-5	X		
001:072-009	FDO421	Alarm	SD C LVL Z5 ADULT HOLD OFC S-5	X		
001:072-010	FDO421	Alarm	SD C LVL Z5 ADLT HLD SPV OFC S-7	X		
001:072-011	FDO421	Alarm	SD C LVL Z5 ADULT HOLD CORR S10	X		
001:072-012	FDO421	Alarm	SMOKE C LVL Z5 ADULT HOLD COR P8	X		
001:072-013	FDO421	Alarm	SMOKE C LVL ADULT HOLD PRIS VEST	X		
001:072-014	FDO421	Alarm	SMOKE C LVL ADULT HOLD PRIS VEST	X		
001:072-017	FDO421	Alarm	SD C LVL Z5 ADULT HOLD ELEC E1	X		
001:072-018	FDO421	Alarm	SD C LVL Z5 ADULT HOLD VEST SP1A	X		
001:072-019	FDO421	Alarm	SD C LVL Z5 ADULT CELL BLK K16	X		
001:072-020	FDO421	Alarm	SD C LVL Z5 ADULT PROCESSING S11	X		
001:072-021	FDO421	Alarm	SD C LVL Z5 ADULT HOLD VEST SP2A	X		
001:072-022	FDO421	Alarm	SD C LVL Z5 ADULT HOLD STORE SP3	X		
001:072-023	FDO421	Alarm	SD C LVL Z5 ADULT CELL BLK K16	X		
001:072-024	FDO421	Alarm	SD C LVL Z5 ADULT HOLD VEST SP5A	X		
001:073-060	FDO421	Alarm	SMOKE JM LVL ZN5 STAIR 7	X		
001:073-002	FDO421	Alarm	SMOKE C ST Z5 JHC ELEV 10 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:073-003	FDO421	Alarm	SMOKE C ST Z5 JHC CORR 500A	X		
001:073-004	FDO421	Alarm	SMOKE C ST Z5 JHC CORR 550C @ 51	X		

001:073-005	FDO421	Alarm	SMOKE C ST Z5 JHC CORRIDOR 500B	X		
001:073-006	FDO421	Alarm	SMOKE C ST Z5 JHC CORRIDOR 500B	X		
001:073-007	XMS-S/D/M/SA	Alarm	PULL C ST Z5 JHC CONTROL RM	X		
001:073-010	FDO421	Alarm	SMOKE JM JHC FML HOLDING 450A	X		
001:073-011	FDO421	Alarm	SMOKE JM JHC AT-RISK CORR 450C	X		
001:073-013	FDO421	Alarm	SMOKE JM JHC AT-RISK CORR 450C	X		
001:073-016	FDO421	Alarm	SMOKE JM Z5 JHC ELEV 10 LOBBY 50	X		
001:073-017	FDO421	Alarm	SMOKE JM Z5 JHC CORR IDOR 500B	X		
001:073-018	FDO421	Alarm	SMK JM Z5 JHC FEMALE HOLD 500C	X		
001:073-019	FDO421	Alarm	SMOKE JM Z5 JHC MALE HOLD 500E	X		
001:073-020	FDO421	Alarm	SMOKE JM Z5 JHC CORRIDOR 500D	X		
001:073-021	FDO421	Alarm	SMOKE JM Z5 JHC MALE HOLDING 500	X		
001:073-022	FDO421	Alarm	SMOKE JM Z5 JHC CORRIDOR 500F	X		
001:073-023	FDO421	Alarm	SMOKE JM Z5 JHC BOND 517	X		
001:073-024	FDO421	Alarm	SMOKE JM Z5 JHC CORRIDOR 5000G	X		
001:073-025	FDO421	Alarm	SMOKE JM Z5 JHC ELEC CLOSET RM 5	X		
001:073-026	XMS-S/D/M/SA	Alarm	PULL JM JHC Z5 AT-RISK CNTRL RM	X		
001:073-027	XMS-S/D/M/SA	Alarm	PULL JM Z5 JHC MAIN CONTROL RM 5	X		
001:073-038	XMS-S/D/M/SA	Alarm	PULL PARK LVL Z5 JHC VESTIBULE 1	X		
001:073-042	FDO421	Alarm	DUCT C ST Z5 JHC AHU SUP MN CONT	X		
001:073-043	FDO421	Alarm	DUCT C ST Z5 JHC AHU RET MN CONT	X		
001:073-045	FDO421	Alarm	DUCT C ST Z5 JHC AHU SUP C510	X		
001:073-046	FDO421	Alarm	DUCT JM Z5 JHC AHU SUP CORR 450C	X		
001:073-047	FDO421	Alarm	DUCT JM Z5 JHC AHU RET CORR 450C	X		
001:073-048	FDO421	Alarm	DUCT JM Z5 JHC AHU SUP CNTRL RM	X		
001:073-049	FDO421	Alarm	DUCT JM Z5 JHC AHU RET CNTRL RM	X		
001:073-050	FDO421	Alarm	DUCT JM Z5 JHC AHU SUP CORR 500E	X		
001:073-051	XTRI-R	Status	RELAY C ST JHC	X		
001:073-052	XTRI-R	Status	RELAY C ST JHC	X		
001:073-053	XTRI-R	Status	RELAY PARKING JHC	X		
001:073-054	XTRI-R	Status	RELAY C ST JHC	X		
001:073-055	XTRI-R	Status	RELAY JM LVL JHC CORR 450C	X		
001:073-056	XTRI-R	Status	RELAY JM LVL JHC CORR 450C	X		
001:073-057	XTRI-R	Status	RELAY JM LVL JHC CNTRL RM 502	X		

001:073-058	XTRI-R	Status	RELAY JM LVL JHC CNTRL RM 502	X		
001:073-059	XTRI-R	Status	RELAY JM LVL JHC CORR 500E	X		
001:073-061	TSM-1X	Relay	TSM-1X @ FOR DD 73:42	X		
001:073-062	TSM-1X	Relay	TSM-1X @ FOR DD 73:43	X		
001:073-063	TSM-1X	Relay	TSM-1X @ FOR DD 73:45	X		
001:073-064	TSM-1X	Relay	TSM-1X @ FOR DD 73:46	X		
001:073-065	TSM-1X	Relay	TSM-1X @ FOR DD 73:47	X		
001:073-066	TSM-1X	Relay	TSM-1X @ FOR DD 73:48	X		
001:073-067	TSM-1X	Relay	TSM-1X @ FOR DD 73:49	X		
001:073-068	TSM-1X	Relay	TSM-1X @ FOR DD 73:50	X		
001:092-001	FDO421	Alarm	SMOK 2ND FL Z6 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:092-002	FDO421	Alarm	SD 2F Z6 SEC COR JURY RM 217	X		
001:092-003	FDO421	Alarm	SD 2F Z6 SEC COR JURY RM 218	X		
001:092-004	FDO421	Alarm	SD 2ND FL Z6 SEC COR JURY RM219	X		
001:092-006	FDO421	Alarm	SMOK 2ND FL Z4 COPY RM JURY 119	X		
001:092-007	FDO421	Alarm	SMOK 2ND FL Z4 SOUTH PRISON COR	X		
001:092-008	FDO421	Alarm	SMOK 2ND FL Z4 SOUTH PRISON COR	X		
001:092-009	FDO421	Alarm	SMOK 2ND FL Z3 SOUTH PRISON COR	X		
001:092-010	FDO421	Alarm	SMOK 2ND FL Z3 SOUTH PRISON COR	X		
001:092-011	FDO421	Alarm	SMOK 3RD FL Z6 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:092-015	FDO421	Alarm	SMOK 3RD FL Z4 SOUTH SEC CLOSET	X		
001:092-016	FDO421	Alarm	SD 3RD FL Z4 SEC COR BY STAIR-8	X		
001:092-017	FDO421	Alarm	SD 3RD FL Z4 SEC COR COPY 3-JJ	X		
001:092-019	FDO421	Alarm	SMOK 3RD FL Z4 ELEV 11 MACH RM	X		Test with Schindler 3/19/2023, ASME A17
001:092-020	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z6 STAIR 8	X		
001:092-021	FDO421	Alarm	SMOK 2ND FL Z6 STAIR 8	X		
001:092-022	FDO421	Alarm	SMOK 3RD FL Z6 STAIR 8	X		
001:092-023	FDO421	Alarm	SMOK 2ND FL Z6 STAIR 9	X		
001:092-024	FDO421	Alarm	SMOK 3RD FL Z6 STAIR 9	X		
001:092-025	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR318-319	X		
001:092-026	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR320-321	X		
001:092-027	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR316-317	X		
001:092-028	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR218-219	X		
001:092-029	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR220-221	X		

001:092-030	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z6 STAIR 8	X		
001:092-031	FDO421	Alarm	SD 2ND FL Z6 SEC COR JURY RM220	X		
001:092-032	FDO421	Alarm	SD 2F Z6 SEC CORR BY JURY RM 235	X		
001:092-033	FDO421	Alarm	SMOK 2ND FL Z6 CLOSET BY STAIR 9	X		
001:092-034	FDO421	Alarm	SMOK 2ND FL Z5 ELEC CLOSET F	X		
001:092-035	FDO421	Alarm	SMOK 2ND FL Z5 COMM CLOSET J	X		
001:092-036	FDO421	Alarm	SMOK 2ND FL Z6 SEC COR COM 2-J	X		
001:092-037	FDO421	Alarm	SD 2ND FL Z5 SEC COR CHAMBER2530	X		
001:092-038	FDO421	Alarm	SMOK PRIS LVL Z5 ELEV 11 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:092-039	FDO421	Alarm	SMOK 2ND FL Z5 SOUTH PRISON COR	X		
001:092-040	FDO421	Alarm	SMOK 3 FL Z4 HOLD BLK CR216-217	X		
001:092-041	FDO421	Alarm	SMOK 3RD FL Z5 SOUTH SEC CLOSET	X		
001:092-042	FDO421	Alarm	SMOK 3RD FL Z5 COMM CLOSET J	X		
001:092-043	FDO421	Alarm	SMOK 3RD FL Z5 ELEC CLOSET 3F	X		
001:092-047	FDO421	Alarm	SMOK 3RD FL Z5 EMR ELEV 11	X		Test with Schindler 3/19/2023, ASME A17
001:092-048	FDO421	Alarm	SD 3RD FL Z5 SEC CORR CHAMB 3530	X		
001:092-049	FDT421	Alarm	HEAT 3RD FL Z5 ELE MACH RM 11	X		Test with Schindler 3/19/2023, ASME A17
001:092-050	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z6 STAIR 9	X		
001:092-051	FDO421	Alarm	SD 2ND Z4 COMM CLOSET JURY RM220	X		
001:092-052	FDO421	Alarm	SD 3RD Z4 COMM CLOSET JURY RM320	X		
001:092-053	FDO421	Alarm	SMOK 2ND FL Z2 SOUTH PRISON CORR	X		
001:092-054	FDO421	Alarm	SMOK 2ND FL Z2 SOUTH PRISON CORR	X		
001:092-055	XTRI-R	Status	RMT RLY 3RD FL Z5 ELEV 11 PRI RE	X		Test with Schindler 3/19/2023, ASME A17
001:092-056	XTRI-R	Status	RMT RLY 3RD FL Z5 ELEV 11 ALT RE	X		Test with Schindler 3/19/2023, ASME A17
001:092-057	XTRI-R	Status	RMT RLY 3RD FL Z5 ELEV 11 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:092-058	XTRI-R	Status	RMT RLY 3RD FL Z5 ELEV 11 FIREHA	X		Test with Schindler 3/19/2023, ASME A17
001:092-059	FDO421	Alarm	SMOK 2ND FL Z2 SOUTH PRISON CORR	X		
001:091-002	FDO421	Alarm	SMOK INDIANA Z6 STAIR 9	X		
001:091-003	FDO421	Alarm	SD 1ST INDNA Z4 COM CLOS 1-J	X		
001:091-011	FDO421	Alarm	SMOK INDIANA Z6 STAIR 8	X		
001:091-030	XTRI-S	Alarm	IND Z4 SERVER RM ANSUL SYSTEM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-031	XTRI-S	Trouble	IND Z4 SERVER RM ANSUL SYSTEM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-032	XTRI-S	Supervisory	IND Z4 SERVER RM ANSUL SYSTEM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-033	XTRI-S	Trouble	IND Z4 SERVER RM FM 200	X		Test with BFPE 1/28/2023, NFPA 2001

001:091-034	XTRI-S	Supervisory	IND Z4 SERVER RM FM 200	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-035	FDO421	Alarm	SMOK INDNA Z4 UNR FL SERVER RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-036	FDO421	Alarm	SMOK INDIANA Z4 SERVER RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-037	FDO421	Alarm	SMOK INDIANA SECURITY NEW OFFICE	X		
001:091-038	FDO421	Alarm	SD 1ST FL Z5 HOLD CELL 119/120	X		
001:091-039	FDO421	Alarm	SD 1ST FL Z4 HOLD CELL 117/118	X		
001:091-040	FDO421	Alarm	SD 1ST FL Z4 HOLD CELL 116	X		
001:091-041	FDO421	Alarm	SMOK INDNA Z4 SERVER RM	X		
001:091-042	FDO421	Alarm	SMOK INDIANA Z6 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:091-047	FDO421	Alarm	SMOK INDNA Z4 SERVER RM	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-048	XTRI-S	Alarm	IND Z4 SERVER RM FM 200	X		Test with BFPE 1/28/2023, NFPA 2001
001:091-050	XMS-S/D/M/SA	Alarm	PULL INDIANA Z6 STAIR 8	X		
001:091-053	FDO421	Alarm	SMOK INDNA Z5 ELEC CLOSET 1-F	X		
001:091-054	FDO421	Alarm	SMOK INDNA Z5 COM CLOSET 1-J	X		
001:091-056	FDO421	Alarm	SMOK INDNA Z5 SEC COR CHAM 1530	X		
001:101-012	FDO421	Alarm	SD 1ST FL Z4 HOLD CELL 111/112	X		
001:101-013	FDO421	Alarm	SD 1ST FL Z4 HOLD CELL 113/114	X		
001:101-031	FDO421	Alarm	SMOK INDIANA Z4 MAIN LOBBY EAST	X		
001:101-032	FDO421	Alarm	SMOK INDIANA Z4 MAIN LOBBY EAST	X		
001:101-033	FDO421	Alarm	SMOK INDIANA Z4 EAST PUBLIC CORR	X		
001:101-034	FDO421	Alarm	SMOK INDIANA Z4 EAST PUBLIC CORR	X		
001:101-035	FDO421	Alarm	SMOK INDIANA Z4 EAST PUBLIC CORR	X		
001:101-036	FDO421	Alarm	SMOK INDIANA Z4 EAST PUBLIC CORR	X		
001:101-037	FDO421	Alarm	SMOK INDIANA Z4 EAST PUBLIC CORR	X		
001:101-038	FDO421	Alarm	SMOK INDIANA Z4 NORTH SEC CORR	X		
001:101-039	FDO421	Alarm	SMOK INDIANA Z4 NORTH SEC CORR	X		
001:101-040	FDO421	Alarm	SMOK INDIANA Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:101-041	FDO421	Alarm	SMOK INDIANA Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:101-042	FDO421	Alarm	SMOK INDIANA Z4 ELEC CLOSET C	X		
001:101-043	FDO421	Alarm	SMOK INDIANA Z4 COMM CLOSET E	X		
001:101-051	XTRI-R	Status	REL SECURE CORR Z4 DOOR RLS	X		
001:101-052	XTRI-R	Status	RELAY INDIANA Z4 DOOR REL CORR	X		
001:101-053	XTRI-R	Status	RELAY INDIANA Z4 DOOR REL CORR	X		
001:101-059	FDO421	Alarm	SMOKE IND Z4 STAIR 6	X		

001:101-060	XMS-S/D/M/SA	Alarm	PULL INDIANA Z4 STAIR 6	X		
001:102-001	FDO421	Alarm	SMOK 2ND FL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:102-002	FDO421	Alarm	SMOK 2ND FL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:102-003	FDO421	Alarm	SMOK 2ND FL Z4 ELEC CLOSET C	X		
001:102-004	FDO421	Alarm	SMOK 2ND FL Z4 COMM CLOSET E	X		
001:102-005	FDO421	Alarm	SMOK 2ND FL Z4 NORTH SEC CORR	X		
001:102-006	FDO421	Alarm	SMOK 2ND FL Z4 NORTH SEC CORR	X		
001:102-008	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-009	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-010	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-011	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-012	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-013	FDO421	Alarm	SMOK 2ND FL Z4 EAST PUBLIC CORR	X		
001:102-014	FDO421	Alarm	SMOK 2ND FL Z4 ATRIUM EAST	X		
001:102-015	FDO421	Alarm	SMOK 2ND FL Z4 ATRIUM EAST	X		
001:102-016	FDO421	Alarm	SMOK 2ND FL Z4 STAIR 6	X		
001:102-017	FDO421	Alarm	SMOK 3RD FL Z4 STAIR 6	X		
001:102-018	XTRI-R	Status	RELAY 2ND FL Z4 DOOR RLS	X		
001:102-019	XTRI-R	Status	RELAY 2ND FL Z4 DOOR RLS	X		
001:102-020	XTRI-R	Status	REL 2ND FL Z4 SEC COR DOOR RLS	X		
001:102-022	XTRI-R	Status	RELAY 2ND FL Z4 DOOR RLS	X		
001:102-023	XTRI-R	Status	RELAY 2ND FL Z4 DOOR RLS	X		
001:102-024	XTRI-R	Status	REL 3RD FL Z4 SEC COR DOOR RLS	X		
001:102-025	FDO421	Alarm	SD 3RD FL Z4 HOLD CELL CR310/311	X		
001:102-026	FDO421	Alarm	SD 3RD FL Z4 HOLD CELL CR312/313	X		
001:102-027	FDO421	Alarm	SD 2ND FL Z4 HOLD CELL CR210/211	X		
001:102-028	FDO421	Alarm	SD 2ND FL Z4 HOLD CELL CR212/213	X		
001:102-030	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z4 STAIR 6	X		
001:102-031	FDO421	Alarm	SMOK 3RD FL Z4 ATRIUM EAST	X		
001:102-032	FDO421	Alarm	SMOK 3RD FL Z4 ATRIUM EAST	X		
001:102-033	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		
001:102-034	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		

001:102-035	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		
001:102-036	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		
001:102-037	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		
001:102-038	FDO421	Alarm	SMOK 3RD FL Z4 EAST PUBLIC CORR	X		
001:102-041	FDO421	Alarm	SMOK 3RD FL Z4 NORTH SEC CLOSET	X		
001:102-042	FDO421	Alarm	SMOK 3RD FL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:102-043	FDO421	Alarm	SMOK 3RD FL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:102-044	FDO421	Alarm	SMOK 3RD FL Z4 NORTH SEC CORR	X		
001:102-045	FDO421	Alarm	SMOK 3RD FL Z4 NORTH SEC CORR	X		
001:102-046	FDO421	Alarm	SMOK 3RD FL Z4 ELEC CLOSET C	X		
001:102-047	FDO421	Alarm	SMOK 3RD FL Z4 COMM CLOSET E	X		
001:102-052	XTRI-R	Status	RELAY 3RD FL Z4 DOOR RLS	X		
001:102-053	XTRI-R	Status	RELAY 3RD FL Z4 DOOR RLS	X		
001:102-054	XTRI-R	Status	RELAY 3RD FL Z4 DOOR RLS	X		
001:102-055	XTRI-R	Status	RELAY 3RD FL Z4 DOOR RLS	X		
001:102-060	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z4 STAIR 6	X		
001:111-001	FDO421	Alarm	SMOK 2F Z5 Z5 COR BY CHMBR 2430	X		
001:111-002	FDO421	Alarm	SMOK 2F Z5 Z5 COR BY CHMBR 2430	X		
001:111-003	FDO421	Alarm	SMOK 1ST FL Z5 ELEV10 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:111-004	FDO421	Alarm	SMOK 2F Z5 JANITOR CLOSET 2-JJ	X		NO CEILING > DETECTOR FREE-AIR
001:111-005	FDO421	Alarm	SMOK 2F Z5 ELEC CLOSET 2-D	X		
001:111-006	FDO421	Alarm	SMOK 2ND FL Z5 COMM CLOSET F	X		
001:111-007	FDO421	Alarm	SMOK 2F Z5 CORR BY OFFICE 2500	X		
001:111-008	FDO421	Alarm	SMOK 2F Z5 CORR BY CHMBR 2510	X		
001:111-009	FDO421	Alarm	SMOK 2F Z5 CORR BY CHMBR 2520	X		
001:111-010	FDO421	Alarm	SMOK 2F Z5 CORR BY COURT RM 221	X		
001:111-011	FDO421	Alarm	SMOK 2F Z5 CORR BY COURT RM 221	X		
001:111-012	FDO421	Alarm	SMOK 2ND FL Z5 ELEV 9 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:111-013	FDO421	Alarm	SMOK 2ND FL Z5 NORTH PRISON COR	X		
001:111-014	FDO421	Alarm	SMOK 2ND FL Z5 NORTH PRISON COR	X		
001:111-015	FDO421	Alarm	SMOK 2ND FL Z5 NORTH PRISON COR	X		
001:111-016	FDO421	Alarm	SMOK 2ND FL Z4 NORTH PRISON COR	X		

001:111-017	FDO421	Alarm	SMOK 1ST FL Z5 STAIR 7	X		
001:111-018	FDO421	Alarm	SMOK 1ST FL Z5 NORTH SEC CORR	X		
001:111-019	FDO421	Alarm	SMOK 1F Z5 CORR BY CLOSET 1-JJ	X		
001:111-020	FDO421	Alarm	SMOK 2ND FL Z5 STAIR 7	X		
001:111-021	XTRI-D	Alarm/SUPV	FS/TS 2ND FL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:111-023	XMS-S/D/M/SA	Alarm	PULL 1ST FL Z5 SUITE 1500 EXIT	X		
001:111-024	FDO421	Alarm	SD 1F Z4 CORR BY CLOSET 1-JJ	X		
001:111-025	FDO421	Alarm	SD INDIANA AVE HOLD CELL 116B	X		
001:111-026	FDO421	Alarm	SD 2ND FL Z5 HOLD CELL CR214/215	X		
001:111-027	FDO421	Alarm	SMOK 2ND FL Z5 BY CHAMBER 2440	X		
001:111-029	FDO421	Alarm	SMOK 1ST FL Z5 STAIR 7	X		
001:111-030	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z5 STAIR 7	X		
001:111-031	FDO421	Alarm	SMOK INDIANA Z5 EAST PUBLIC CORR	X		
001:111-032	FDO421	Alarm	SMOK INDIANA Z5 EAST PUBLIC CORR	X		
001:111-033	FDO421	Alarm	SMOK INDIANA Z5 NORTH SEC CORR	X		
001:111-034	FDO421	Alarm	SMOK INDIANA Z5 NORTH SEC CORR	X		
001:111-035	FDO421	Alarm	SD IND Z5 CORR BY COM CLST 1-F	X		
001:111-036	FDO421	Alarm	SMK INDIANA Z5 BY CHAMBER 1510	X		
001:111-037	FDO421	Alarm	SMK INDIANA Z5 BY CHAMBER 1520	X		
001:111-038	FDO421	Alarm	SMOK 2ND FLR Z5 2440 HALLWAY	X		
001:111-039	FDO421	Alarm	SMK INDIANA Z5 ELEC CLOSET 1-D	X		
001:111-040	FDO421	Alarm	SMOK INDIANA Z5 EQUIP STORG 101	X		
001:111-043	FDO421	Alarm	SMK IND Z5 CORR BY CHAMBER 1440	X		
001:111-044	FDO421	Alarm	SMK IND Z5 CORR BY CHAMBER 1430	X		
001:111-045	FDO421	Alarm	SMOK INDIANA Z5 IN OFFICE 1230	X		
001:111-051	XTRI-D	Alarm/SUPV	FS/TS INDIANA Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:111-053	FDO421	Alarm	SD INDIANA Z5 A/V RM COURTRM 115	X		
001:111-054	FDO421	Alarm	SMOK INDIANA Z5 VESTIBULE 115D	X		
001:111-055	FDO421	Alarm	SD IND AVE Z5 HOLD CELL 116A	X		
001:111-056	FDO421	Alarm	SD IND AVE Z5 HOLD CELL VST 116	X		
001:111-059	FDT421	Alarm	HEAT 1ST FL Z5 ELEV10 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:111-060	XMS-S/D/M/SA	Alarm	PULL INDIANA Z5 STAIR 7	X		

001:112-002	FDO421	Alarm	SMOK 4TH FL Z5 CLOSET	X		SPACE UNDER CONSTRUCTION/COOPER
001:112-003	FDO421	Alarm	SMOK 4TH FL Z5 ELEC CLOSET D	X		
001:112-006	FDO421	Alarm	SD 4F Z5 PUB CORR BY OFFICE 4450	X		SPACE UNDER CONSTRUCTION/COOPER
001:112-007	FDO421	Alarm	SD 4F Z5 PUB CORR BY OFFICE 4475	X		SPACE UNDER CONSTRUCTION/COOPER
001:112-008	FDO421	Alarm	SD 4F Z5 PUBLIC CORR BY ELEC 4D	X		SPACE UNDER CONSTRUCTION/COOPER
001:112-011	FDO421	Alarm	SMOK 4TH FL Z5 COMM CLOSET F	X		
001:112-012	FDO421	Alarm	SMOK 4TH FL Z5 OFFICE 4475	X		
001:112-014	XTRI-R	Trouble	4F Z5 RM 4485 PAD-4 /STAIR 7	X		ROOM FULL OF CONSTRUCTION MTRLS.
001:112-017	FDO421	Alarm	SMOK 3RD FL Z5 STAIR 7	X		
001:112-018	FDO421	Alarm	SMOK 4TH FL Z5 STAIR 7	X		SPACE UNDER CONSTRUCTION/COOPER
001:112-019	FDO421	Alarm	SD 3RD FL Z5 HOLD CELL CR314/315	X		
001:112-021	XTRI-D	Alarm/SUPV	FS/TS 4TH FL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:112-029	FDO421	Alarm	SD 3F Z5 SEC CORR BY CHMBR 3440	X		
001:112-030	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z5 STAIR 7	X		
001:112-031	FDO421	Alarm	SMOK 3RD FL Z5 NORTH SEC CORR	X		
001:112-032	FDO421	Alarm	SMOK 3F Z5 SEC CORR BY STAIR 7	X		
001:112-033	FDO421	Alarm	SD 3F Z5 SEC CORR BY COPY 3-MM	X		
001:112-034	FDO421	Alarm	SMOK 3RD FL Z5 ELV MECH RM #9	X		
001:112-035	FDO421	Alarm	SMOK 3RD FL Z5 CHAMBERS 3500	X		
001:112-036	FDO421	Alarm	SMOK 3RD FL Z5 ELEC CLOSET	X		
001:112-037	FDO421	Alarm	SMOK 3RD FL Z5 COMM CLOSET	X		
001:112-039	FDO421	Alarm	SMK 3F Z5 SEC COR BY CHAMBER 350	X		
001:112-038	FDO421	Alarm	SMOK 3F Z5 COPY RM 3-MM	X		
001:112-040	FDO421	Alarm	SMK 3F Z5 SEC CORR BY CHMBR 3510	X		
001:112-041	FDO421	Alarm	SMK 3F Z5 SEC CORR BY CHMBR 3520	X		
001:112-042	FDO421	Alarm	SMK 3F Z5 PUBLIC CORR BY CR 321	X		
001:112-043	FDO421	Alarm	SMOK 3F Z5 PUBLIC CORR BY CR 320	X		
001:112-044	FDO421	Alarm	SMOK 3F Z5 CLOSET 3-NN	X		
001:112-046	XTRI-R	Status	RELAY 3RD FL Z5 PRI-RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:112-047	XTRI-R	Status	RELAY 3RD FL Z5 ALT-RECALL	X		Test with Schindler 3/19/2023, ASME A17

001:112-048	XTRI-R	Trouble	RELAY 3RD FL Z5 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:112-049	XTRI-R	Status	RELAY 3RD FL Z5 FIRE HAT	X		Test with Schindler 3/19/2023, ASME A17
001:112-051	FDT421	Alarm	HEAT 3RD FL Z5 ELV #9 MECH RM	X		Test with Schindler 3/19/2023, ASME A17
001:112-054	FDO421	Alarm	SMOKE 3F Z5 ELEV 9 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:112-055	XTRI-D	Alarm/SUPV	FS/TS 3RD FL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:112-060	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z5 STAIR 7	X		
001:121-001	FDO421	Alarm	SMK INDIANA Z1 JANITOR CLT 1-AA	X		
001:121-002	FDO421	Alarm	SMOKE INDIANA Z1 STOR CLOS 11B	X		
001:121-003	FDO421	Alarm	SMK INDIANA Z1 ELEC CLOSET 1-A	X		
001:121-004	FDO421	Alarm	SMOK INDIANA Z1 COMM CLOSET 1-A	X		
001:121-005	FDO421	Alarm	SMOK INDIANA Z1 CLOSET	X		
001:121-006	FDO421	Alarm	SD INDIANA Z1 SEC COR BY CR 106	X		
001:121-007	FDO421	Alarm	SD INDIANA Z1 SEC COR BY CR 108	X		
001:121-008	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 107	X		
001:121-009	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 106	X		
001:121-010	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 106	X		
001:121-011	FDO421	Alarm	SMK INDIANA SEC COR Z1 STAIR 1	X		
001:121-012	FDO421	Alarm	SMK INDIANA SEC COR Z2 STAIR 2	X		
001:121-013	FDO421	Alarm	SMOK INDIANA Z1 STAIR 1	X		
001:121-014	FDO421	Alarm	SMOK INDIANA Z2 STAIR 2	X		
001:121-015	FDO421	Alarm	SMOK INDIANA Z2 HOLDING CELL	X		
001:121-019	XMS-S/D/M/SA	Alarm	PULL INDIANA Z1 STAIR 1	X		
001:121-020	XMS-S/D/M/SA	Alarm	PULL INDIANA Z1 SEC COR STAIR 1	X		
001:121-021	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 110	X		
001:121-022	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 109	X		
001:121-023	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 104	X		
001:121-024	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 104	X		
001:121-025	FDO421	Alarm	SD IND Z1 SEC PUB COR BY CR 104	X		
001:121-026	FDO421	Alarm	SMOK INDIANA Z3 COMM CLOSET G	X		
001:121-039	XMS-S/D/M/SA	Alarm	PULL INDIANA Z2 SEC COR STAIR 2	X		
001:121-040	XMS-S/D/M/SA	Alarm	PULL INDIANA Z2 STAIR 2	X		
001:121-041	FDO421	Alarm	SMOK INDIANA Z3 MAIN LOBBY WEST	X		

001:121-042	FDO421	Alarm	SMOK INDIANA Z3 MAIN LOBBY WEST	X		
001:121-043	FDO421	Alarm	SMOK INDIANA Z3 MAIN LOBBY EAST	X		
001:121-044	FDO421	Alarm	SMOK INDIANA Z3 MAIN LOBBY EAST	X		
001:121-045	FDO421	Alarm	SMOK INDIANA Z3 SEC CORR BY COMM	X		
001:121-046	FDO421	Alarm	SMK Z3 SEC COR BY JURY RM 111	X		
001:121-051	XTRI-R	Status	RMT RLY INDIANA Z2 DOOR RLS	X		
001:121-052	XTRI-R	Status	RMT RLY INDIANA Z2 DOOR RLS	X		
001:121-057	XMS-S/D/M/SA	Alarm	PULL INDIANA Z3 MAIN ENTRANCE	X		
001:121-058	XMS-S/D/M/SA	Alarm	PULL INDIANA Z3 MAIN ENTRANCE	X		
001:121-059	XMS-S/D/M/SA	Alarm	PULL INDIANA Z3 GUARD STATION	X		
001:121-060	XMS-S/D/M/SA	Alarm	PULL INDIANA Z3 GUARD STATION	X		
001:122-002	FDO421	Alarm	SMK 2F Z1 STORAGE 2_BB	X		
001:122-003	FDO421	Alarm	SMOK 2F Z1 ELEC CLOSET 1-A	X		
001:122-004	FDO421	Alarm	SMOK 2ND FL Z1 COMM CLOSET A	X		
001:122-005	FDO421	Alarm	SMOK 2ND FL Z1 COMM CLOSET A	X		
001:122-006	FDO421	Alarm	SD 2F Z1 SEC PUB COR BY CR 200	X		
001:122-007	FDO421	Alarm	SD 2F Z1 SEC PUB COR BY CR 201	X		
001:122-008	FDO421	Alarm	SMOK 2ND FL Z1 A/V CLOSET 204B	X		
001:122-009	FDO421	Alarm	SMK 2F Z1 SEC COR BY COURT 205	X		
001:122-010	FDO421	Alarm	SMK 2F Z1 SEC COR BY COURT 204	X		
001:122-011	FDO421	Alarm	SMOK 2ND FL Z1 STAIR 1	X		
001:122-012	FDO421	Alarm	SMOK 2ND FL Z2 STAIR 2	X		
001:122-013	FDO421	Alarm	SMOK 2ND FL Z1 STAIR 1	X		
001:122-014	FDO421	Alarm	SMOK 2ND FL Z2 STAIR 2	X		
001:122-015	FDO421	Alarm	SMOK 2ND FL Z2 HEARING RM CLOSET	X		
001:122-016	FDO421	Alarm	SMOK 2ND FL Z1 CLOSET 201	X		
001:122-017	FDO421	Alarm	SMOK 2ND FL Z2 EQUIP STOR RM 202	X		
001:122-019	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z1 STAIR 1	X		
001:122-020	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z1 STAIR 1	X		
001:122-021	FDO421	Alarm	SD 2F Z1 SEC PUB CORR COURT 202	X		
001:122-022	FDO421	Alarm	SD 2F Z1 SEC PUB CORR COURT 203	X		

001:122-025	FDO421	Alarm	SMK 2F Z1 SEC COR BY COURT 206	X		
001:122-031	XTRI-R	Status	RELAY 2ND FL Z2 DOOR REL CORR	X		
001:122-039	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z2 STAIR 2	X		
001:122-040	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z2 STAIR 2	X		
001:122-041	FDO421	Alarm	SMOK 2ND FL Z3 ATRIUM WEST	X		
001:122-042	FDO421	Alarm	SMOK 2ND FL Z3 ATRIUM EAST	X		
001:122-043	FDO421	Alarm	SMOK 2ND FL Z3 ATRIUM EAST	X		
001:122-044	FDO421	Alarm	SMOK 2ND FL Z3 OFFICE 2300	X		
001:122-045	FDO421	Alarm	SMOK 2ND FL Z3 OFFICE 2300	X		
001:122-046	FDO421	Alarm	SMK 2F Z3 SEC COR BY OFFICE 2300	X		
001:122-047	FDO421	Alarm	SMK 2F Z3 SEC COR BY JURY RM 210	X		
001:126-001	HTRI-M	Trouble	STROBE PANEL XLSRV-11	X		
001:126-002	FDO421	Alarm	SMOK 3RD FL Z1 A/V CLOS 301B	X		
001:126-003	FDO421	Alarm	SMOK 3RD FL Z2 A/V CLOS 302B	X		
001:126-004	FDO421	Alarm	SMOK 3RD FL Z2 A/V CLOS 303D	X		
001:126-005	FDO421	Alarm	SMOK 3RD FL Z2 HOLDING VEST 305	X		
001:126-006	FDO421	Alarm	SMOK 3RD FL Z2 HOLDING VEST 305	X		
001:126-007	FDO421	Alarm	SMOK 3RD FL Z1 HOLDING VEST 305	X		
001:123-001	FDO421	Alarm	SMOK 3RD FL Z1 CLOSET STAIR 1	X		
001:123-002	FDO421	Alarm	SMOK 3RD FL Z1 CLOSET STAIR 1	X		
001:123-003	FDO421	Alarm	SMOK 3RD FL Z1 COMM CLOSET A	X		
001:123-004	FDO421	Alarm	SMOK 3RD FL Z1 ELEC CLOSET A	X		
001:123-005	FDO421	Alarm	SMOK 3RD FL Z1 JURY LOUNGE 3100	X		
001:123-006	FDO421	Alarm	SMOK 3RD FL Z1 WEST PUBLIC CORR	X		
001:123-007	FDO421	Alarm	SMOK 3RD FL Z1 WEST PUBLIC CORR	X		
001:123-008	FDO421	Alarm	SMOK 3RD FL Z1 WEST PUBLIC CORR	X		
001:123-009	FDO421	Alarm	SMOK 3RD FL Z1 STAIR 1	X		
001:123-010	FDO421	Alarm	SMOK 3RD FL Z2 STAIR 2	X		
001:123-020	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z1 STAIR 1	X		
001:123-021	FDO421	Alarm	SMOK 3RD FL Z2 JUROR OFFICE 3130	X		
001:123-022	FDO421	Alarm	SMOK 3RD FL Z2 COMM CLOSET D	X		
001:123-023	FDO421	Alarm	SMOK 3RD FL Z2 ELEC CLOSET A1	X		
001:123-024	FDO421	Alarm	SMOK 3RD FL Z2 WEST PUBLIC CORR	X		
001:123-025	FDO421	Alarm	SMOK 3RD FL Z2 WEST PUBLIC CORR	X		

001:123-026	FDO421	Alarm	SMOK 3RD FL Z2 ATRIUM WEST	X		
001:123-027	FDO421	Alarm	SMOK 3RD FL Z2 ATRIUM WEST	X		
001:123-031	XTRI-R	Status	RMT RLY 3RD FL Z3 CORR	X		
001:123-032	XTRI-R	Status	RMT RLY 3RD FL Z3 CORR	X		
001:123-040	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z2 STAIR 2	X		
001:123-041	FDO421	Alarm	SMOK 3RD FL Z3 ATRIUM WEST	X		
001:123-042	FDO421	Alarm	SMOK 3RD FL Z3 ATRIUM WEST	X		
001:123-043	FDO421	Alarm	SMOK 3RD FL Z3 ATRIUM EAST	X		
001:123-044	FDO421	Alarm	SMOK 3RD FL Z3 ATRIUM EAST	X		
001:123-045	FDO421	Alarm	SMOK 3RD FL Z3 JUDGES CONF RM	X		
001:123-046	FDO421	Alarm	SMOK 3RD FL Z3 OFFICE	X		
001:123-047	FDO421	Alarm	SMOK 3RD FL Z3 NORTH SEC CORR	X		
001:123-048	FDO421	Alarm	SMOK 3RD FL Z3 NORTH SEC CORR	X		
001:133-001	FDO421	Alarm	SMOK 3RD FL Z1 JURY LOUNGE 3100	X		
001:133-002	FDO421	Alarm	SMOK 3RD FL Z1 JURY LOUNGE 3100	X		
001:133-003	FDO421	Alarm	SMOK 3RD FL Z1 COMM CLOSET B	X		
001:133-004	FDO421	Alarm	SD 3F Z1 SEC COR BY COMM CLT 3-B	X		
001:133-005	FDO421	Alarm	SD 3F Z1 SEC COR BY COMM CLT 3-B	X		
001:133-006	FDO421	Alarm	SMOK 3RD FL Z1 ELEC CLOSET B	X		
001:133-008	FDO421	Alarm	SMOK 3RD FL Z1 COMM CLOSET C	X		
001:133-009	FDO421	Alarm	SD 3F Z6 SEC COR BY JAN CLT 3-CC	X		
001:133-010	FDO421	Alarm	SMK 3F Z6 SEC COR BY JURY RM 301	X		
001:133-013	FDO421	Alarm	SMOK 3RD FL Z6 STAIR 3	X		
001:133-014	FDO421	Alarm	SMOK 3RD FL Z6 STAIR 4	X		
001:133-015	FDO421	Alarm	SMOK 3RD FL Z3 STAIR 5	X		
001:133-020	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z6 STAIR 3	X		
001:133-024	FDO421	Alarm	SMOK 3RD FL Z2 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:133-025	FDO421	Alarm	SD 3F Z6 SEC COR BY JURY RM 302	X		
001:133-031	XTRI-D	Alarm/SUPV	FS/TS 3RD FL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:133-033	XTRI-D	Alarm/SUPV	FS/TS 3RD FL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:133-040	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z6 STAIR 4	X		
001:133-041	FDO421	Alarm	SMOK 3RD FL Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:133-042	FDO421	Alarm	SMOK 3RD FL Z6 SOUTH SEC CORR	X		
001:133-043	FDO421	Alarm	SMOK 3RD FL Z6 SOUTH SEC CORR	X		

001:133-044	FDO421	Alarm	SMOK 3RD FL Z6 SOUTH SEC CORR	X		
001:133-045	FDO421	Alarm	SMOKE 3 FL. Z3 COMM CLT 3- K	X		
001:133-046	FDO421	Alarm	SMOK 3F Z3 ELEC CLOSET 3-E	X		
001:133-047	FDO421	Alarm	SMOK 3F Z3 COMM CLOSET 3-H	X		
001:133-060	XMS-S/D/M/SA	Alarm	PULL 3RD FL Z3 STAIR 5	X		
001:131-001	FDO421	Alarm	SMOK INDIANA Z1 COMM CLOSET C	X		
001:131-002	FDO421	Alarm	SMOK INDIANA Z1 ELEC CLOSET B	X		
001:131-003	FDO421	Alarm	SMK INDIANA Z1 SEC COR CLST 101	X		
001:131-004	FDO421	Alarm	SMK INDIANA Z1 SEC COR CLST 100	X		
001:131-005	FDO421	Alarm	SMK IND Z6 SEC COR BY OFFICE 101	X		
001:131-006	FDO421	Alarm	SD IND Z6 SEC COR BY MECH RM 1-M	X		
001:131-008	FDO421	Alarm	SMOK INDIANA Z6 STAIR 3	X		
001:131-009	FDO421	Alarm	SMOK INDIANA Z6 STAIR 4	X		
001:131-010	FDO421	Alarm	SMOK INDIANA Z3 STAIR 5	X		
001:131-011	FDO421	Alarm	SD 1ST FL Z1 HOLD CELL 101/102	X		
001:131-012	FDO421	Alarm	SD 1ST FL Z1 HOLD CELL 103/104	X		
001:131-020	XMS-S/D/M/SA	Alarm	PULL INDIANA Z6 STAIR 3	X		
001:131-021	FDO421	Alarm	SD IND Z6 SEC COR BY JURY RM 103	X		
001:131-022	FDO421	Alarm	SMOK INDIANA Z2 SOUTH SEC CLOSET	X		
001:131-023	FDO421	Alarm	SMOK INDIANA Z2 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:131-025	XTRI-D	Alarm/SUPV	FS/TS INDIANA Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:131-027	XTRI-D	Alarm/SUPV	FS/TS INDIANA Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:131-040	XMS-S/D/M/SA	Alarm	PULL INDIANA Z6 STAIR 4	X		
001:131-041	FDO421	Alarm	SMOK INDIANA Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:131-042	FDO421	Alarm	SMOK INDIANA Z3 SOUTH SEC CORR	X		
001:131-044	FDO421	Alarm	SMOK INDIANA Z3 SOUTH SEC CORR	X		
001:131-045	FDO421	Alarm	SMOK INDIANA Z3 ELEC CLOSET E	X		
001:131-046	FDO421	Alarm	SMOK INDIANA Z3 COMM CLOSET H	X		
001:131-047	FDO421	Alarm	SMOK INDIANA Z3 COMM CLOSET K	X		
001:131-060	XMS-S/D/M/SA	Alarm	PULL INDIANA Z3 STAIR 5	X		

001:132-001	FDO421	Alarm	SMOK 2ND FL Z1 COMM CLOSET C	X		
001:132-002	FDO421	Alarm	SMOK 2ND FL Z1 ELEC CLOSET B	X		
001:132-003	FDO421	Alarm	SMOKE 2 FL. Z6 SECUR COR BY ELE	X		
001:132-004	FDO421	Alarm	SMOKE 2 FL. Z1 SECUR COR BY COM	X		
001:132-005	FDO421	Alarm	SMOK 2ND FL Z1 SOUTH SEC CORR	X		
001:132-006	FDO421	Alarm	SD 2F Z6 SCUR COR BY JURY RM 201	X		
001:132-007	FDO421	Alarm	SD 2F Z6 SCUR COR BY JURY RM 201	X		
001:132-008	FDO421	Alarm	2 FL Z1 SMK HOLDING CELL CR-202	X		
001:132-010	FDO421	Alarm	SMOK 2ND FL Z6 STAIR 3	X		
001:132-011	FDO421	Alarm	SMOK 2ND FL Z6 STAIR 4	X		
001:132-012	FDO421	Alarm	SMOK 2ND FL Z3 STAIR 5	X		
001:132-013	FDO421	Alarm	SMOK 2ND FL Z1 HOLDING CELL 217	X		
001:132-014	FDO421	Alarm	SMOK 2ND FL Z1 SOUTH PRISON CORR	X		
001:132-015	FDO421	Alarm	SMOK 2ND FL Z1 SOUTH PRISON CORR	X		
001:132-016	FDO421	Alarm	SMOK 2ND FL Z1 SOUTH PRISON CORR	X		
001:132-017	FDO421	Alarm	SMOK 2ND FL Z1 SOUTH PRISON CORR	X		
001:132-019	FDO421	Alarm	SMK 2F Z1 COMM ROOM 2L	X		
001:132-020	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z6 STAIR 3	X		
001:132-021	FDO421	Alarm	2 FL Z1 SMK HOLDING CELL CR-201	X		
001:132-023	FDO421	Alarm	2 FL Z2 SMK HOLDING CELL CR-203	X		
001:132-024	FDO421	Alarm	SD 2F Z6 SEC COR BY COPY RM 2-SC	X		
001:132-025	FDO421	Alarm	SMOK 2ND FL Z6 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:132-031	XTRI-D	Alarm/SUPV	FS/TS 2ND FL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:132-033	XTRI-D	Alarm/SUPV	FS/TS 2ND FL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:132-040	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z6 STAIR 4	X		
001:132-041	FDO421	Alarm	SMOK 2ND FL Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:132-042	FDO421	Alarm	SMOK 2F Z3 COMM CLOSET 2-K	X		
001:132-043	FDO421	Alarm	SD 2F Z6 SEC COR BY COMM CLT 2-K	X		
001:132-044	FDO421	Alarm	SMK 2F Z6 SEC COR BY ELEC RM 2-E	X		
001:132-045	FDO421	Alarm	SMOK 2F Z6 SEC COR ELEC RM 2-E	X		
001:132-046	FDO421	Alarm	SMOK 2ND FL Z3 ELEC CLOSET 2-E	X		
001:132-047	FDO421	Alarm	SMOK 2F Z3 COMM CLOSET 2-H	X		
001:132-060	XMS-S/D/M/SA	Alarm	PULL 2ND FL Z3 STAIR 5	X		

001:141-001	FDO421	Alarm	SMOK 4TH FL Z4 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:141-002	FDO421	Alarm	SMOK 4F Z4 STORAGE 4_FC	X		
001:141-003	FDO421	Alarm	SMOK 4TH FL Z4 COMM CLOS 4-H	X		
001:141-005	FDO421	Alarm	SMOK 4TH FL Z4 ELEC CLOSET 4-E	X		
001:141-006	FDO421	Alarm	SMOK 4F Z4 E. PUB COR ENTRANCE	X		
001:141-007	FDO421	Alarm	SMOK 4F Z4 E. PUBLIC CORRIDOR	X		
001:141-008	FDO421	Alarm	SMOK 4F Z4 AV CLOSET 4_AC	X		
001:141-009	FDO421	Alarm	SMOK 4TH FL Z4 COR BY COURT RM 4	X		
001:141-012	FDO421	Alarm	DUCT AHU-1 4F Z4 JURY LNGE 4300	X		
001:141-013	FDO421	Alarm	SMOK 4F Z4 AV CLOSET 4_AM	X		
001:141-014	XTRI-R	Test	RLY 4F Z4 AHU-1 JURY LNG 4300	X		
001:141-016	FDO421	Alarm	SMOK 4F Z4 AV CLOSET 4_AL	X		SPACE UNFINISH/COOPER CONSTRUCTION
001:141-017	FDO421	Alarm	SMOK 4TH FL Z6 STAIR 9	X		
001:141-021	XTRI-R	Status	RLY 5TH FL Z4 DOOR RLS	X		
001:141-029	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z4 COR BY COURT RM 4	X		
001:141-030	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z6 STAIR 8	X		
001:141-031	FDO421	Alarm	SMOK 4TH FL Z5 CLOSET STAIR 9	X		
001:141-032	FDO421	Alarm	SMOK 4TH FL Z5 ELEC CLT 4-F	X		
001:141-034	FDO421	Alarm	SMOK 4TH FL Z5 COMM CLT 4-J	X		
001:141-056	XTRI-R	Trouble	PAD-4 4F Z4 ELECTTIC RM	X		
001:141-060	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z6 STAIR 9	X		
001:142-001	FDO421	Alarm	SMOK 5TH FL Z4 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:142-002	FDO421	Alarm	SMK 5F Z4 SEC COR BY COURT 516	X		
001:142-003	FDO421	Alarm	SMOK 5F Z4 COMM CLOSET 5-H	X		
001:142-004	FDO421	Alarm	SMOK 5F Z4 ELEC CLOSET 5-E	X		
001:142-005	FDO421	Alarm	SMK 5F Z4 SEC COR BY RM 5650	X		
001:142-006	FDO421	Alarm	SMK 5F Z4 PUB COR BY RM 5650	X		
001:142-007	FDO421	Alarm	SMK 5F Z4 SEC COR CHAMBER 5640	X		
001:142-008	FDO421	Alarm	SMK 5F Z4 SEC COR CHAMBER 5630	X		
001:142-009	FDO421	Alarm	SMK 5F Z4 SEC COR CHAMBER 5620	X		
001:142-010	FDO421	Alarm	SMOK 5TH FL Z4 STAIR 8	X		

001:142-011	FDO421	Alarm	SMOK 5TH FL Z5 STAIR 9	X		
001:142-030	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z4 STAIR 8	X		
001:142-031	FDO421	Alarm	SMK 5F Z5 SEC COR CHAMBER 5610	X		
001:142-032	FDO421	Alarm	SMK 5F Z5 SEC COR CHAMBER 5600	X		
001:142-033	FDO421	Alarm	SMK 5F Z5 SEC COR COURT 519	X		
001:142-035	FDO421	Alarm	SMK 5F Z5 SEC COR CHAMBER 5530	X		
001:142-036	FDO421	Alarm	SMOK 5F Z5 ELEC CLOSET 5-F	X		
001:142-037	FDO421	Alarm	SMOK 5TH FL Z5 CLOSET STAIR 9	X		
001:142-060	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z5 STAIR 9	X		
001:143-001	FDO421	Alarm	SMOK 6TH FL Z4 ELEV 12 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:143-002	FDO421	Alarm	SMOKE 6TH FL Z4 ELEV 12 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:143-003	FDO421	Alarm	SMOKE 6TH FL Z4 PANTRY 6682 RM	X		
001:143-004	FDO421	Alarm	SMOKE 6TH FL Z4 STAIR8 CLOS6694H	X		
001:143-005	FDO421	Alarm	SMOKE 6TH FL Z4 TELCLO 6695H1	X		
001:143-007	FDO421	Alarm	SMOKE 6TH FL Z4 SOUTH SEC CORR	X		
001:143-009	FDO421	Alarm	SMOKE 6TH FL Z4 ELEC CLO 6687E	X		
001:143-014	FDO421	Alarm	SMOKE 6TH FL Z5 STAIR 9	X		
001:143-015	FDO421	Alarm	SMOKE 6TH FL Z4 STORAGE 6690 RM	X		
001:143-028	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z4 CORR 6.02	X		
001:143-029	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z4 STAIR 8	X		
001:143-034	FDO421	Alarm	SMOKE 6TH FL Z5 TELCLO 6543J	X		
001:143-035	FDO421	Alarm	SMOKE 6TH FL Z5 ELECCLO 6541 F-1	X		
001:143-036	FDO421	Alarm	SMOKE 6TH FL Z5 ELEC CLO 6542	X		
001:143-037	FDO421	Alarm	SMOKE 6TH FL Z5 ELECCLO 6546 F-2	X		
001:143-042	FDO421	Alarm	SMOKE 6TH FL Z4 SECURE STOR 6688	X		
001:143-058	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z5 SEC CORR 6.11	X		
001:143-059	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z5 SEC CORR 6.11	X		
001:143-060	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z5 STAIR 9	X		
001:143-013	FDO421	Alarm	6TH FL Z4 SMOKE BY STAIR-8	X		
001:144-001	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:144-002	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:144-003	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		

001:144-004	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:144-005	FDT421	Alarm	HEAT EAST PENT HOUSE GEN RM	X		
001:144-006	FDT421	Alarm	HEAT EAST PENT HOUSE GEN RM	X		
001:144-007	FDO421	Alarm	SMOK EAST PH BY GEN RM	X		
001:144-008	FDO421	Alarm	SMOK EAST PH BY GEN RM	X		
001:144-011	FDO421	Alarm	DUCT EPH Z4 MECH RM AHU18	X		
001:144-012	XTRI-R	Status	DUCT RELAY EPH Z4 MECH RM AHU18	X		
001:144-013	FDO421	Alarm	DUCT EPH Z4 MECH RM RAF18	X		
001:144-014	XTRI-R	Status	DUCT RELAY EPH Z4 MECH RM RAF18	X		
001:144-015	XTRI-S	Trouble	EAST PH GEN 1 FAULT	X		Simulate Signals and verify received in FACP
001:144-016	XTRI-S	Supervisory	EAST PH GEN 1 RUN	X		Simulate Signals and verify received in FACP
001:144-017	XTRI-S	Trouble	EAST PH GEN 2 FAULT	X		Simulate Signals and verify received in FACP
001:144-018	XTRI-S	Supervisory	EAST PH GEN 2 RUN	X		Simulate Signals and verify received in FACP
001:144-030	XMS-S/D/M/SA	Alarm	PULL EPH Z4 MECH RM	X		
001:144-031	FDO421	Alarm	SMOK EPH Z5 MECH RM	X		
001:144-032	FDO421	Alarm	SMOK EPH Z5 MECH RM	X		
001:144-041	FDO421	Alarm	DUCT EPH Z5 MECH RM RAF17	X		
001:144-042	XTRI-R	Status	DUCT RELAY EPH Z5 MECH RM RAF17	X		
001:144-043	FDO421	Alarm	DUCT EPH Z5 MECH RM AHU17	X		
001:144-044	XTRI-R	Status	DUCT RELAY EPH Z5 MECH RM AHU17	X		
001:144-045	XTRI-R	Status	RELAY EPH Z4 STAIR 8	X		
001:144-046	XTRI-R	Status	RELAY EPH Z5 STAIR 9	X		
001:151-001	FDO421	Alarm	SMOK 4TH FL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:151-002	FDO421	Alarm	SMOK 4TH FL Z4 ELEC CLOSET C	X		SPACE UNDER CONSTRUCTION/COOPER
001:151-004	FDO421	Alarm	SMOK 4TH FL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:151-005	FDO421	Alarm	SMOK 4TH FL Z4 COMM CLOSET C	X		SPACE UNDER CONSTRUCTION/COOPER
001:151-009	FDO421	Alarm	SMOK 4TH FL Z4 NORTH PUBLIC CORR	X		SPACE UNDER CONSTRUCTION/COOPER
001:151-010	FDO421	Alarm	SMOK 4TH FL Z4 NORTH PUBLIC CORR	X		SPACE UNDER CONSTRUCTION/COOPER
001:151-011	FDO421	Alarm	SMOK 4TH FL Z4 NORTH PUBLIC CORR	X		SPACE UNDER CONSTRUCTION/COOPER
001:151-022	FDO421	Alarm	SMOK 4TH FL Z4 STAIR 6	X		
001:151-023	FDO421	Alarm	SMOK 5TH FL Z4 STAIR 6	X		

001:151-028	FDO421	Alarm	SMOKE 4TH FLR Z4 A/V CLOSET 308	X		
001:151-029	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z4 NORTH PUBLIC CORR	X		
001:151-030	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z4 STAIR 6	X		
001:151-031	FDO421	Alarm	SMOK 5TH FL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:151-032	FDO421	Alarm	SMOK 5TH FL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:151-033	FDO421	Alarm	SMOK 5TH FL Z4 ELEC CLOSET C	X		
001:151-035	FDO421	Alarm	SMOK 5TH FL Z4 COMM CLOSET E	X		
001:151-037	FDO421	Alarm	SMOK 5TH FL Z4 NORTH PUBLIC CORR	X		
001:151-046	FDO421	Alarm	SMOK 5TH FL Z4 EAST PUBLIC CORR	X		
001:151-047	FDO421	Alarm	SMOK 5TH FL Z4 EAST PUBLIC CORR	X		
001:151-048	FDO421	Alarm	SMOK 5TH FL Z4 EAST PUBLIC CORR	X		
001:151-049	FDO421	Alarm	SMOK 5TH FL Z4 SOUTH PUBLIC CORR	X		
001:151-055	XTRI-R	Status	REL 5TH FL STAIR 6 DOOR REL	X		
001:151-060	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z4 STAIR 6	X		
001:152-001	FDO421	Alarm	SMOK 6TH FL Z4 ELEV 7 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:152-002	FDO421	Alarm	SMOK 6TH FL Z4 ELEV 7 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:152-003	FDO421	Alarm	SMOK 6TH FL Z4 ELEV 8 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:152-004	FDO421	Alarm	SMOK 6TH FL Z4 ELEV 8 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:152-005	FDO421	Alarm	SMO 6TH Z4 FOOD SER STOR 6408	X		
001:152-006	FDO421	Alarm	SMOK 6TH FL Z4 TEL RM 6406E	X		
001:152-007	FDO421	Alarm	SMOK 6TH FL Z4 ELEC CLOS 6409C	X		
001:152-013	FDO421	Alarm	SMOK 6TH FL Z4 STOR RM 6.04C	X		
001:152-017	FDO421	Alarm	SMO 6TH Z4 CHAIR/TABLE STOR6405B	X		
001:152-019	FDO421	Alarm	SMOK 6TH FL Z4 STAIR 6	X		
001:152-020	FDO421	Alarm	SM 6TH Z4 LIT CONTL PNL CLOS6404	X		
001:152-021	XTRI-R	Status	RLY 6TH ZONE 4 SMK DAMP 6408 RM	X		
001:152-026	XTRI-D	Alarm/SUPV	FS/TS PENTHOUSE ZN 4 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:152-028	XTRI-R	Status	RELAY EPH Z4 STAIR 6	X		
001:152-029	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z4 SEC CORR 6.05	X		
001:152-030	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z4 STAIR 6	X		
001:152-031	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:152-032	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		

001:152-033	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:152-034	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:152-035	FDO421	Alarm	SMOK EPH Z4 MECH RM	X		
001:152-037	FDO421	Alarm	DUCT EPH Z5 AHU 23	X		
001:152-038	XTRI-R	Status	RELAY EPH Z5 AHU 23	X		
001:152-039	FDO421	Alarm	DUCT EPH Z5 RAF 23	X		
001:152-040	XTRI-R	Status	RELAY EPH Z5 RAF 23	X		
001:152-041	FDO421	Alarm	DUCT EPH Z4 MECH RM RAF15	X		
001:152-042	XTRI-R	Status	DUCT RELAY EPH Z4 MECH RM RAF15	X		
001:152-043	FDO421	Alarm	DUCT EPH Z4 MECH RM AHU15	X		
001:152-044	XTRI-R	Status	DUCT RELAY EPH Z4 MECH RM AHU15	X		
001:152-045	XTRI-R	Status	RLY EPH Z4 EX FAN-2	X		
001:152-046	FDO421	Alarm	DUCT EPH Z4 MECH RM EX FAN -2	X		
001:152-047	XTRI-R	Status	RLY EPH Z4 EX FAN-1	X		
001:152-048	FDO421	Alarm	DUCT EPH Z4 MECH RM EX FAN 1	X		
001:152-049	XTRI-R	Status	RLY EPH Z4 ELEC DUCT HEATER 1	X		
001:152-050	FDO421	Alarm	DD AC-1 EPH Z4 ELEC DUCT HEAT-1	X		
001:152-051	XTRI-R	Status	RLY EPH Z4 ELEC DUCT HEATER 2	X		
001:152-052	FDO421	Alarm	DD AC-2 EPH Z4 ELEC DUCT HEAT 2	X		
001:152-053	XTRI-R	Status	DOOR RELESE 6F TEL CLST 6406-E	X		
001:152-060	XMS-S/D/M/SA	Alarm	PULL EPH Z4 MECH RM	X		
001:161-001	FDO421	Alarm	5TH FLR SD @ EXEC OFF SWING CORR	X		
001:161-002	FDO421	Alarm	5TH FLR SD @ EXEC OFF SWING CORR	X		
001:161-003	FDO421	Alarm	5TH FLR SD @ EXEC OFF SWING STR7	X		
001:161-006	FDO421	Alarm	SMOK 5TH FL Z5 STAIR 7	X		
001:161-021	XTRI-D	Alarm/SUPV	FLOW/TAMP 5TH FL Z5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:161-031	FDO421	Alarm	SMOK 5TH FL Z5 CLOSET STAIR 7	X		
001:161-032	FDO421	Alarm	SMOK 5TH FL Z5 ELEC CLOSET D	X		
001:161-034	FDO421	Alarm	SMOK 5TH FL Z5 COMM CLOSET F	X		
001:161-041	FDO421	Alarm	SMOK 5TH FL Z5 EAST PUBLIC CORR	X		
001:161-042	FDO421	Alarm	SMOK 5TH FL Z5 EAST PUBLIC CORR	X		
001:161-043	FDO421	Alarm	SMOK 5TH FL Z5 NORTH SEC CORR	X		

001:161-060	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z5 STAIR 7	X		
001:162-001	FDO421	Alarm	SMOK 6TH FL Z5 ELEC CLOS 6496D.1	X		
001:162-002	FDO421	Alarm	SMOK 6TH FL Z5 ELEC CLOS 6498D	X		
001:162-008	XTRI-D	Alarm/SUPV	FLOW/TAMP 6TH FL ZN5 STAIR 7	X		Test with BFPE 11/3/2022, NFPA 25
001:162-010	FDO421	Alarm	SMOK 6TH FL Z5 ADT CLOS 6.10A	X		
001:162-011	FDO421	Alarm	SMOK 6TH FL Z5 TEL/DATA 6.10B-F	X		
001:162-012	FDO421	Alarm	SMOK 6TH FL Z5 STAIR 7	X		
001:162-016	FDO421	Alarm	SMOK 6TH FL Z5 ARCHIEVE 6735 C	X		
001:162-017	FDO421	Alarm	SMOK 6TH FL Z5 STORAGE 6515	X		
001:162-030	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z5 STAIR 7	X		
001:162-031	FDO421	Alarm	SMOK EAST PH Z5 MECH RM	X		
001:162-032	FDO421	Alarm	SMOK EAST PH Z5 MECH RM	X		
001:162-033	FDO421	Alarm	SMOK EAST PH Z5 MECH RM	X		
001:162-041	FDO421	Alarm	DUCT EAST PH Z5 MECH RM RAF16	X		
001:162-042	XTRI-R	Status	RELAY EAST PH Z5 MECH RM RAF16	X		
001:162-043	FDO421	Alarm	DUCT EAST PH Z5 MECH RM AHU16	X		
001:162-044	XTRI-R	Status	RELAY EAST PH Z5 MECH RM AHU16	X		
001:162-045	XTRI-R	Status	RELAY EAST PH Z5 STAIR 7	X		
001:171-001	FDO421	Alarm	SMOK 4F Z1 JAN CLOSET 4-A	X		
001:171-002	FDO421	Alarm	SMOK 4TH FL Z1 CLOSET STAIR 1	X		
001:171-003	FDO421	Alarm	SMOK 4F Z1 COMM CLOSET 4-A	X		
001:171-005	FDO421	Alarm	SMOK 4F Z1 ELEC CLOSET 4-A	X		
001:171-009	FDO421	Alarm	SMK 4F Z1 PROPERTY RM 4019	X		
001:171-011	FDO421	Alarm	SMOK 4TH FL Z1 STAIR 1	X		
001:171-013	FDO421	Alarm	SMOK 4TH FL Z2 STAIR 2	X		
001:171-014	FDO421	Alarm	SMOK 5TH FL Z2 STAIR 2	X		
001:171-015	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z1 STAIR 1	X		
001:171-016	FDO421	Alarm	SMOK 5TH FL Z1 STAIR 1	X		
001:171-018	FDO421	Alarm	SMOK 5F Z1 COMM CLOSET 5-A	X		
001:171-019	FDO421	Alarm	SMOK 5F Z1 ELEC CLOSET 5-A	X		
001:171-020	FDO421	Alarm	SMOK 5TH FL Z1 STORAGE RM 5213	X		
001:171-021	FDO421	Alarm	SMOK 5TH FL Z1 FILE STORAGE 5215	X		

001:171-022	FDO421	Alarm	SMOK 5TH FL Z1 JAN CLOS STAIR 1	X		
001:171-024	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z1 STAIR 1	X		
001:171-033	FDO421	Alarm	SMOK 4TH FL Z2 COMM CLOSET D	X		
001:171-045	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z2 STAIR 2	X		
001:171-048	FDO421	Alarm	SMOK 5TH FL Z2 STORAGE 5402	X		
001:171-049	FDO421	Alarm	SMOK 5TH FL Z2 STORAGE 5402	X		
001:171-050	FDO421	Alarm	SMOK 5TH FL Z2 EXHIBIT STOR 5402	X		
001:171-054	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z2 STAIR 2	X		
001:171-017	FDO421	Alarm	SMK 5F Z1 STORAGE CLST 5-BB	X		
001:172-001	FDO421	Alarm	SMOK WEST PH Z1 MECH EQ RM	X		
001:172-002	FDO421	Alarm	SMOK WEST PH Z1 MECH EQ RM	X		
001:172-003	FDO421	Alarm	SMOK WEST PH Z1 MECH EQ RM	X		
001:172-004	FDO421	Alarm	SMOK WEST PH Z1 MECH EQ RM	X		
001:172-005	FDO421	Alarm	SMOK WEST PH Z1 MECH EQ RM	X		
001:172-006	FDO421	Alarm	SMOK WEST 6TH FL Z3 STAIR 5	X		
001:172-007	XTRI-R	Status	RELAY WEST PH Z1 STAIR 1	X		
001:172-008	FDO421	Alarm	SMOK WEST PH Z1 GEN RM	X		
001:172-009	FDT421	Alarm	HEAT WEST PH Z1 GEN RM	X		
001:172-011	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM AHU4	X		
001:172-012	XTRI-R	Status	RELAY WEST PH Z1 MECH EQ RM AHU4	X		
001:172-013	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM RAF4	X		
001:172-014	XTRI-R	Status	RELAY WEST PH Z1 MECH EQ RM RAF4	X		
001:172-015	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM RAF3	X		
001:172-016	XTRI-R	Status	RELAY WEST PH Z1 MECH EQ RM RAF3	X		
001:172-017	XTRI-R	Status	RELAY WEST PH Z2 STAIR 2	X		
001:172-018	XTRI-R	Status	RELAY WEST PH Z1 STAIR 3	X		
001:172-019	XTRI-R	Status	RELAY WEST PH Z2 STAIR 4	X		
001:172-020	XTRI-R	Status	RELAY WEST PH Z3 STAIR 5	X		
001:172-021	XTRI-D	Alarm/SUPV	FS/TS WEST PH	X		Test with BFPE 11/3/2022, NFPA 25
001:172-023	XTRI-D	SUPV/TRBL	WEST PH GEN RUN/FAULT	X		Simulate Signals and verify received in FACP
001:172-027	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM RAF2	X		
001:172-028	XTRI-R	Status	RELAY WEST PH Z1 MECH EQ RM RAF2	X		
001:172-029	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM RAF19	X		
001:172-030	XTRI-R	Status	RLY WEST PH Z1 MECH EQ RM RAF19	X		

001:172-031	FDO421	Alarm	DUCT WEST PH Z1 MECH EQ RM AHU19	X		
001:172-032	XTRI-R	Status	RLAY WEST PH Z2 MECH EQ RM AHU19	X		
001:172-033	FDO421	Alarm	DUCT WEST PH Z2 MECH EQ RM AHU2	X		
001:172-034	XTRI-R	Status	RELAY WEST PH Z2 MECH EQ RM AHU2	X		
001:172-035	FDO421	Alarm	DUCT WEST PH Z2 MECH EQ RM AHU3	X		
001:172-036	XTRI-R	Status	RELAY WEST PH Z2 MECH EQ RM AHU3	X		
001:172-040	XMS-S/D/M/SA	Alarm	PULL WEST PH Z2 MECH EQ RM EXT	X		
001:172-041	FDO421	Alarm	SMOK 6TH FL Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:172-042	FDO421	Alarm	SMOK 6TH FL Z3 ELEV 4 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:172-043	FDO421	Alarm	SMOK 6TH FL Z3 ELEV 3 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:172-044	FDO421	Alarm	SMOK 6TH FL Z3 ELEV 2 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:172-045	FDO421	Alarm	SMOK 6TH FL Z3 ELEV 1 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:172-050	XTRI-D	Alarm/SUPV	FS/TS 6TH ZN 3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:172-060	XMS-S/D/M/SA	Alarm	PULL 6TH FL Z3 STAIR 5	X		
001:181-004	FDO421	Alarm	SMOK 4TH FL Z1 ELEC CLOSET B	X		
001:181-005	FDO421	Alarm	SMOK 4TH FL Z1 COMM CLOSET C	X		
001:181-009	FDO421	Alarm	SMOK 4TH FL Z1 CRIM DIV FILE RM	X		
001:181-010	FDO421	Alarm	SMOK 4TH FL Z1 CRIM DIV FILE RM	X		
001:181-011	FDO421	Alarm	SMOK 4TH FL Z1 CRIM DIV FILE RM	X		
001:181-013	FDO421	Alarm	SMOK 4TH FL Z6 STAIR 3	X		
001:181-014	FDO421	Alarm	SMOK 4TH FL Z6 STAIR 4	X		
001:181-015	FDO421	Alarm	SMOK 4TH FL Z3 STAIR 5	X		
001:181-020	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z6 STAIR 3	X		
001:181-021	FDO421	Alarm	SMOK 4TH FL Z6 ELEV 5 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:181-022	FDO421	Alarm	SMOK 4TH FL Z2 ELEV 5 SHAFT	X		Test with Schindler 3/19/2023, ASME A17
001:181-023	FDO421	Alarm	SMOK 4TH FL Z2 CRIMINAL DIV ENT	X		
001:181-024	FDO421	Alarm	SMOK 4TH FL Z2 CRIMINAL DIV ENT	X		
001:181-026	FDO421	Alarm	4TH F Z2 CRIMINAL DIVISION VAULT	X		
001:181-027	FDO421	Alarm	SMOK 4TH FL Z1 CRIM DIV FILE RM	X		
001:181-031	XTRI-D	Alarm/SUPV	FS/TS 4TH FL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:181-033	XTRI-D	Alarm/SUPV	FS/TS 4TH FL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:181-040	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z6 STAIR 4	X		

001:181-041	FDO421	Alarm	SMOK 4TH FL Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:181-042	XTRI-R	Status	RELAY 4TH FL Z3 DOOR RELEASE COR	X		
001:181-057	FDO421	Alarm	SMOK 4F Z3 S. CORR BY STAIR 5	X		
001:181-060	XMS-S/D/M/SA	Alarm	PULL 4TH FL Z3 STAIR 5	X		
001:182-001	FDO421	Alarm	SMOK 5TH FL Z1 STAIR 3	X		
001:182-002	FDO421	Alarm	SMOK 5TH FL Z2 STAIR 4	X		
001:182-003	FDO421	Alarm	SMOK 5TH FL Z1 ELEC CLOSET 5201	X		
001:182-004	FDO421	Alarm	SMOK 5TH FL Z1 ELEC CLOSET B	X		
001:182-005	FDO421	Alarm	SMOK 5TH FL Z1 COMM CLOSET C	X		
001:182-007	FDO421	Alarm	SMOK 5TH FL Z3 STAIR 5	X		
001:182-020	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z1 STAIR 3	X		
001:182-023	FDO421	Alarm	SMOK 5TH FL Z2 SUPPLY STOR 5410	X		
001:182-025	FDO421	Alarm	SMOK 5TH FL Z2 SEALED FILES 5408	X		
001:182-028	FDO421	Alarm	SMOK 5TH FL Z2 ELEV MACH RM 5	X		Test with Schindler 3/19/2023, ASME A17
001:182-030	FDT421	Alarm	HEAT 5TH FL Z2 ELEV MACH RM	X		Test with Schindler 3/19/2023, ASME A17
001:182-031	XTRI-R	Status	RELAY PRI 5TH FL Z2 ELEV 5	X		Test with Schindler 3/19/2023, ASME A17
001:182-032	XTRI-R	Status	RELAY ALT 5TH FL Z2 ELEV 5	X		Test with Schindler 3/19/2023, ASME A17
001:182-033	XTRI-R	Trouble	RELAY SHUNT 5TH FL Z2 ELEV 5	X		Test with Schindler 3/19/2023, ASME A17
001:182-034	XTRI-R	Status	RELAY HAT 5TH FL Z2 ELEV 5	X		Test with Schindler 3/19/2023, ASME A17
001:182-035	XTRI-R	Status	RMT DOOR RLY 5TH FL Z2 CORRIDOR	X		
001:182-040	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z2 STAIR 4	X		
001:182-041	FDO421	Alarm	SMOK 5TH FL Z3 ELEV 1-4 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:182-051	XTRI-D	Alarm/SUPV	FS/TS 5TH FL Z1 STAIR 3	X		Test with BFPE 11/3/2022, NFPA 25
001:182-053	XTRI-D	Alarm/SUPV	FS/TS 5TH FL Z3 STAIR 5	X		Test with BFPE 11/3/2022, NFPA 25
001:182-060	XMS-S/D/M/SA	Alarm	PULL 5TH FL Z3 STAIR 5	X		
001:064-001	XMS-S/D/M/SA	Alarm	PULL CST LVL Z6 STAIR 9	X		
001:064-002	FDO421	Alarm	SMOKE C ST Z6 STAIR 9	X		
001:064-003	FDO421	Alarm	SMOKE C ST Z6 FACP MEP 2007.B	X		
001:064-004	FDO421	Alarm	SMOKE C ST Z6 COMM RM 2007	X		
001:064-005	XMS-S/D/M/SA	Alarm	PULL C LVL Z6 EXIT TO C ST	X		

001:064-006	FDO421	Alarm	SMOKE C ST Z6 ELEC RM 2005	X		
001:064-007	XMS-S/D/M/SA	Alarm	PULL C LVL Z6 CORR BY ELEC RM	X		
001:064-017	FDO421	Alarm	SMOKE C ST Z6 IT CLOSET 2006K	X		
001:064-019	XTRI-R	Status	C ST LVL SEC DOOR RELEASE	X		
001:086-005	FDO421	Alarm	SMOKE 3F Z6 ELEC RM 6023	X		
001:086-006	FDO421	Alarm	SMOKE 3F Z6 COMM RM 6043A	X		
001:086-007	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-012	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-013	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-014	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-015	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-016	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-018	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-019	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-020	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-021	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR	X		
001:086-022	FDO421	Alarm	SMOKE 3F Z6 SECURE CORR STAIR 9	X		
001:086-023	XTRI-R	Status	RLY SECURITY 3F Z6 COMM RM 6043	X		
001:086-134	FDO421	Alarm	SMOKE 4F Z6 MEP 7005 A	X		
001:086-135	FDO421	Alarm	SMOKE 4F Z6 COMM RM 7005	X		
001:086-136	FDO421	Alarm	SMOKE 4F Z6 SUPPLY RM 7003D	X		
001:086-132	FDO421	Alarm	SMOKE 4F Z6 ELEC RM 7004	X		
001:086-137	FDO421	Alarm	SMOKE 4F Z6 STORAGE RM 7003J	X		
001:086-139	FDO421	Alarm	SMOKE 4F Z6 FILE RM 7003K	X		
001:086-140	XTRI-R	Status	RLY SECURITY 4F Z6 COMM RM 7005	X		
001:047-001	FDO421	Alarm	SMOKE 2F Z6 STORAGE 5043	X		
001:047-002	FDO421	Alarm	SMOKE 2F Z6 ELEC RM	X		
001:047-005	FDO421	Alarm	SMOKE 2F Z6 A/V CLOSET	X		
001:047-006	FDO421	Alarm	SMOKE 2F Z6 PRISON ELEV.14 LOBBY	X		
001:047-007	FDO421	Alarm	SMOKE 2F Z6 HOLDING CELL 5013	X		
001:047-009	FDO421	Alarm	SMOKE 2F Z6 A/V CLOSET	X		
001:047-021	FDO421	Alarm	SMOKE 2F Z6 SECURE CORR	X		
001:047-024	FDO421	Alarm	SMOKE 2F Z6 SECURE CORR 5505	X		
001:047-028	FDO421	Alarm	SMOKE 2F Z6 SECURE CORR	X		

001:047-029	XMS-S/D/M/SA	Alarm	PULL 2F Z6 STAIR 9	X		
001:047-101	FDO421	Alarm	SMOKE 2F Z6 PRISONER CORR	X		
001:047-102	FDO421	Alarm	SMOKE 2F Z6 PRISONER CORR	X		
001:047-178	XMS-S/D/M/SA	Alarm	PULL 2FZ6 PUBLIC COR COURT RM 1	X		
001:053-127	FDO421	Alarm	SMOKE IND AVE Z6 STORAGE 4041	X		
001:053-128	FDO421	Alarm	SMOKE IND AVE Z6 ELEC RM	X		
001:053-129	FDO421	Alarm	SMOKE IND AVE Z6 PRISON ELEV.14 LOB	X		
001:053-131	FDO421	Alarm	SMOKE IND AVE Z6 A/V CLST 4015	X		
001:053-132	XMS-S/D/M/SA	Alarm	PULL IND Z6 PUBLIC CORR 4006	X		
001:053-130	FDO421	Alarm	SMOKE IND AVE Z6 A/V RM 4039	X		
001:053-133	FDO421	Alarm	SMOKE IND AVE HOLDING PASSAGE	X		
001:053-148	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-149	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-150	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-151	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-152	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-153	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-154	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-155	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-156	FDO421	Alarm	SMOKE IND AVE Z6 SECURE CORR	X		
001:053-159	XMS-S/D/M/SA	Alarm	PULL 1ND AVE Z6 STAIR 9	X		
001:053-004	FDO421	Alarm	SMOKE JM Z6 COMM RM	X		
001:053-003	FDO421	Alarm	SMOKE JM Z6 MEP RM	X		
001:053-005	FDO421	Alarm	SMOKE JM Z6 ELEC RM	X		
001:053-016	FDO421	Alarm	SMOKE JM Z6 SECURE CORR 3506	X		
001:053-018	FDO421	Alarm	SMOKE JM Z6 A/V CLST	X		
001:053-022	FDO421	Alarm	SMOKE JM Z6 SECURE CORR 3506	X		
001:053-024	FDO421	Alarm	SMOKE JM Z6 FILE RM 3003	X		
001:053-026	FDO421	Alarm	SMOKE JM Z6 SECURE CORR 3002	X		
001:053-027	FDO421	Alarm	SMOKE JM Z6 SECURE CORR 3002	X		
001:053-028	FDO421	Alarm	SMOKE JM Z6 HALLWAY BY MEP	X		
001:053-029	FDO421	Alarm	SMOKE JM Z6 STORAGE 3003Q	X		
001:053-006	FDO421	Alarm	DD A-33 JM Z6 HEARING RM	X		
001:053-103	FDO421	Alarm	SMOKE JM Z6 PRISON ELEV.14 LOBBY	X		

001:053-104	FDO421	Alarm	SMOKE JM Z6 PRISON ELEV.14 LOBBY	X		
001:053-034	XMS-S/D/M/SA	Alarm	PULL JM SECURE CORR STAIR 9	X		
001:053-033	XTRI-R	Status	LVL JM Z6 SEC DOOR RELEASE	X		
001:053-001	ILED-XC/XW	Relay	ILED FOR DUCT 53-6	X		
001:201-003	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-004	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-005	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-006	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-008	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-009	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-35 SUP	X		
001:201-010	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-011	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-012	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-35 RTN	X		
001:201-013	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-014	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-015	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-016	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-017	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-019	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-020	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-34 RTN	X		
001:201-021	HTRI-R	Status	RELY PKG Z6 TURNSTILE RELEASE	X		
001:201-022	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-33 RTN	X		
001:201-023	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-025	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-026	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-027	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-029	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-030	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-32 RTN	X		
001:201-031	HFP-11	Alarm	DUCT PKG Z6 MECH 1001 AHU-31 RTN	X		
001:201-032	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-034	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-035	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-036	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-037	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		

001:201-038	HFP-11	Alarm	SMOK PKG Z6 MECH 1001	X		
001:201-039	HFPT-11	Alarm	HEAT PKG Z6 MECH 1001	X		
001:201-040	HFPT-11	Alarm	HEAT PKG Z6 MECH 1001	X		
001:201-065	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-31	X		
001:201-066	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-31	X		
001:201-067	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-32	X		
001:201-068	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-32	X		
001:201-069	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-33	X		
001:201-070	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-33	X		
001:201-071	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-34	X		
001:201-072	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-34	X		
001:201-073	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-35	X		
001:201-074	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-35	X		
001:201-075	FDCIO B	Status	4IO PKG Z6 MECH 1001 AHU-36	X		
001:201-076	HTRI-M	Trouble	PAD #1 PKG Z6 STROBE PANEL	X		
001:201-080	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-081	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-082	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-083	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-084	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-085	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-086	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-087	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-088	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-089	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-34 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-090	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-091	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-092	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-093	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-094	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-095	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-096	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-097	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-098	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED

001:201-099	HFP-11	Alarm	PLEN PKG Z6 MECH 1001 AHU-33 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-100	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-101	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-102	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-103	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-104	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-105	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-106	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-107	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-108	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-109	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-32 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-110	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-111	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-112	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-113	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-114	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-115	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-116	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-117	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-118	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-119	FDO421	Alarm	PLEN PKG Z6 MECH 1001 AHU-31 SUP		X	CONCEALED = REQUIRED A REMOTE LED
001:201-127	HFP-11	Alarm	SMOK CST Z6 ELEC 2018	X		
001:201-128	HFP-11	Alarm	SMOK CST Z6 MEP 2017A	X		
001:201-130	HFP-11	Alarm	SMOK CST Z6 COMM 2017	X		
001:201-131	HFP-11	Alarm	SMOK CST Z6 STAIR 3	X		
001:201-132	HMS-S/D/M/SA	Alarm	PULL CST Z6 STAIR 3	X		
001:201-133	HFP-11	Alarm	DD A-31/32 CST Z6 SHAFT/STAIR 4	X		
001:201-135	HFP-11	Alarm	SMOK CST Z6 ELEV 5 LBY STAIR 4	X		
001:201-136	HFP-11	Alarm	SMOK CST Z6 STAIR 10	X		
001:201-137	HFP-11	Alarm	SMOK CST Z6 FIRE COMMAND 2012	X		
001:201-138	HFP-11	Alarm	SMOK CST Z6 A/V CLOSET 2021	X		
001:201-139	HFP-11	Alarm	SMOK CST Z6 STORAGE RM EL201	X		
001:201-140	HFP-11	Alarm	SMOK CST Z6 STORAGE RM EL202	X		
001:201-142	HMS-S/D/M/SA	Alarm	PULL CST Z6 C ST VESTIBULE 2000	X		

001:201-143	HMS-S/D/M/SA	Alarm	PULL CST Z6 C ST VESTIBULE 2000	X		
001:201-147	HFP-11	Alarm	SMOK CST Z6 STAGING AREA X2003	X		
001:201-148	HFP-11	Alarm	SMOK CST Z6 STORAGE X2008	X		
001:201-149	HFP-11	Alarm	SMOK CST Z6 DVR ROOM X2007	X		
001:201-150	HTRI-R	Status	RELY CST Z6 DVR ROOM X2007	X		
001:201-151	HFP-11	Alarm	SMOK CST Z6 FILE ROOM 2014B	X		
001:201-152	HFP-11	Alarm	SMOK CST Z6 FILE ROOM 2013.4	X		
001:201-153	HTRI-D	Alarm/SUPV	FLOW/TAMP CST Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:201-154	HFP-11	Alarm	SMOK CST Z6 STORAGE 2003C	X		
001:201-156	HFP-11	Alarm	SMOK CST Z6 STAIR 11	X		
001:201-157	HTRI-D	Alarm/SUPV	FLOW/TAMP CST Z6 STAIR 11			
001:201-158	HFP-11	Alarm	DUCT CST Z6 OPEN OFFICE 2010	X		
001:201-159	HMS-S/D/M/SA	Alarm	PULL CST Z6 STAIR 11 EXIT	X		
001:201-160	HMS-S/D/M/SA	Alarm	PULL CST Z6 C ST VESTIBULE 2000	X		
001:201-161	HTRI-M	Trouble	PAD #2 CST Z6 STROBE PANEL	X		
001:201-162	HTRI-S	Supervisory	TAMP CST Z6 STAIR #10 STANDPIPE	X		Test with BFPE 11/3/2022, NFPA 25
001:201-163	HTRI-S	Supervisory	TAMP CST Z6 STAIR #11 STANDPIPE	X		Test with BFPE 11/3/2022, NFPA 25
001:201-164	HTRI-R	Status	RELY CST Z6 COMM 2017 SECURITY	X		
001:201-165	HTRI-R	Status	RLY C ST ENTERANCE TURNSTILE 1	X		
001:201-166	HTRI-R	Status	RLY C ST ENTERANCE TURNSTILE 2	X		
001:201-167	HTRI-R	Status	RLY C ST ENTERANCE TURNSTILE 3	X		
001:103-001	HFP-11	Alarm	SMOK JM Z6 COMM 3006	X		
001:103-002	HFP-11	Alarm	SMOK JM Z6 MEP 3006A	X		
001:103-003	HFP-11	Alarm	SMOK JM Z6 ELEC 3007	X		
001:103-004	HFP-11	Alarm	DD A32/32 JMZ6 SHAFT BY STAIR 4	X		
001:103-005	HMS-S/D/M/SA	Alarm	PULL JM Z6 STAIR 10	X		
001:103-006	HFP-11	Alarm	SMOK JM Z6 STAIR 10	X		
001:103-007	HFPT-11	Alarm	HEAT JM Z6 ELEV 16 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-008	HFP-11	Alarm	SMOK JM Z6 ELEV 16 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-009	HFP-11	Alarm	SMOK JM Z6 ELEV 15/16 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:103-010	HFPT-11	Alarm	HEAT JM Z6 ELEV 15 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-011	HFP-11	Alarm	SMOK JM Z6 ELEV 15 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-012	HFP-11	Alarm	SMOK JM Z6 CORR DOOR RELEASE	X		
001:103-013	HFP-11	Alarm	SMOK JM Z3 CORR DOOR RELEASE	X		

001:103-014	HTRI-R	Status	RELY JM Z6 ROLL UP DOOR	X		
001:103-015	HFP-11	Alarm	SMOK JM Z3 ROLL UP DOOR	X		
001:103-016	HFP-11	Alarm	SMOK JM Z6 ROLL UP DOOR	X		
001:103-021	HFP-11	Alarm	SMOK JM Z6 FILE ROOM 3005.1	X		
001:103-024	FDO421	Alarm	SMOKE JM Z6 SEC COR	X		
001:103-025	HFP-11	Alarm	SMOK JM Z6 WAITING 3005G	X		
001:103-026	HFP-11	Alarm	SMOK JM Z6 OPEN OFFICE 3005	X		
001:103-028	HTRI-R	Status	RELY JM Z6 COMM 3006 SECURITY	X		
001:103-031	HTRI-D	Alarm/SUPV	FLOW/TAMP JM Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:103-033	HFP-11	Alarm	SMOK JM Z3 CORR DOOR RELEASE	X		
001:103-034	HFP-11	Alarm	SMOK JM Z6 CORR DOOR RELEASE	X		
001:103-035	FDO421	Alarm	SMOKE JM Z6 SEC COR BY ELEC RM	X		
001:103-036	FDO421	Alarm	SMOKE JM Z6 SEC COR BY ELEV 12	X		
001:103-040	HTRI-D	Alarm/SUPV	FLOW/TAMP JM Z6 STAIR 11	X		Test with BFPE 11/3/2022, NFPA 25
001:103-041	HMS-S/D/M/SA	Alarm	PULL JM Z6 STAIR 11	X		
001:103-042	HFP-11	Alarm	SMOK JM Z6 STAIR 11	X		
001:103-043	HFP-11	Alarm	SMOK JM Z6	X		
001:103-044	HTRI-M	Trouble	PAD #4 JM Z6 STROBE PANEL	X		
001:103-045	HTRI-S	Supervisory	TAMP JM Z6 ELEV #15 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-046	HTRI-S	Supervisory	TAMP JM Z6 ELEV #16 PIT	X		Test with Schindler 3/19/2023, ASME A17
001:103-127	HFP-11	Alarm	SMOK IN Z6 ELEC 4048	X		
001:103-128	HFP-11	Alarm	SMOK IN Z6 MEP 4047B	X		
001:103-129	HFP-11	Alarm	SMOK IN Z6 COMM 4047	X		
001:103-130	HFP-11	Alarm	DD A-31/32 IA Z6 SHAFT /STAIR 4	X		
001:103-131	HFP-11	Alarm	SMOK IN Z6 STAIR 10	X		
001:103-132	HMS-S/D/M/SA	Alarm	PULL IN Z6 STAIR 10	X		
001:103-133	HFP-11	Alarm	SMOK IN Z6 A/V CLOSET 4045	X		
001:103-134	HFP-11	Alarm	SMOK IN Z3 CORR DOOR RELEASE	X		
001:103-135	HFP-11	Alarm	SMOK IN Z6 CORR DOOR RELEASE	X		
001:103-136	HFP-11	Alarm	SMOK IN Z6 ELEV 15/16 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:103-137	HTRI-R	Status	RELY IN Z6 ROLL UP DOOR	X		
001:103-138	HFP-11	Alarm	SMOK IN Z3 ROLL UP DOOR	X		
001:103-139	HFP-11	Alarm	SMOK IN Z6 ROLL UP DOOR	X		
001:103-143	HFP-11	Alarm	SMOK IN Z6 SUPPLY & COPY RM 4046	X		

001:103-144	FDO421	Alarm	SMOKE IND Z6 SEC COR	X		
001:103-146	HFP-11	Alarm	SMOK IN Z6 CHILD GUID FILES 4046	X		
001:103-149	FDO421	Alarm	SMOKE IND Z6 SEC COR	X		
001:103-151	HTRI-R	Status	RELY IN Z6 COMM 4047 SECURITY	X		
001:103-153	HTRI-D	Alarm/SUPV	FLOW/TAMP IN Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:103-155	HFP-11	Alarm	SMOK IN Z3 CORR DOOR RELEASE	X		
001:103-156	HFP-11	Alarm	SMOK IN Z6 CORR DOOR RELEASE	X		
001:103-157	FDO421	Alarm	SMOKE IND Z6 SEC COR	X		
001:103-158	FDO421	Alarm	SMOKE IND Z6 SEC COR	X		
001:103-161	HTRI-D	Alarm/SUPV	FLOW/TAMP IN Z6 STAIR 11	X		Test with BFPE 11/3/2022, NFPA 25
001:103-162	HMS-S/D/M/SA	Alarm	PULL IN Z6 STAIR 11	X		
001:103-163	HFP-11	Alarm	SMOK IN Z6 STAIR 11	X		
001:103-164	HFP-11	Alarm	DUCT INDIANA Z6 SHAFT BY STAIR 11		X	CANNOT ACCESS. AGAINST THE WALL
001:103-165	HTRI-R	Status	RELY IN Z6 COMM 4004 SECURITY	X		
001:103-166	HFP-11	Alarm	SMOK IN Z6 COMM 4004	X		
001:103-167	HFP-11	Alarm	SMOK IN Z6 MEP 4004B	X		
001:103-168	HFP-11	Alarm	SMOK IN Z6 ELEC 4003	X		
001:103-169	HFP-11	Alarm	SMOK IN Z6 A/V CLOSET 4010A	X		
001:103-170	HFP-11	Alarm	SMOK IN Z6 STORAGE 4007A	X		
001:103-171	HFP-11	Alarm	DD A-33/34 IN Z6 SHAFT/STAIR 11	X		
001:103-172	HFP-11	Alarm	DUCT INDIANA Z6 SHAFT BY STAIR-11 ELEC RM.		X	CONCEALED= REQUIRED REMOTE LED
001:103-173	HTRI-M	Trouble	PAD #6 IN Z6 STROBE PANEL	X		
001:113-001	HFP-11	Alarm	SMOK 2ND FLR Z6 COMM 5058	X		
001:113-002	HFP-11	Alarm	SMOK 2ND FLR Z6 MEP 5058B	X		
001:113-003	HFP-11	Alarm	SMOK 2ND FLR Z6 ELEC 5059	X		
001:113-004	HFP-11	Alarm	DD A-32/32 2FZ6 SHAFT BY STAIR 4	X		
001:113-005	HMS-S/D/M/SA	Alarm	PULL 2ND FLR Z2 STAIR 10	X		
001:113-006	FDO421	Alarm	SMOKE 2ND FLR Z6 SEC COR	X		
001:113-007	HFP-11	Alarm	SMOK 2ND FLR Z6 STORAGE 5047	X		
001:113-008	HFP-11	Alarm	SMOK 2ND FLR Z6 ELEV 15/16 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:113-014	HFP-11	Alarm	SMOK 2ND FLR Z6 IT STORAGE	X		
001:113-017	FDO421	Alarm	SMOKE 2ND FLR Z6 SEC COR	X		
001:113-021	HTRI-R	Status	RELY 2ND FLR Z6 COMM 5058 SEC	X		
001:113-022	HTRI-D	Alarm/SUPV	FLOW/TAMP 2ND FLR Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25

001:113-023	FDO421	Alarm	SMOKE 2ND FLR Z6 SEC COR	X		
001:113-025	FDO421	Alarm	SMOKE 2F Z6 SECURE CORR/STAIR 8	X		
001:113-028	HTRI-D	Alarm/SUPV	FLOW/TAMP 2ND FLR Z6 STAIR 11	X		Test with BFPE 11/3/2022, NFPA 25
001:113-029	HMS-S/D/M/SA	Alarm	PULL 2ND FLR Z6 STAIR 11	X		
001:113-030	HFP-11	Alarm	SMOK 2ND FLR Z6 STAIR 11	X		
001:113-031	HFP-11	Alarm	DD A-33/34 2F Z6 SHAFT /STAIR 11	X		
001:113-032	HFP-11	Alarm	SMOK 2ND FLR Z6 ELEC 5005	X		
001:113-033	HFP-11	Alarm	SMOK 2ND FLR Z6 MEP 5006B	X		
001:113-034	HTRI-R	Status	RELY 2ND FLR Z6 COMM 5006 SEC	X		
001:113-035	HFP-11	Alarm	SMOK 2ND FLR Z6 COMM 5006	X		
001:113-036	HFP-11	Alarm	DUCT 2FL Z6 SHAFT BY STAIR-11		X	CANNOT ACCESS.WALL BLOCK- DETECTOR
001:113-037	HFP-11	Alarm	DUCT 2FL Z6 SHAFT BY STAIR-11	X		
001:113-038	HTRI-M	Trouble	PAD #8 2ND Z6 STROBE PANEL	X		
001:205-001	HFP-11	Alarm	SMOK 3RD FLR Z6 COMM 6110	X		
001:205-002	HFP-11	Alarm	SMOK 3RD FLR Z6 MEP 6110B	X		
001:205-003	HFP-11	Alarm	SMOK 3RD FLR Z6 ELEC 6111	X		
001:205-004	HFP-11	Alarm	DD A-31/32 3FZ6 SHAFT BY STAIR 4	X		
001:205-005	HTRI-D	Alarm/SUPV	FLOW/TAMP 3RD FLR Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:205-006	HMS-S/D/M/SA	Alarm	PULL 3RD FLR Z2 STAIR 10	X		
001:205-007	FDO421	Alarm	SMOKE 3RD FL Z6 SEC CORR	X		
001:205-014	FDO421	Alarm	SMOKE 3RD FL Z6 SEC CORR	X		
001:205-020	FDO421	Alarm	SMOKE 3RD FL Z6 SEC CORR	X		
001:205-022	FDO421	Alarm	SMOKE 3RD FL Z6 SEC CORR	X		
001:205-023	FDO421	Alarm	SMOKE 3RD FL Z6 SEC CORR	X		
001:205-025	HMS-S/D/M/SA	Alarm	PULL 3RD FLR Z4 STAIR 11	X		
001:205-027	HTRI-D	Alarm/SUPV	TS/FS 3RD FLR Z6 STAIR 11	X		Test with BFPE 11/3/2022, NFPA 25
001:205-028	HFP-11	Alarm	DD A-33/34 3F Z6 SHAFT /STAIR 1	X		
001:205-030	HTRI-M	Trouble	PAD #10 3RD Z6 STROBE PANEL	X		
001:205-031	HTRI-R	Status	RELY 3RD FLR Z6 COMM 6110 SEC	X		
001:205-127	HFP-11	Alarm	SMOK 4TH FLR Z6 COMM 7011	X		
001:205-128	HFP-11	Alarm	SMOK 4TH FLR Z6 MEP 7011B	X		
001:205-129	HFP-11	Alarm	SMOK 4TH FLR Z6 ELEC 7010	X		
001:205-130	HFP-11	Alarm	DD A-31/32 4F Z6 SHAFT/STAIR 4	X		
001:205-131	HMS-S/D/M/SA	Alarm	PULL 4TH FLR Z6 STAIR 10	X		

001:205-132	HFP-11	Alarm	SMOK 4TH FLR Z6 STAIR 10	X		
001:205-133	HFP-11	Alarm	SMOK 4TH FLR Z3 CORR DOOR RELEAS	X		
001:205-134	HFP-11	Alarm	SMOK 4TH FLR Z6 CORR DOOR RELEAS	X		
001:205-135	HFP-11	Alarm	SMOK 4TH FLR Z6 ELEV 15/16 LOBBY	X		Test with Schindler 3/19/2023, ASME A17
001:205-137	HTRI-R	Status	RELY 4TH FLR Z6 ROLL UP DOOR	X		
001:205-138	HFP-11	Alarm	SMOK 4TH FLR Z6 ROLL UP DOOR	X		
001:205-139	HFP-11	Alarm	SMOK 4TH FLR Z3 ROLL UP DOOR	X		
001:205-140	HFP-11	Alarm	SMOK 4TH FLR Z6 LUNCH ROOM 7009H	X		
001:205-141	HFP-11	Alarm	SMOK 4TH Z6 ELEV 5 LBY STAIR 4	X		
001:205-143	HTRI-D	Alarm/SUPV	FLOW/TAMP 4TH FLR Z6 STAIR 10	X		Test with BFPE 11/3/2022, NFPA 25
001:205-146	HFP-11	Alarm	SMOK 4TH FLR Z3 CORR DOOR RELEAS	X		
001:205-147	HFP-11	Alarm	SMOK 4TH FLR Z6 CORR DOOR RELEAS	X		
001:205-148	HFP-11	Alarm	SMOK 4TH FLR Z6 CORR 7001E	X		
001:205-149	HFP-11	Alarm	SMOK 4TH FLR Z6 STAIR 8	X		
001:205-151	HMS-S/D/M/SA	Alarm	PULL 4TH FLR Z6 STAIR 11	X		
001:205-152	HFP-11	Alarm	SMOK 4TH FLR Z6 STAIR 11	X		
001:205-153	HFP-11	Alarm	DD A-33/34 4FL Z6 SHAFT/STAIR 11	X		
001:205-154	HTRI-D	Alarm/SUPV	FLOW/TAMP 4TH FLR Z6 STAIR 11	X		Test with BFPE 11/3/2022, NFPA 25
001:205-155	HTRI-M	Trouble	PAD #12 4TH Z6 STROBE PANEL	X		
001:205-156	HTRI-M	Trouble	PAD #14 4TH Z6 (ROOF STROBES)	X		
001:205-157	HTRI-S	Supervisory	TAMP 4TH FLR Z6 ELEV #1 TOS	X		Test with Schindler 3/19/2023, ASME A17
001:205-158	HTRI-S	Supervisory	TAMP 4TH FLR Z6 ELEV #2 TOS	X		Test with Schindler 3/19/2023, ASME A17
001:205-159	HTRI-R	Status	RELY 4TH FLR Z6 COMM 7011 SEC	X		
001:215-001	HFP-11	Alarm	SMOK ROOF Z6 ELEV 16 TOP OF SHAF	X		Test with Schindler 3/19/2023, ASME A17
001:215-002	HFPT-11	Alarm	HEAT ROOF Z6 ELEV 16 TOP OF SHAF	X		Test with Schindler 3/19/2023, ASME A17
001:215-003	HFP-11	Alarm	SMOK ROOF Z6 ELEV 15/16 MR 8000	X		Test with Schindler 3/19/2023, ASME A17
001:215-004	HFPT-11	Alarm	HEAT ROOF Z6 ELEV 15/16 MR 8000	X		Test with Schindler 3/19/2023, ASME A17
001:215-005	HFP-11	Alarm	SMOK ROOF Z6 ELEV 15 TOP OF SHAF	X		Test with Schindler 3/19/2023, ASME A17
001:215-006	HFPT-11	Alarm	HEAT ROOF Z6 ELEV 15 TOP OF SHAF	X		Test with Schindler 3/19/2023, ASME A17
001:215-007	FDCIO B	Relay	4IO ROOF Z6 ELEV 15 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:215-008	HTRI-R	Supervisory	PWR LOSS ROOF Z6 ELV 15 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:215-009	FDCIO B	Relay	4IO ROOF Z6 ELEV 16 RECALL	X		Test with Schindler 3/19/2023, ASME A17
001:215-010	HTRI-R	Supervisory	PWR LOSS ROOF Z6 ELV 16 SHUNT	X		Test with Schindler 3/19/2023, ASME A17
001:215-011	HTRI-R	Status	RELY ROOF Z6 STAIR 10 PRESS FAN	X		

001:215-012	HTRI-R	Status	RELY ROOF Z6 STAIR 11 PRESS FAN	X		
001:215-013	HTRI-R	Supervisory	TAMP ROOF Z6 ELEV 15/16 MR 8000	X		Test with Schindler 3/19/2023, ASME A17

Supplementary Records 10 pages

H. Carl Moultrie DC Superior Court

500 Indiana Avenue

7.1, 7.2, 7.3, 7.5 and 7.11

ADDRESS	TYPE	CLASS STYLE	LOCATION	Charger VDC	Battery PASS	Battery FAIL	DATE OF MANUFAC TURE	PRIMARY POWER		SECONDARY POWER		COMMENT
								AC STAND -BY	AC ALARM LOAD	DC STAND -BY	DC ALARM LOAD	
19	FACP XLSV SIEMENS	X	C Level, Engineers office	27.22	X		8/11/22	.38	.40	.94	1.0	35AH X2 Battery > 31ah / 31ah 120vac Disconnect ELL3C Ckt.#32 Electrical room JM-C by stair-6
20	XLSRV-1 SIEMENS	X	JM Level by Stair-1 Communication JM-A	27.15	X		8/11/22	.70	1.46	1.70	5.34	100AH X2 Battery > 70ah / 70ah 120vac Disconnect ELL4B Ckt.#1 Electrical room 1-B by stair-3 NOTE: Batteries are failed at 38ah / 50ah and charge the batteries externally for 72hrs and results with 70ah each
25-3	NACP PS-6 Wheelock	B	JM Level by Stair-1 Communication JM-A	27.55	X		6/19/22	.13	.38	.08	1.75	7AH X2 Battery > 7ah / 7ah 120vac Disconnect ELL4B Ckt.#1 Electrical room 1-B by stair-3
25-1	NACP PS-6 Wheelock	B	JM Level by Stair-1 Communication JM-A	27.55	X		6/19/22	.14	.37	.08	1.13	7AH X2 Battery > 7.65ah / 7.65ah 120vac Disconnect ELL4B Ckt.#1 Electrical room 1-B by stair-3
25-2	NACP PS-6 Wheelock	B	JM Level by Stair-1 Communication JM-A	27.25	X		6/19/22	.13	.97	.08	4.70	7AH X2 Battery > 8ah / 8ah 120vac Disconnect ELL4B Ckt.#1 Electrical room 1-B by stair-3
25-3.1	NACP PS-6 Wheelock	B	JM Level by Stair-1 Communication JM-A	26.25	X		6/19/22	.13	.43	.12	1.86	7AH X2 Battery > 7.3ah / 7.6ah 120vac Disconnect ELL4B Ckt.#1 Electrical room 1-B by stair-3

NFPA 72, Fig. 14.6.2.4 (p. 1 of 12)

30	XLSRV-2 SIEMENS	X	JM Level by Stair-3 Communication JM-C	27.25	X		8/11/22	.70	.86	1.63	4.01	100AH X2 Battery >70ah / 65ah 120vac Disconnect ELL4B Ckt.#3 Electrical room 1-B by stair-3
35-3	NACP PS-6 Wheelock	B	JM Level by Stair-3 Communication JM-C	27.75	X		6/19/22	.15	.62	.08	2.42	7AH X2 Battery > 6.52ah / 6.76ah 120vac Disconnect ELL4B Ckt.#3 Electrical room 1-B by stair-3
35-1 &2	NACP PS-6 Wheelock	B	JM Level by Stair-3 Communication JM-C	27.60	X		6/19/22	.13	.80	.08	3.9	7AH X2 Battery > 6.7ah / 6.7ah 120vac Disconnect ELL4B Ckt.#3 Electrical room 1-B by stair-3
40	XLSRV-3 SIEMENS	X	C Level by Stair-8 Communication C-H	27.25	X		8/11/22	.65	.84	1.30	2.04	100AH X2 Battery > 65ah / 65ah 120vac Disconnect ELL3E Ckt.#7 Electrical room JM-E by stair-8
45-3	NACP PS-6 Wheelock	B	C Level by Stair-8 Communication C-H	27.16	X		6/19/22	.12	.22	.12	.63	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL3E Ckt.#7 Electrical room JM-E by stair-8
45-1&2	NACP PS-6 Wheelock	B	C Level by Stair-8 Communication C-H	27.77	X		6/19/22	.14	.57	.08	2.04	7AH X2 Battery > 7.3ah / 6.7ah 120vac Disconnect ELL3E Ckt.#7 Electrical room JM-E by stair-8
45-3	NACP PS-6 Wheelock	B	C Level by Stair-8 Communication C-H	27.71	X		6/19/22	.13	.35	.08	1.05	7AH X2 Battery > 6.7ah / 7.3ah 120vac Disconnect ELL3E Ckt.#7 Electrical room JM-E by stair-8
50	XLSRV-4 SIEMENS	X	C Level by Stair-6 Communication C-E	27.28	X		8/11/22	.68	.90	1.33	3.31	100AH X2 Battery >65ah / 65ah 120vac Disconnect ELL3C Ckt.#5 Electrical room JM-C by stair-6 NOTE: Batteries are failed at 45ah / 50ah and charge the batteries externally for 50hrs and results with 65ah each
55-2	NACP PS-6 Wheelock	B	C Level by Stair-6 Communication C-E	26.83	X		6/19/22	.13	.27	.11	1.17	7AH X2 Battery > 8ah / 7.3ah 120vac Disconnect ELL3C Ckt.#5 Electrical room JM-C by stair-6
55-3	NACP	B	C Level by Stair-6	26.54	X		6/19/22	.12	.60	.08	2.66	7AH X2 Battery > 7ah / 7.3ah

NFPA 72, Fig. 14.6.2.4 (p. 2 of 12)

	PS-6 Wheelock		Communication C-E									120vac Disconnect ELL3C Ckt.#5 Electrical room JM-C by stair-6
55-2.1	NACP PS-6 Wheelock	B	C Level by Stair-6 Communication C-E	26.15	X		6/19/22	.11	.80	.08	4.10	7AH X2 Battery > 6.1ah /6.2ah 120vac Disconnect ELL3C Ckt.#5 Electrical room JM-C by stair-6
60	XLSRV-5 SIEMENS	X	JM Level secure corridor Between Stair-6 and Stair 7	27.15	X		8/11/22	.75	.96	1.41	2.53	100AH X2 Battery > 65ah / 65ah 120vac Disconnect ELL3C Ckt.#28 Electrical room JM-C by stair-6
65-1	NACP PS-6 Wheelock	B	JM Level secure corridor Between Stair-6 and Stair 7	26.55	X		6/19/22	.12	.23	.08	.80	7AH X2 Battery > 7.3ah /7.3ah 120vac Disconnect ELL3C Ckt.#28 Electrical room JM-C by stair-6
65-2	NACP PS-6 Wheelock	B	JM Level secure corridor Between Stair-6 and Stair 7	26.75	X		6/19/22	.16	.26	.08	.37	7AH X2 Battery > 7.3ah /7.0ah 120vac Disconnect ELL3C Ckt.#28 Electrical room JM-C by stair-6
65-3	NACP PS-6 Wheelock	B	JM Level secure corridor Between Stair-6 and Stair 7	26.10	X		6/19/22	.13	1.2	.08	5.70	7AH X2 Battery > 7.0ah /7.0ah 120vac Disconnect ELL3C Ckt.#28 Electrical room JM-C by stair-6
70	XLSRV-6 SIEMENS	X	C Level by USM C-600	27.25		X	8/11/22	.78	1.16	1.77	3.45	100AH X2 Battery >51ah / 65ah 120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
75-4	NACP PS-6 Wheelock	B	C Level by USM C-600	NOT IN SERVICE								7AH X2 Battery > 120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
75-3	NACP PS-6 Wheelock	B	C Level by USM C-600	27.32	X		6/19/22	.13	.39	.08	1.15	7AH X2 Battery > 8ah /7.3ah 120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
75-1	NACP PS-6 Wheelock	B	C Level by USM C-600	27.35	X		6/19/22	.11	.29	.08	2.32	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
75-1&2	NACP PS-6 Wheelock	B	C Level by USM C-600	26.72	X		6/19/22	.13	.48	.08	1.60	7AH X2 Battery > 7.6ah /7.3ah 120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
75-5	NACP	B	C Level by USM C-600	NOT IN								7AH X2 Battery >

NFPA 72, Fig. 14.6.2.4 (p. 3 of 12)

	PS-6 Wheelock			SERVICE								120vac Disconnect ELL3E Ckt.#1 Electrical room JM-E by stair-8
80	XLSRV-7 LOC SIEMENS	X	Indiana CSO Main Control room	27.11	X		8/11/22	.39	.40	.87	.90	35AH X2 Battery >34.5ah /34.5ah 120vac Disconnect LL4E2 Ckt.#22 Electrical room 1-E by stair-8
90	XLSRV-8 SIEMENS	X	2 nd Floor by Stair-10 Communication 2-FF	27.35		X	8/11/22	.65	.90	1.55	3.53	100AH X2 Battery >51.5ah /65ah 120vac Disconnect ELL3E Ckt.#3 Electrical room JM-E by stair-8
95-1	NACP PS-6 Wheelock	B	2 nd Floor by Stair-10 Communication 2-FF	27.40	X		6/19/22	.13	.50	.08	2.23	7AH X2 Battery > 7.3ah / 7ah 120vac Disconnect ELL3E Ckt.#3 Electrical room JM-E by stair-8
95-2	NACP PS-6 Wheelock	B	2 nd Floor by Stair-10 Communication 2-FF	27.30	X		6/19/22	.13	.75	.08	3.10	7AH X2 Battery > 7.3ah / 7.6ah 120vac Disconnect ELL3E Ckt.#3 Electrical room JM-E by stair-8
95-3	NACP PS-6 Wheelock	B	2 nd Floor by Stair-10 Communication 2-FF	27.40	X		6/19/22	.14	.47	.08	1.88	7AH X2 Battery > 7.6ah / 7ah 120vac Disconnect ELL3E Ckt.#3 Electrical room JM-E by stair-8
100	XLSRV-9 SIEMENS	X	2 nd Floor by Stair-6 Communication 2-E	27.25	X		8/11/22	.60	.90	1.18	2.80	100AH X2 Battery > 73ah / 65ah 120vac Disconnect ELL3C Ckt.#26 Electrical room JM-C by stair-6
105-1	NACP PS-6 Wheelock	B	2 nd Floor by Stair-6 Communication 2-E	27.71	X		6/19/22	.12	.53	.08	2.22	7AH X2 Battery > 7.6ah / 8ah 120vac Disconnect ELL3C Ckt.#26 Electrical room JM-C by stair-6
105-2	NACP PS-6 Wheelock	B	2 nd Floor by Stair-6 Communication 2-E	26.92	X		6/19/22	.13	.57	.08	2.22	7AH X2 Battery > 7.3ah / 7.3ah 120vac Disconnect ELL3C Ckt.#26 Electrical room JM-C by stair-6
105-3	NACP PS-6 Wheelock	B	2 nd Floor by Stair-6 Communication 2-E	27.75	X		6/19/22	.13	.55	.08	2.35	7AH X2 Battery > 7.6ah / 8ah 120vac Disconnect ELL3C Ckt.#26 Electrical room JM-C by stair-6
110	XLSRV-10	X	2 nd Floor by Stair-7	27.25		X	8/11/22	.60	1.60	1.56	5.35	100AH X2 Battery > 65ah / 51ah

NFPA 72, Fig. 14.6.2.4 (p. 4 of 12)

	SIEMENS		Communication 2-F									120vac Disconnect ELL4C Ckt.#3 Electrical room 4-C by stair-6
115-1&2	NACP PS-6 Wheelock	B	2 nd Floor by Stair-7 Communication 2-F	27.35	X		6/19/22	.13	1.12	.77	8.12	7AH X2 Battery > 7.3ah / 7.3ah 120vac Disconnect ELL4C Ckt.#3 Electrical room 4-C by stair-6 CIRCUIT OVER LOAD #1 0.52A #2 2.06A #3 3.90A #4 0.64A = 3AMP MAX./CIRCUIT
115-3&4	NACP PS-6 Wheelock	B	2 nd Floor by Stair-7 Communication 2-F	26.75	X		6/19/22	.13	.98	.08	6.06	7AH X2 Battery > 6.7ah / 5.14ah 120vac Disconnect ELL4C Ckt.#3 Electrical room 4-C by stair-6 CIRCUIT OVER LOAD #1 0.42A #2 SPARE #3 0.70A #4 3.34A = 3AMP MAX./CIRCUIT
115-2	NACP PS-6 Wheelock	B	2 nd Floor by Stair-7 Communication 2-F	27.42	X		6/19/22	.14	.30	.08	.42	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL4C Ckt.#3 Electrical room 4-C by stair-6
120	XLSRV-11 SIEMENS	X	3rd Floor by Stair-1 Communication 3-A	27.15		X	8/11/22	.65	1.1	1.38	4.10	100AH X2 Battery > 51ah / 65ah 120vac Disconnect ELL8B Ckt.#12 Electrical room 5-B by stair-3
125-1&2	NACP PS-6 Wheelock	B	3rd Floor by Stair-1 Communication 3-A	27.72	X		6/19/22	.13	.99	.08	5.10	7AH X2 Battery > 4.6AH, 5.8AH 120vac Disconnect ELL8B Ckt.#12 Electrical room 5-B by stair-3
125-3.1	NACP PS-6 Wheelock	B	3rd Floor by Stair-1 Communication 3-A	27.10	X		6/19/22	.11	.60	.11	2.68	7AH X2 Battery > 8ah / 8ah 120vac Disconnect ELL8B Ckt.#12 Electrical room 5-B by stair-3
125-3	NACP PS-6 Wheelock	B	3rd Floor by Stair-1 Communication 3-A	27.35	X		6/19/22	.13	.44	.08	1.59	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL8B Ckt.#12 Electrical room 5-B by stair-3
130	XLSRV-12 SIEMENS	X	3rd Floor by Stair-3 Communication 3-C	27.25		X	8/11/22	.60	.90	1.25	2.82	100AH X2 Battery > 51ah / 51ah 120vac Disconnect ELL8B Ckt.#10 Electrical room 5-B by stair-3
135-1	NACP	B	3rd Floor by Stair-3	26.80	X		6/19/22	.13	.66	.08	1.91	7AH X2 Battery > 7.6ah / 7.3ah

NFPA 72, Fig. 14.6.2.4 (p. 5 of 12)

	PS-6 Wheelock		Communication 3-C									120vac Disconnect ELL8B Ckt.#10 Electrical room 5-B by stair-3
135-2	NACP PS-6 Wheelock	B	3rd Floor by Stair-3 Communication 3-C	27.50	X		6/19/22	.13	.59	.08	2.43	7AH X2 Battery > 7.3ah / 7.3ah 120vac Disconnect ELL8B Ckt.#10 Electrical room 5-B by stair-3
135-3	NACP PS-6 Wheelock	B	3rd Floor by Stair-3 Communication 3-C	27.25	X		6/19/22	.12	.42	.08	1.46	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL8B Ckt.#10 Electrical room 5-B by stair-3
140	XLSRV-13 SIEMENS	X	5th Floor by Stair-8 Communication 5-H	27.35	X		8/11/22	.74	1.83	1.67	5.93	100AH X2 Battery >70ah / 70ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8 NOTE: Batteries are failed at 31ah / 34ah and charge the batteries externally for 90hrs and results with 70ah each
145-4	NACP PS-6 Wheelock	B	5th Floor by Stair-8 Communication 5-H	27.35	X		6/19/22	.16	.18	.12	.16	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8
145-3	NACP PS-6 Wheelock	B	5th Floor by Stair-8 Communication 5-H	27.70	X		6/19/22	.13	.77	.08	3.27	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8
145-2	NACP PS-6 Wheelock	B	5th Floor by Stair-8 Communication 5-H	27.25	X		6/19/22	.12	.89	.08	3.76	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8
145-1	NACP PS-6 Wheelock	B	5th Floor by Stair-8 Communication 5-H	27.35	X		6/19/22	.13	.52	.08	1.91	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8
145-3	NACP PS-6 Wheelock	B	5th Floor by Stair-8 Communication 5-H	27.30	X		6/19/22	.16	.47	.12	1.77	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL9E Ckt.#6 Electrical room 6-E by stair-8
150	XLSRV-14 SIEMENS	X	5th Floor by Stair-6 Communication 5-E	27.12		X	8/11/22	.69	1.28	1.80	3.96	100AH X2 Battery > 65ah / 38ah 120vac Disconnect ELL7C Ckt.#12 Electrical room 4-C by stair-6
155-1	NACP	B	5th Floor by Stair-6	27.35	X		6/19/22	.14	.42	.08	1.22	7AH X2 Battery > 8ah / 7.3ah

NFPA 72, Fig. 14.6.2.4 (p. 6 of 12)

	PS-6 Wheelock		Communication 5-E									120vac Disconnect ELL7C Ckt.#12 Electrical room 4-C by stair-6
155-2	NACP PS-6 Wheelock	B	5th Floor by Stair-6 Communication 5-E	27.30	X		6/19/22	.10	.11	.11	1.61	7AH X2 Battery > 7.6ah / 7ah 120vac Disconnect ELL7C Ckt.#12 Electrical room 4-C by stair-6
155-3	NACP PS-6 Wheelock	B	5th Floor by Stair-6 Communication 5-E	27.30	X		6/19/22	.11	.56	.08	3.10	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL7C Ckt.#12 Electrical room 4-C by stair-6
155-3	NACP PS-6 Wheelock	B	5th Floor by Stair-6 Communication 5-E	27.70	X		6/19/22	.13	.74	.12	2.46	7AH X2 Battery > 7ah / 6.7ah 120vac Disconnect ELL7C Ckt.#12 Electrical room 4-C by stair-6
160	XLSRV-15 SIEMENS	X	4th Floor by Stair-7 Communication 4-F	27.15	X		8/11/22	.58	.99	1.15	2.64	100AH X2 Battery >65ah / 65ah 120vac Disconnect ELL7C Ckt.#8 Electrical room 4-C by stair-6
165-1&2	NACP PS-6 Wheelock	B	4th Floor by Stair-7 Communication 4-F	27.30	X		6/19/22	.13	.53	.08	1.91	7AH X2 Battery > 7.3ah / 7.3ah 120vac Disconnect ELL7C Ckt.#8 Electrical room 4-C by stair-6
165-2	NACP PS-6 Wheelock	B	4th Floor by Stair-7 Communication 4-F	27.35	X		6/19/22	.16	.50	.12	1.75	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL7C Ckt.#8 Electrical room 4-C by stair-6
165-2	NACP PS-6 Wheelock	B	4th Floor by Stair-7 Communication 4-F	27.40	X		6/19/22	.11	.26	.12	.79	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL7C Ckt.#8 Electrical room 4-C by stair-6
112-14	NACP PAD-4 Siemens	B	4th Floor by Stair-7 Communication 4-F New installed by Cooper/PPSI PAD-4	26.98	X		10/4/22	.11	.88	.06	1.05	7AH X2 Battery > 6.5ah / 6.5ah 120vac Disconnect ELL7C Ckt.#8 Electrical room 4-C by stair-6
141-58	NACP PAD-4 Siemens	B	4th Floor Electrical room 4-E by Stair-8 New installed by Cooper/PPSI	27.32	X		4/22/19	.08	.69	.07	3.1	7AH X2 Battery > 6ah / 6ah 120vac Disconnect LL7E Ckt.#37 Same room.
170	XLSRV-16 SIEMENS	X	5th Floor by Stair-1 Communication 5-A	27.11	X		8/11/22	.66	.95	1.58	2.66	100AH X2 Battery >65ah / 70ah 120vac Disconnect ELL8B Ckt.#11

NFPA 72, Fig. 14.6.2.4 (p. 7 of 12)

												Electrical room 5-B by stair-3 NOTE: Batteries are failed at 51ah / 50ah and charge the batteries externally for 24hrs and results with 70ah each
175-3	NACP PS-6 Wheelock	B	5th Floor by Stair-1 Communication 5-A	27.30	X		6/19/22	.13	.33	.08	.86	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL8B Ckt.#11 Electrical room 5-B by stair-3
175-2	NACP PS-6 Wheelock	B	5th Floor by Stair-1 Communication 5-A	27.13	X		6/19/22	.13	.51	.08	1.82	7AH X2 Battery > 7ah / 7.3ah 120vac Disconnect ELL8B Ckt.#11 Electrical room 5-B by stair-3
180	XLSRV-17 SIEMENS	X	5th Floor by Stair-3 Communication 5-C	27.28	X		8/11/22	.71	1.2	1.53	3.85	100AH X2 Battery >65ah / 65ah 120vac Disconnect ELL8B Ckt.#8 Electrical room 5-B by stair-3
185-2&3	NACP PS-6 Wheelock	B	5th Floor by Stair-3 Communication 5-C	27.35	X		6/19/22	.13	.95	.08	4.29	7AH X2 Battery > 7.6ah / 6.5ah 120vac Disconnect ELL8B Ckt.#8 Electrical room 5-B by stair-3
185-1	NACP PS-6 Wheelock	B	5th Floor by Stair-3 Communication 5-C	27.30	X		6/19/22	.13	.25	.08	.55	7AH X2 Battery > 7.6ah / 7.3ah 120vac Disconnect ELL8B Ckt.#8 Electrical room 5-B by stair-3
216	XLSRV-18 LOC SIEMENS	X	C str. Out-side Main entry C addition	27.35		X	3/2/18	.46	.46	1.21	1.26	100AH X2 Battery >18.7ah / 15ah 120vac Disconnect EFAP-Ckt.#1 Next to XLSRV-18
217	XLSRV-19 SIEMENS	X	C Floor By Stair-4 Mechanical C-MM	27.43		X	1/1/18	.55	.85	1.63	2.82	100AH X2 Battery >11ah / 15ah 120vac Disconnect EFAP-Ckt.#3 Next to XLSRV-18
201-161	NACP PS-8-LP Wheelock	A	C Floor By Stair-4 Mechanical C-MM	27.60		X	3/2/18	.12	.42	.14	1.48	7AH X2 Battery > 3.4ah / 4.2ah 120vac Disconnect EFAP-Ckt.#9 Next to XLSRV-18
201-76	NACP PS-8-LP Wheelock	A	C Floor By Stair-4 Mechanical C-MM	27.65		X	3/2/18	.12	.23	.14	.61	7AH X2 Battery > 3.7ah / 3.6ah 120vac Disconnect EFAP-Ckt.#9 Next to XLSRV-18

NFPA 72, Fig. 14.6.2.4 (p. 8 of 12)

63	XLSRV-20 SIEMENS	X	C Floor By Stair-9 Mechanical C-BB	27.30		X	4/8/21	.43	.56	1.10	1.67	100AH X2 Battery >51ah / 39ah 120vac Disconnect EFAP-Ckt.#2 Next to XLSRV-18
66-1	NACP PS-8-LP Wheelock	A	C Floor by Stair-9 Mechanical C-BB	27.56	X		12/16/21	.12	.29	.14	1.00	7AH X2 Battery > 6.5ah /6.2ah 120vac Disconnect EFAP-Ckt.#8 Next to XLSRV-18
219	XLSRV-21 SIEMENS	X	Indiana Fl By Stair-4 Mechanical 1-MM	27.30		X	1/1/18	.65	1.24	2.04	4.71	100AH X2 Battery >22ah /13.6ah 120vac Disconnect EFAP-Ckt.#5 Next to XLSRV-18
103-173	NACP PS-8-LP Wheelock	A	Indiana Fl By Stair-4 Mechanical 1-MM	27.42	X		3/2/18	.13	.46	.14	1.30	7AH X2 Battery > 5.5ah / 6.2ah 120vac Disconnect EFAP-Ckt.#13 Next to XLSRV-18
113-38	NACP PS-8-LP Wheelock	A	2nd Fl By Stair-4 Mechanical 2-MM	27.55	X		3/2/18	.12	.46	.14	1.80	7AH X2 Battery > 6.2ah /6.2ah 120vac Disconnect EFAP-Ckt.#15 Next to XLSRV-18
103-44	NACP PS-8-LP Wheelock	A	JM Floor By Stair-4 Mechanical J-MM	27.20	X		3/2/18	.12	.36	.14	1.30	7AH X2 Battery > 6.76ah / 7ah 120vac Disconnect EFAP-Ckt.#11 Next to XLSRV-18
46	XLSRV-22 SIEMENS	X	Indiana fl By Stair-11 Mechanical 1-JJ	27.37		X	4/8/21	.64	.98	1.13	2.96	100AH X2 Battery >23ah / 19.ah 120vac Disconnect EFAP-Ckt.#12 Next to XLSRV-18 NOTE: Batteries are failed and being charge the from 5/4/23 at 12:30am externally and will re- test for results on 5/8/2023
54-2	NACP PS-8-LP Wheelock	A	Indiana fl By Stair-11 Mechanical 1-JJ	27.27	X		1/25/22	.12	.41	.14	1.58	7AH X2 Battery > 6.7ah / 6.7ah 120vac Disconnect EFAP-Ckt.#4 Next to XLSRV-18
54-3	NACP PS-8-LP	A	2nd floor By Stair-11 Mechanical 2-QQ	27.10	X		1/25/22	.12	.47	.14	1.92	7AH X2 Battery > 6.ah /6.5ah 120vac Disconnect EFAP-Ckt.#14

NFPA 72, Fig. 14.6.2.4 (p. 9 of 12)

	Wheelock											Next to XLSRV-18
54-1	NACP PS-8-LP Wheelock	A	JM Floor By Stair-9 Mechanical JM-JJ	27.60	X		12/16/21	.12	.35	.14	1.29	7AH X2 Battery > 6.2ah / 6.5ah 120vac Disconnect EFAP-Ckt.#10 Next to XLSRV-18
222	XLSRV-23 SIEMENS	X	4 TH floor By Stair-4 Mechanical 4-MM	27.14		X	1/1/18	.60	1.18	1.71	4.16	100AH X2 Battery >11ah / 14ah 120vac Disconnect EFAP-Ckt.#7 Next to XLSRV-18
205-156	NACP PS-8-LP Wheelock	A	4 TH floor By Stair-4 Mechanical 4-MM	27.61	X		3/2/18	.12	.15	.14	.26	7AH X2 Battery > 5ah / 5.14ah 120vac Disconnect EFAP-Ckt.#19 Next to XLSRV-18
205-155	NACP PS-8-LP Wheelock	A	4 TH floor By Stair-4 Mechanical 4-MM	27.61		X	3/2/18	.12	.34	.14	1.20	7AH X2 Battery > 5.5ah / 3.36ah 120vac Disconnect EFAP-Ckt.#19 Next to XLSRV-18
205-30	NACP PS-8-LP Wheelock	A	3nd floor By Stair-4 Mechanical 3-MM	27.55	X		3/2/18	.12	.48	.14	1.80	7AH X2 Battery > 6ah / 5.8ah 120vac Disconnect EFAP-Ckt.#17 Next to XLSRV-18
85	XLSRV-24 SIEMENS	X	4th floor By Stair-9 Mechanical 4-BB	27.23	X		4/8/21	.40	.67	.92	2.03	100AH X2 Battery >68ah / 68ah 120vac Disconnect EFAP-Ckt.#6 Next to XLSRV-18 NOTE: Batteries are failed at 38ah / 51ah and charge the batteries externally for 90hrs and resulted with 68ah each
87-1	NACP PS-8-LP Wheelock	A	4th floor By Stair-9 Mechanical 4-BB	27.52	X		12/16/21	.12	.26	.14	1.44	7AH X2 Battery > 6.2ah / 6.2ah 120vac Disconnect EFAP-Ckt.#18 Next to XLSRV-18
87-2	NACP PS-8-LP Wheelock	A	3rd floor By Stair-9 Mechanical 3-BB	27.65	X		12/16/21	.12	.39	.14	1.37	7AH X2 Battery > 6.2ah / 6.2ah 120vac Disconnect EFAP-Ckt.#16 Next to XLSRV-18

NFPA 72, Fig. 14.6.2.4 (p. 10 of 12)

Keltron >TX 10.3.7.17	Indiana CSO Main Control		X		10/05/20					12AH X1 Battery > 10.6ah 120vac Disconnect LL4E2 Ckt.#22 Electrical room 1-E by stair-8
--------------------------	--------------------------	--	---	--	----------	--	--	--	--	---

7.11 STAIR PRESSURIZATION

Floor	STAIR-1 Smoke Detector	STAIR-2 Smoke Detector	STAIR-3 Smoke Detector	STAIR-4 Smoke Detector	STAIR-5 Smoke Detector	STAIR-6 Smoke Detector	STAIR-7 Smoke Detector	STAIR-8 Smoke Detector	STAIR-9 Smoke Detector
6	N/A	N/A	N/A	N/A	172-06	152-19	162-12	143-13	143-14
5	171-16	171-14	182-01	182-05	182-07	151-23	161-06	142-10	142-11
4	171-11	171-13	181-13	181-14	181-15	151-22	112-18	205-149	141-17
3	123-09	123-10	133-13	133-14	133-15	102-17	112-17	92-22	92-24
2	122-11	122-12	132-10	132-11	132-12	102-16	111-20	92-21	92-23
Indiana	121-11	121-12	131-08	131-09	131-10	101-59	111-17	91-42	91-02
JM	24-10	24-11	34-08	34-09	34-48	52-54	73-60	42-49	45-50
C	22-09	23-10	33-05	201-135	33-07	52-53	N/A (JAIL)	42-28	64-02
Parking	21-05	21-06	31-09	31-10	N/A	51-03	71-13	41-1	41-08

NFPA 72, Fig. 14.6.2.4 (p. 11 of 12)

7.11 STAIR PRESSURIZATION C addition only

Floor	STAIR-10	STAIR-11
5	All new Initiating devices in C addition activate the stair pressurization. Manual pull stations, Smoke detectors, Heat detectors, Duct detectors and Water flows.	All new Initiating devices in C addition activate the stair pressurization. Manual pull stations, Smoke detectors, Heat detectors, Duct detectors and Water flows.
4		
3		
2		
Indiana		
JM		
C		
Parking		