

System: Fire-Lite Model: MS 9600 UDLS

DEVICE TEST RESULTS

(Attach additional sheets if required)

Address		Device Type	Location	Test Results/ Comment
1-D01	ALARM	SMOK E-PHOTO	ABOVE PANEL	
1-D020	ALARM	DUCT DETECTOR	RETURN – RTU 1 IN MENS BATHROOM	
1-D022	ALARM	DUCT DETECTOR	SUPPLY – RTU 1 IN MENS BATHROOM	
1-D023	ALARM	DUCT DETECTOR	RETURN – RTU 2 CORRIDOR BY RM 185	
1-D025	ALARM	DUCT DETECTOR	SUPPLY – RTU 2 CORRIDOR BY RM 185	
1-D082	ALARM	DUCT DETECTOR	RTU 3 - WOMENS	
1-D083		SMOKE PHOTO	RTU 3 -WOMENS	
1-D084	ALARM	DUCT DETECTOR	RTU 4- MULTI PURPOSE ROOM RM-150	
1-M01	ALARM	PULL	FRONT DOOR	
1-M02	ALARM	PULL	REAR EXIT	
1-M03		RELAY	FRONT DOOR RELEASE	
1-M021		RELAY	RTU1 - SHUTDOWN	
1-M042		RELAY	RTU2 - SHUTDOWN	
1-M082		RELAY	RTU3 - SHUTDOWN	
1-M083		RELAY	RTU4 - SHUTDOWN	
2-M50		RELAY	ALARM TO 2575 REED ST.	
2-M51		MONITOR	ALARM FROM 2575 REED ST.	

ADDITIONAL COMMENTS	
Central Station- CINTAS 1-800-932-3822 ACCOUNT # H460237 PASSCODE> DOUGLAS1 MONITORING is contracted with Douglas development.	BEFORE ANY WORK OR TESTING. BOTH BUILDING NEEDS TO CALL OUT TO MONITORING STATION. <i>THIS BUILDING ACTIVATE NEXT DOOR FIRE ALARM SYSTEM 2575 REED ST. ALSO NEXT DOOR SPACE 920-A.</i> WHEN BUILDING IS IN ALARM, THE FIRE DEPARTMENT GOES TO 920 RHODE ISLAND. BECAUSE THAT IS IN THE CONTRACT WITH CENTRAL STATION.

NOTE: 2 PHONE LINES ARE OUT OF SERVICE. Chuck Page and his Boss Tim Roberts of Douglas development were notified since April with this concerning issue and again today were notified. CSO on duty were advised to call 911 if signs of Smoke or Fire in the building.