

System: Fire-Lite Model: MS 9200 UDLS

**DEVICE TEST RESULTS**

(Attach additional sheets if required)

Address		Device Type	Location	Test Results
1-D001	ALARM	SMOKE-PHOTO	ABOVE PANEL	
1-M001	ALARM	FLOW	RM 129 A/V CLOSET	
1-M002	SUPV.	TAMPER	RM 129 A/V CLOSET	
1-M003	ALARM	PULL	REAR EXIT	
1-M004	ALARM	PULL	FRONT ENTRANCE 2575	
1-M005		RELAY	DOOR RELEASE	
1-M006		PULL	SOUTH EXIT DOOR	
1-M007		RELAY	NAC CONTROL PANEL	
1-M008	TRBL.	MONITOR	NAC CONTROL PANEL	
1-M009		RELAY	DOOR RELEASE – ADT	
1-M010	ALARM	MONITOR	ALARM TO 2575 REED ST.	
1-M011	SUPV	MONITOR	SUPERVISORY TO 2575 REED ST.	
1-M012	TROUBLE	MONITOR	TROUBLE TO 2575 REED ST.	
1-M013		RELAY	ALARM TO RHODE ISLAND	

ADDITIONAL COMMENTS	
Central Station- CINTAS 1-800-932-3822 <b>ACCOUNT # H460237</b> <b>PASSCODE&gt; DOUGLAS1</b> <b>MONITORING is contracted with Douglas development.</b>	<b>BEFORE ANY WORK OR TESTING.</b> BOTH BUILDING NEEDS TO CALL OUT TO MONITORING STATION. <b><i>THIS BUILDING ACTIVATE NEXT DOOR FIRE ALARM SYSTEM 920 Rhode Island.</i></b> WHEN BUILDING IS IN ALARM, THE FIRE DEPARTMENT GOES TO 920 RHODE ISLAND. BECAUSE THAT IS IN THE CONTRACT WITH CENTRAL STATION.

**NOTE:** 2 PHONE LINES ARE OUT OF SERVICE. Chuck Page and his Boss Tim Roberts of Douglas development were notified since April with this concerning issue and again today were notified. CSO on duty were advised to call 911 if signs of Smoke or Fire in the building.