

System: Notifier Model: AFP-200

**DEVICE TEST RESULTS**

(Attach additional sheets if required)

Address		Device Type	Location	Test Results
1M001	ALARM	PULL	Front left door	
1M002	ALARM	PULL	Main entrance 1FL.	
1M003	ALARM	FLOW	1 <sup>ST</sup> FL. FLOW	
1M004	SUPV.	TAMPER	1 <sup>ST</sup> FL. TAMPER	
1M005	SUPV.	TAMPER	MAIN TAMPER	
1M006	SUPV.	TAMPER	MAIN TAMPER	
1M007		RELAY	Primary Elev. Recall	
1M008		RELAY	Alt Elev. Recall	
1M009		RELAY	Elev. Shunt trip	
1M010	SUPV.	MONITOR	Elev. Shunt power	
1M011		RELAY	Elev. Shunt 1F	
1M012	ALARM	PULL	Rear Exit 1F	
1M013	ALARM	PULL	Rear Stair Exit 1F	
1M014	ALARM	FLOW	2 <sup>ND</sup> FL. FLOW	
1M015	SUPV.	TAMPER	2 <sup>ND</sup> FL. TAMPER	
1M016	ALARM	PULL	Front Stair 2F	
1M017		RELAY	AC-2 Shutdown 2F	
1M018	ALARM	PULL	Rear Stair 2 <sup>ND</sup> FL.	
1M019	ALARM	PULL	Front Stair Exit 3F	

1M020	ALARM	FLOW	3 <sup>RD</sup> FL. FLOW	
1M021	SUPV.	TAMPER	3 <sup>RD</sup> FL. TAMPER	
1M022	ALARM	PULL	Rear Stair 3F	
1M023	ALARM	PULL	3 <sup>RD</sup> FL. MEZZ Stair	
1M024	ALARM	FLOW	3 <sup>RD</sup> /MEZZANINE FL. FLOW	
1M025	SUPV.	TAMPER	3 <sup>RD</sup> /MEZZANINE FL. TAMPER	
1M026		RELAY	RTU-1 Shutdown	
1M027	SUPV.	TAMPER	EMR/ PIT TAMPER 1F	
1M028		RELAY	Elev. Hat Light	
1M029		Control	FCPS Trigger 2 <sup>ND</sup> F	
1D001	ALARM	SMOKE- PHOTO	Security room	
1D002	ALARM	SMOKE- PHOTO	Elev. Lobby 1 <sup>ST</sup> FL.	
1D003	ALARM	SMOKE- PHOTO	Elev. Mach. 1 <sup>ST</sup> FL.	
1D004	ALARM	HEAT	Elev. Mach. 1 <sup>ST</sup> FL.	
1D005	ALARM	HEAT	Elev. Pit	
1D006	ALARM	SMOKE- PHOTO	Elec. Closet 1 <sup>ST</sup> FL. Front	
1D007	ALARM	SMOKE- PHOTO	Duct AC-1 SUP 1F	
1D008	ALARM	SMOKE- PHOTO	Duct AC-1 RET 1F	
1D009	ALARM	SMOKE- PHOTO	Janitor Closet 1F	
1D010	ALARM	SMOKE- PHOTO	Elev. Lobby 2 <sup>ND</sup> FL.	
1D011	ALARM	SMOKE- PHOTO	Above FACP 2 <sup>ND</sup> F. Elec.	
1D012	ALARM	SMOKE- PHOTO	Mech. Room 2 <sup>ND</sup> F.	
1D013	ALARM	SMOKE- PHOTO	Duct AC-2 SUP 2F	
1D014	ALARM	SMOKE- PHOTO	Duct AC-2 RET 2F	
1D015	ALARM	SMOKE- PHOTO	Elev. Lobby 3 <sup>RD</sup> FL.	
1D017	ALARM	SMOKE- PHOTO	Mech. Room 3 <sup>RD</sup> F.	
1D018	ALARM	SMOKE- PHOTO	Under Mezz. Stair 3F	

1D019	ALARM	SMOKE- PHOTO	Elev. Lobby 3 <sup>RD</sup> FL. Mezz	
1D020	ALARM	SMOKE- PHOTO	Duct RTU-1 RET ROOF	
1D021	ALARM	SMOKE- PHOTO	Duct RTU-1 SUP ROOF	
1D022	ALARM	SMOKE- PHOTO	Roof Access	
1D023	ALARM	SMOKE- PHOTO	Storage Rear 1F	
1D024	ALARM	SMOKE- PHOTO	Mech. Room 1F	
1D025	ALARM	SMOKE- PHOTO	3 <sup>RD</sup> F Lobby	
<b>ADDITIONAL COMMENTS</b>				
Central Station- Dynamark 1-855-493-9799 <b>ACCOUNT # 325-0079</b>			There are two Monitoring company that relay each other with this Panel. You can call out either one.  Kemco @ 301-327-5257 <b>ACCOUNT # 325-0079</b>	

**NOTE:** DEVICES RELATED TO ELEVATOR ARE NOT TESTED. THIS WILL PERFORM ALONG WITH THE ELEVATOR ANNUAL SAFETY INSPECTION.

Kemco account # 3251613 performs daily test signal and monitor 1 elevator.  
This is a cellular system (Bosch 465). updated 11/7/2024