

118 Q Street North East, DC

Fire Alarm EST Points List

SERIAL ADDRESS	DEVICE ADDRESS	DEVICE	TYPE	DESCRIPTION/LOCATION	PASS	FAIL	COMMENTS
4933233382	001	MONITOR	SUPV.	1 ST FLR WOMENS BATH. DUCT DETECTOR#1			
5269961826	002	MODULE	RELAY	ELEV. SHUNT TRIP, RELAY#2			
5269956655	003	MODULE	RELAY	ELEV. ALT. RECALL, RELAY#3			
5269956648	004	MODULE	RELAY	ELEV. PRI. RECALL, RELAY#4			
5269846710	005	MODULE	RELAY	ELEV. FIRE HAT, RELAY#5			
4956680149	006	MONITOR	SUPV.	1ST FL SPRINKLER 109A, TAMPER SWITCH#8			
4956680149	007	MONITOR	ALARM	1ST FL SPRINKLER 109A, WATER FLOW#7			
4933233399	008	MONITOR	TROUBLE	1 ST FLR WOMENS BATH. UNUSED CT2 PORT			
4933233269	009	MONITOR	SUPV.	NEED LOCATION			
4933233276	010	MONITOR	SUPV.	NEED LOCATION			
4886823463	011	PULL	ALARM	FRONT ENTRANCE, PULL STATION#11			
4886795159	012	PULL	ALARM	2 ND FLR STAIRWELL #2, PULL STATION#12			
4886777339	013	PULL	ALARM	2 ND FLR STAIRWELL #1, PULL STATION#13			
4886746717	014	PULL	ALARM	1 ST FLR STAIRWELL #2, PULL STATION#14			
4824754019	015	MONITOR	SUPV.	2 ND FLR WOMENS BATH. DUCT DETECTOR#15			
4824752992	016	MONITOR	SUPV.	1 ST FLR MENS BATH. DUCT DETECTOR#16			
4824752701	017	MONITOR	SUPV.	2 ND FLR MENS BATH. DUCT DETECTOR#17			
3987931978	018	SMOKE	ALARM	1 ST FLR ELEC.RM 115, SMOKE DETECTOR#18			

118 Q Street North East, DC

Fire Alarm EST Points List

3987931763	019	SMOKE	ALARM	2 ND FLR COMM. ROOM, SMOKE DETECTOR#19			
3913342120	020	SMOKE	ALARM	ELEVATOR TOP SHAFT, SMOKE DETECTOR#20			
3913340652	021	SMOKE	ALARM	ELEVATOR PIT, SMOKE DETECTOR#21			
3913327820	022	SMOKE	ALARM	2 ND FLR E.M.R., SMOKE DETECTOR#22			
3913322221	023	SMOKE	ALARM	1 ST FLR COMM. ROOM 111, SMOKE DETECTOR#23			
3913321972	024	SMOKE	ALARM	2 ND FLR ELEV. LOBBY, SMOKE DETECTOR#24			
3913304494	025	SMOKE	ALARM	1 ST FLR ELEV. LOBBY, SMOKE DETECTOR#25			
3908735708	026	SMOKE	ALARM	1 ST FLR SPRINKLER 109A, SMOKE DETECTOR#26			
3815671052	027	HEAT-ROR	ALARM	2 ND FLR E.M.R., HEAT DETECTOR#27			
3815656462	028	HEAT-ROR	ALARM	ELEV. TOP OF SHAFT, HEAT DETECTOR#28			
4822471222	029	MONITOR	SUPV.	EMR ROOM 211, TAMPER #29			
4821955648	029	MONITOR	SUPV.	ELEVATOR SHAFT, TAMPER #30			

NOTE: UPON ARRIVAL TO THE **BACK PARKING LOT CALL 202-636-2775** TO REMOTELY OPEN THE GATE