

● Means that its not on 2023 Points List

Total Devices - 626
Devices Not Verified - 31
Devices Verified in Field- 585

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:17 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)










| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--|--|--------------------------------|---|---------------------------------|
| ✓ L1_Z3_DS_AHU9_RETURN_1 SUPERVISORY | BASEMENT ZONE 3 RF-9 RETURN DUCT | SD Relay Base or remote LED |  01020001 | 3947960734 |
| ✓ L1_Z3_DS_AHU13_RETURN_2 SUPERVISORY | BASEMENT ZONE 3 AHU-13 RETURN DUCT | SD Relay Base or remote LED |  01020002 | 3947961892 |
| ✓ L1_Z3_DS_AHU13_SUPPLY_3 SUPERVISORY | BASEMENT ZONE 3 AHU-13 SUPPLY DUCT | SD Relay Base or remote LED |  01020003 | 3947963742 |
| ✓ L1_Z3_DS_AHU9_SUPPLY_4 SUPERVISORY | BASEMENT ZONE 3 AHU-9 SUPPLY DUCT | SD Relay Base or remote LED |  01020004 | 3947961922 |
| ✓ L1_Z3_DS_AHU8_RETURN_5 SUPERVISORY | BASEMENT ZONE 3 AHU-8 RETURN DUCT | SD Relay Base or remote LED |  01020005 | 3947963667 |
| ✓ L1_Z3_DS_AHU8_SUPPLY_6 SUPERVISORY | BASEMENT ZONE 3 AHU-8 SUPPLY DUCT | SD Relay Base or remote LED |  01020006 | 3947963735 |
| ✓ L1_Z3_ELSMK_1_7 SMOKEVFY | BASEMENT ZONE 3 REAR ELEV 1 LOBBY SMOKE | PS Standard Base |  01020007 | 3947570391 |
| ✓ L1_Z2_SMK_8 SMOKEVFY | BASEMENT ZONE 2 001 LOBBY SMOKE | PS Standard Base |  01020008 | 3947570438 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:17 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---|--|--------------------------------|---|------------|
| ✓ L1_Z2_SMK_9 SMOKEVFY | BASEMENT ZONE 2 001 LOBBY SMOKE | PS Standard Base |  01020009 | 3947376726 |
| ✓ L1_Z2_DS_AHU10_RETURN_10 SUPERVISORY | BASEMENT ZONE 2 AHU-10 RETURN DUCT | SD Relay Base or remote LED |  01020010 | 3947961861 |
| ✓ L1_Z2_DS_AHU10_SUPPLY_11 SUPERVISORY | BASEMENT ZONE 2 AHU-10 SUPPLY DUCT | SD Relay Base or remote LED |  01020011 | 3947961915 |
| ✓ L1_Z2_SMK_12 SMOKEVFY | BASEMENT ZONE 2 001 LOBBY SMOKE | PS Standard Base |  01020012 | 3936158586 |
| ✓ L1_Z2_ELSMK_1_13 SMOKEVFY | BASEMENT ZONE 2 ELEV 1-4 LOBBY SMOKE | PS Standard Base |  01020013 | 3947575518 |
| ✓ L1_Z3_ESHT_1_14 HEAT | BASEMENT ZONE 2 ELEVATOR 1 PIT HEAT | HRS Standard Base |  01020014 | 3805738499 |
| ✓ L1_Z3_ESHT_3_15 HEAT | BASEMENT ZONE 3 ELEVATOR 3 PIT HEAT | HRS Standard Base |  01020015 | 3805731018 |
| ✓ L1_Z3_EMRHT_1_16 HEAT | BASEMENT ZONE 3 ELEV 1-4 MACH RM HEAT | HRS Standard Base |  01020016 | 3807352297 |
| ✓ L1_Z3_EMRHT_1_17 HEAT | BASEMENT ZONE 3 ELEV 1-4 MACH RM HEAT | HRS Standard Base |  01020017 | 3807352471 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:17 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00






| | | | | |
|--------------------------------|---|----------------------|---|------------|
| ✓ L1_Z3_EMRSK_1_18 SMOKEVFY | BASEMENT ZONE 3 ELEV MACHINE RM SMOKE | PS Standard Base |  01020018 | 3947565748 |
| ✓ L1_Z3_EMRHT_1_19 HEAT | BASEMENT ZONE 3 ELEV 1-4 MACH RM HEAT | HRS Standard Base |  01020019 | 3807348320 |
| ✓ L1_Z3_SMK_20 SMOKEVFY | BASEMENT ZONE 3 RECYCLE STORAGE SMOKE | PS Standard Base |  01020020 | 3947569470 |
| ✓ L1_Z3_SMK_21 SMOKEVFY | BASEMENT ZONE 3 TRASH STORAGE SMOKE | PS Standard Base |  01020021 | 3947565410 |
| ✓ L1_Z3_ESHT_4_22 HEAT | BASEMENT ZONE 3 ELEVATOR 4 PIT HEAT | HRS Standard Base |  01020022 | 3805738833 |
| ✓ LOOP1_ISO_23 ISOLATOR | DATA LOOP 1A SUPPLY ISOLATION MODULE | IM Isolator Base |  01020023 | 3691757192 |
| ✓ LOOP1_ISO_24 ISOLATOR | DATA LOOP 1A RETURN ISOLATION MODULE | IM Isolator Base |  01020024 | 3691757642 |
| ✓ L1_Z3_SMK_25 SMOKEVFY | BASEMENT ZONE 3 SMK TUNNEL DOOR HOLDER | PS Standard Base |  01020025 | 3932151758 |
| ✓ LOOP1_ISO_33 ISOLATOR | BASEMENT ZN 3 SLC 1B ISOLATION MODULE | IM Isolator Base |  01020033 | 3691757246 |

Signature Detectors/Modules Barcode Worksheet



2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--------------------------------|--|----------------------|---|------------|
| ✓ LOOP1_IISO_34 ISOLATOR | BASEMENT ZN 3 SLC 1B ISOLATION MODULE | IM Isolator Base |  01020034 | 3691757178 |
| ✓ L1_Z2_EMRHT_1_53 HEAT | BASEMENT ZONE 2 ELEV 1-4 MECH RM HEAT | HRS Standard Base |  01020053 | 3807348887 |
| ✓ L1_Z1_SMK_54 SMOKEVFY | BASEMENT ZONE 1 044 SERVICE TUNNEL SMOKE | PS Standard Base |  01020054 | 3947568657 |
| ✓ L1_Z3_SMK_55 SMOKEVFY | BASEMENT ZONE 3 042A FUEL TANK ROOM SMOKE | PS Standard Base |  01020055 | 3947566042 |
| ✓ L1_Z1_SMK_56 SMOKEVFY | BASEMENT ZONE 1 045 SERVICE TUNNEL SMOKE | PS Standard Base |  01020056 | 3947374388 |

Modules (Loop 1)


| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|-----------------------------------|---|--|---|---------------------------------|
| ✓ L1_Z3_TS_126 TAMPER | BASEMENT ZONE 3 ELEV 1-4 MACH RM TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01020126 | 4947917568 |
| ✓ L1_Z3_EFS_1_127 WATERFLOW | BASEMENT ZONE 3 ELEV 1-4 MACH RM WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01020127 | 4947917575 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | |
|---|---|--|--|---|------------|
| ✓ | L1_Z3_EFS_1_128 WATERFLOW | BASEMENT ZONE 3 ELEV 1-4 SHAFT WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01020128 | 4947916868 |
| ✓ | L1_Z3_TS_129 TAMPER | BASEMENT ZONE 3 1-4 SHAFT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01020129 | 4947916875 |
| ✓ | L1_Z3_FS_130 WATERFLOW | BASEMENT ZONE 3 NORTH WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01020130 | 4947917223 |
| ✓ | L1_Z3_TS_131 TAMPER | BASEMENT ZONE 3 NORTH VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01020131 | 4947917230 |
| ✓ | L1_Z3_TS_132 TAMPER | BASEMENT ZONE 3 NORTH ENTRY PAVILION TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01020132 | 4947915601 |
| ✓ | L1_Z3_FS_133 WATERFLOW | BASEMENT ZONE 3 NORTH ENTRY PAVILION FLOW | CT2 (1) Alarm - NO latching (Class B) |  01020133 | 4947915618 |
| ✓ | AHU13_SUPPLY_AUTO MONITOR | BASEMENT ZONE 3 AHU13 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020134 | 4947916844 |
| ✓ | AHU13_RETURN_AUTO MONITOR | BASEMENT ZONE 13 RETURN IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020135 | 4947916851 |
| ✓ | AHU13_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 3 RF-13 AHU-13 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020136 | 5282854655 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00




| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | DOOR_RELEASE_137 NONSUPERVISEDOUTPUT | ● | BASEMENT TUNNEL DOOR HOLDER | CR (8) Signal - dry contact output |  01020137 | 5211736038 |
| ✓ | MUSEUM_ALM_138 SUPERVISORY | ● | NATIONAL LAW ENF MUSEUM ALARM | CT1 (3) Active - NO nonlatching (Class B) |  01020138 | 4814192500 |
| ✓ | L1_Z3_COURT_ALM_139 NONSUPERVISEDOUTPUT | ● | COURTHOUSE ALARM TO NLEM PANEL | CR (8) Signal - dry contact output |  01020139 | 5211707991 |
| ✓ | AHU9_SUPPLY_AUTO MONITOR | | BASEMENT ZONE 3 AHU-9 IN AUTO | CT1 (3) Active - NO nonlatching (Class B) |  01020140 | 4839734723 |
| ✓ | AHU9_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 AHU-9 ON RELAY | CR (8) Signal - dry contact output |  01020142 | 5282834435 |
| ✓ | AHU9_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 AHU-9 SUPPLY SHUTDOWN | CR (8) Signal - dry contact output |  01020143 | 5282833988 |
| ✓ | AHU8_SUPPLY_AUTO MONITOR | | BASEMENT ZONE 3 AHU-8 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020144 | 4947917162 |
| ✓ | AHU8_RETURN_AUTO MONITOR | | BASEMENT ZONE 3 AHU-8 RETURN IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020145 | 4947917179 |
| ✓ | AHU8_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 AHU-8 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  01020146 | 5282854525 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00


| | | | | | | |
|---|--|---|---|--|---|------------|
| ✓ | AHU8_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 AHU-8 SHUTDOWN | CR (8) Signal - dry contact output |  01020148 | 5282834534 |
| ✓ | AHU2_L1SMOKE_DAMPER MONITOR | | BASEMENT ZONE 2 ATRIUM SMOKE DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01020150 | 4841698297 |
| ✓ | AHU2_L1SMOKE_DMPR_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 2 ATRIUM DAMPER RELAY | CR (8) Signal - dry contact output |  01020151 | 5286675218 |
| ✓ | AHU10_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 2 AHU-10 SUPPLY SHUTDWN | CR (8) Signal - dry contact output |  01020153 | 5286676093 |
| ✓ | L1_Z2_TS_154 TAMPER | | BASEMENT ZONE 2 036 MECH RM TAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01020154 | 4839735690 |
| ✓ | L1_Z1_PULL_156 PULL | | BASEMENT ZONE 1 STAIR H PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01020156 | 4891277749 |
| ✓ | L1_Z1_EF_157 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 1 EF-18 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020157 | 5286675805 |
| ✓ | L1_Z1_PULL_158 PULL | | BASEMENT ZONE 1 MECH CORRIDOR PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01020158 | 4891346209 |
| ✓ | MUSEUM_TRB_159 SUPERVISORY | ● | NATIONAL LAW ENF MUSEUM TROUBLE | CT2 (3) Active - NO nonlatching (Class B) |  01020159 | 4913249686 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|---|---|---|--|---|------------|
| ✓ | MUSEUM_SUP_160 SUPERVISORY | ● | NATIONAL LAW ENF MUSEUM SUPERVISORY | CT2 (3) Active - NO nonlatching (Class B) |  01020160 | 4913249693 |
| ✓ | PRIMARY_RECALL_1 NONSUPERVISEDOUTPUT | ● | ELEVATOR 1 THRU 4 PRIMARY RECALL | CR (8) Signal - dry contact output |  01020161 | 5282855164 |
| ✓ | ALTERNATE_RECALL_1 NONSUPERVISEDOUTPUT | ● | ELEVATOR 1 THRU 4 ALTERNATE RECALL | CR (8) Signal - dry contact output |  01020162 | 5282839249 |
| ✓ | EARTHQUAKE_MODE_1 NONSUPERVISEDOUTPUT | ● | ELEVATOR 1 THRU 4 EARTHQUAKE MODE | CR (8) Signal - dry contact output |  01020163 | 5282834107 |
| ✓ | FIREMANS_HAT_1 NONSUPERVISEDOUTPUT | ● | ELEVATOR 1 THRU 4 FIREMANS HAT | CR (8) Signal - dry contact output |  01020164 | 5282835265 |
| ✓ | OAF1_OFF_167 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 OAF-1 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020167 | 5282834633 |
| ✓ | L1_Z3_EF_168 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 EF-19 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020168 | 5282834060 |
| ✓ | OAF2_OFF_169 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 OAF-2 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020169 | 5286671531 |
| ✓ | L1_Z3_PULL_170 PULL | | BASEMENT ZONE 3 RECEIVING CORR PULL | 278 (1) Alarm - NO latching (Class B) |  01020170 | 4891307057 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | |
|--|---|--|--|---|------------|
| ✓ L1_Z3_DPFS_171 WATERFLOW | | BASEMENT ZONE 3 DRY SYSTEM WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01020171 | 4947917100 |
| ✓ L1_Z3_TS_172 TAMPER | | BASEMENT ZONE 3 DRY SYSTEM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01020172 | 4947917117 |
| ✓ L1_Z3_HILO_173 SUPERVISORY | | BASEMENT ZONE 3 DRY SYSTEM HI/LO AIR | CT1 (3) Active - NO nonlatching (Class B) |  01020173 | 4839735355 |
| ✓ L1_Z3_EF_174 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 EF-17 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020174 | 5282854037 |
| ✓ L1_Z3_EF_175 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 EF-14 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01020175 | 5282834381 |
| ✓ L1_Z3_PULL_176 PULL | | BASEMENT ZONE 3 LOADING DOCK PULL | 278 (1) Alarm - NO latching (Class B) |  01020176 | 4891328342 |
| ✓ AHU10_SUPPLY_ON MONITOR | | BASEMENT ZONE 2 AHU10 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01020180 | 4839729927 |
| ✓ AHU10_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 2 AHU10 OUTSIDE AIR DAMPER | CR (8) Signal - dry contact output |  01020181 | 5286675744 |
| ✓ AHU10_OA_DAMPER MONITOR | | BASEMENT ZONE 2 AHU10 OUTSIDE AIR DMPR OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01020182 | 4839735195 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|--|---|--|--|---|------------|
| ✓ AHU10_RECIRC_DAMPER MONITOR | | BASEMENT ZONE 2 AHU10 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  01020183 | 4841699102 |
| ✓ AHU10_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 2 AHU10 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  01020184 | 5286675799 |
| ✓ AHU10_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 2 AHU10 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  01020185 | 5286676130 |
| ✓ AHU10_SUPPLY_AUTO MONITOR | | BASEMENT ZONE 2 AHU10 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020187 | 4947917148 |
| ✓ AHU10_RETURN_AUTO MONITOR | | BASEMENT ZONE 2 AHU10 RETURN IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01020188 | 4947917155 |
| ✓ AHU13_SUPPLY_ON MONITOR | | BASEMENT ZONE 2 AHU13 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01020189 | 4839733313 |
| ✓ AHU8_SUPPLY_ON MONITOR | | ATTIC ZONE 3 AHU9 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01020190 | 4839729668 |
| ✓ AHU9_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 3 AHU-9 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  01020193 | 5286675966 |
| ✓ AHU9_RECIRC_DAMPER MONITOR | | BASEMENT ZONE 3 AHU-9 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  01020194 | 4841699027 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | |
|---|--|--|---|------------|
| ✓ AHU9_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT ● | BASEMENT ZONE 3 AHU-9 OUTSIDE AIR DAMPER | CR (8) Signal - dry contact output |  01020195 | 5282835104 |
| ✓ AHU9_OA_DAMPER MONITOR | BASEMENT ZONE 3 AHU-9 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01020196 | 4839735874 |
| ✓ AHU9_SUPPLY_ON MONITOR | BASEMENT ZONE 3 AHU-9 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01020197 | 4839733283 |
| ✓ HILO_AIR SUPERVISORY | BASEMENT ZONE 2 DRY SYSTEM HI/LO AIR | CT1 (3) Active - NO nonlatching (Class B) |  01020200 | 4839729453 |
| ✓ AHU9_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT ● | BASEMENT ZONE 3 AHU9 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  01020201 | 5282835012 |
| ✓ AHU13_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT ● | BASEMENT ZONE 3 AHU13 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  01020202 | 5282854020 |
| ✓ AHU8_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT ● | BASEMENT ZONE 3 AHU-8 SMOKE EVAC | CR (8) Signal - dry contact output |  01020203 | 5286680052 |
| ✓ AHU10_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT ● | BASEMENT ZONE 3 AHU10 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  01020204 | 5286675898 |
| ✓ PRIMARY_RECALL_4 NONSUPERVISEDOUTPUT ● | ELEVATOR 4 PRIORITY RECALL RELAY | CR (8) Signal - dry contact output |  01020228 | 5282854877 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00




| | | | | | | |
|---|---|---|---|--|---|------------|
| ✓ | ALTERNATE_RECALL_4 NONSUPERVISEDOUTPUT | ● | ELEVATOR 4 ALTERNATE RECALL RELY | CR (8) Signal - dry contact output |  01020229 | 5282854853 |
| ✓ | EARTHQUAKE_MODE_4 NONSUPERVISEDOUTPUT | ● | ELEVATOR 4 EARTHQUAKE MODE RELAY | CR (8) Signal - dry contact output |  01020230 | 5282834176 |
| ✓ | FIREMANS_HAT_4 NONSUPERVISEDOUTPUT | ● | ELEVATOR 4 FIREMANS HAT RELAY | CR (8) Signal - dry contact output |  01020231 | 5282854860 |
| ✓ | PRIMARY_RECALL_3 NONSUPERVISEDOUTPUT | ● | ELEVATOR 3 PRIROITY RECALL RELAY | CR (8) Signal - dry contact output |  01020232 | 5282854969 |
| ✓ | ALTERNATE_RECALL_3 NONSUPERVISEDOUTPUT | ● | ELEVATOR 3 ALTERNATE RECALL RELY | CR (8) Signal - dry contact output |  01020233 | 5282834244 |
| ✓ | EARTHQUAKE_MODE_3 NONSUPERVISEDOUTPUT | ● | ELEVATOR 3 EARTHQUAKE MODE RELAY | CR (8) Signal - dry contact output |  01020234 | 5282834497 |
| ✓ | FIREMANS_HAT_3 NONSUPERVISEDOUTPUT | ● | ELEVATOR 3 FIREMANS HAT RELAY | CR (8) Signal - dry contact output |  01020235 | 5282834787 |
| ✓ | L1_Z3_PULL_236 PULL | | BASEMENT ZONE 3 042 MECHANICAL ROOM PULL | 278 (1) Alarm - NO latching (Class B) |  01020236 | 4891358639 |
| ✓ | DOOR_RELEASE_240 NONSUPERVISEDOUTPUT | | BASEMENT SECURITY 047 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01020240 | 5286675614 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1A

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---|--|---------------------------------------|---|------------|
| ✓ NORTH_ATRIUM_DOORELEASE NONSUPERVISEDOUTPUT | NORTH ATRIUM DOOR RELEASE RELAY | CR (8) Signal - dry contact output |  01020247 | 5288935143 |
| ✓ AHU13_ON_248 NONSUPERVISEDOUTPUT | BASEMENT ZONE 3 AHU13 RETURN ON RELAY | CR (8) Signal - dry contact output |  01020248 | 5282838310 |
| ✓ AHU8_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 AHU8 OA DAMPER OPEN | CR (8) Signal - dry contact output |  01020249 | 5286676307 |

Modules (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--------------------------------|--------------------------------------|--|---|---------------------------------|
| ✓ AHU8_OA_DAMPER MONITOR | ATTIC ZONE 3 AHU-8 OA DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01020250 | 4841698778 |



Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|-------------------------------|---|----------------------|---|---------------------------------|
| ✓ L2_Z3_SMK_1 SMOKEVFY | 1ST FLOOR ZONE 3 FIRE CONTROL RM SMOKE | PS Standard Base |  01030001 | 3947571770 |
| ✓ L2_Z2_SMK_2 SMOKEVFY | 1ST FLOOR ZONE 2 161 NORTH ENTRY SMOKE | PS Standard Base |  01030002 | 3947572265 |
| ✓ LOOP2_ISO_3 ISOLATOR | DATA LOOP 2 ISOLATION MODULE | IM Isolator Base |  01030003 | 3691011638 |
| ✓ LOOP2_ISO_4 ISOLATOR | DATA LOOP 2 ISOLATION MODULE | IM Isolator Base |  01030004 | 3691014639 |
| ✓ LOOP2_ISO_5 ISOLATOR | DATA LOOP 2 ISOLATION MODULE | IM Isolator Base |  01030005 | 3691011645 |
| ✓ L2_Z2_SMK_6 SMOKEVFY | 1ST FLOOR ZONE 2 160 NORTH ENTRY SMOKE | PS Standard Base |  01030006 | 3947570032 |
| ✓ L2_Z1_SMK_EF1_7 SMOKEVFY | 1ST FLOOR ZONE 1 112 ELECTRIC ROOM SMOKE | PS Standard Base |  01030007 | 3947569289 |
| ✓ L2_Z1_SMK_EF2_8 SMOKEVFY | 1ST FLOOR ZONE 1 114 STAFF TOILET SMOKE | PS Standard Base |  01030008 | 3947570131 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|------------------------------|--|---------------------|---|------------|
| ✓ | L2_Z1_SMK_9 SMOKEVFY | 1ST FLOOR ZONE 1 110 TELE/LAN ROOM SMOKE | PS Standard Base |  01030009 | 3947577956 |
| ✓ | L2_Z1_SMK_10 SMOKEVFY | 1ST FLOOR ZONE 1 158A WEST CORRIDOR SMOKE | PS Standard Base |  01030010 | 3947566080 |
| ✓ | L2_Z1_ELSMK_5_11 SMOKEVFY | 1ST FLOOR ZONE 1 ELEVATOR 5 LOBBY SMK | PS Standard Base |  01030011 | 3947577536 |
| ✓ | L2_Z2_SMK_12 SMOKEVFY | 1ST FLOOR ZONE 2 160 NORTH ENTRY SMOKE | PS Standard Base |  01030012 | 3947570353 |
| ✓ | L2_Z2_ELSMK_1_13 SMOKEVFY | 1ST FLOOR ZONE 2 ELEV 1-4 LOBBY SMOKE | PS Standard Base |  01030013 | 3974024447 |
| ✓ | L2_Z3_SMK_EF6_14 SMOKEVFY | 1ST FLOOR ZONE 3 120 WOMENS TOILET SMK | PS Standard Base |  01030014 | 3947570056 |
| ✓ | L2_Z3_SMK_EF9_15 SMOKEVFY | 1ST FLOOR ZONE 3 124 ELECTRIC RM SMOKE | PS Standard Base |  01030015 | 3947569746 |
| ✓ | L2_Z3_SMK_16 SMOKEVFY | 1ST FLOOR ZONE 3 125 TELE/LAN RM SMOKE | PS Standard Base |  01030016 | 3947376702 |
| ✓ | L2_Z3_SMK_17 SMOKEVFY | 1ST FLOOR ZONE 3 162A EAST CORR SMOKE | PS Standard Base |  01030017 | 3947577420 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:18 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---------------------------------|--|---------------------|---|------------|
| ✓ L2_Z3_ELSMK_6_18 SMOKEVFY | 1ST FLOOR ZONE 3 ELEVATOR 6 LOBBY SMK | PS Standard Base |  01030018 | 3947569364 |
| ✓ L3_Z1_SMK_EF1_19 SMOKEVFY | 2ND FLOOR ZONE 1 206 ELECTRIC ROOM SMOKE | PS Standard Base |  01030019 | 3947577208 |
| ✓ L3_Z1_SMK_20 SMOKEVFY | 2ND FLOOR ZONE 1 230 WEST CORRIDOR SMOKE | PS Standard Base |  01030020 | 3947571336 |
| ✓ L3_Z1_SMK_21 SMOKEVFY | 2ND FLOOR ZONE 1 205 TELE/LAN ROOM SMOKE | PS Standard Base |  01030021 | 3947572333 |
| ✓ L3_Z1_SMK_22 SMOKEVFY | 2ND FLOOR ZONE 1 230B WEST CORRIDOR B SMOKE | PS Standard Base |  01030022 | 3947577598 |
| ✓ L3_Z1_ELSMK_5_23 SMOKEVFY | 2ND FLOOR ZONE 1 ELEVATOR 5 LOBBY SMK | PS Standard Base |  01030023 | 3947570650 |
| ✓ L3_Z1_SMK_EF10_25 SMOKEVFY | 2ND FLOOR ZONE 1 JUDGES BATH ROOM | PS Standard Base |  01030025 | 3947570063 |
| ✓ L3_Z1_SMK_EF3_26 SMOKEVFY | 2ND FLOOR ZONE 1 208D KITCHEN SMOKE | PS Standard Base |  01030026 | 3947572340 |
| ✓ L3_Z1_SMK_EF2_27 SMOKEVFY | 2ND FLOOR ZONE 1 207 STAFF TOILET SMOKE | PS Standard Base |  01030027 | 3947571701 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--------------------------------|---|---------------------|---|------------|
| ✓ L3_Z1_SMK_EF3_28 SMOKEVFY | 2ND FLOOR ZONE 1 209A KITCHENETTE SMOKE | PS Standard Base |  01030028 | 3947579677 |
| ✓ L3_Z1_SMK_29 SMOKEVFY | 2ND FLOOR ZONE 1 209 WORK AREA SMOKE | PS Standard Base |  01030029 | 3947577284 |
| ✓ L3_Z2_SMK_30 SMOKEVFY | 2ND FLOOR ZONE 2 CENTER STAIR HALL SMK | PS Standard Base |  01030030 | 3947574993 |
| ✓ L3_Z2_SMK_31 SMOKEVFY | 2ND FLOOR ZONE 2 233B EXHIBIT HALL SMOKE | PS Standard Base |  01030031 | 3947567186 |
| ✓ L3_Z2_SMK_32 SMOKEVFY | 2ND FLOOR ZONE 2 233B EXHIBIT HALL SMOKE | PS Standard Base |  01030032 | 3947367090 |
| ✓ L3_Z2_SMK_33 SMOKEVFY | 2ND FLOOR ZONE 2 233B EXHIBIT HALL SMOKE | PS Standard Base |  01030033 | 3947571923 |
| ✓ L3_Z2_ELSMK_1_34 SMOKEVFY | 2ND FLOOR ZONE 2 ELEV 1-4 LOBBY SMOKE | PS Standard Base |  01030034 | 3947565328 |
| ✓ L3_Z3_SMK_EF9_35 SMOKEVFY | 2ND FLOOR ZONE 3 221 ELECTRIC ROOM SMOKE | PS Standard Base |  01030035 | 3947577581 |
| ✓ L3_Z3_SMK_EF8_36 SMOKEVFY | 2ND FLOOR ZONE 3 219 T/S/L ROOM SMOKE | PS Standard Base |  01030036 | 3947566882 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|------------------------------|--|---------------------|---|------------|
| ✓ | L3_Z3_SMK_EF7_37 SMOKEVFY | 2ND FLOOR ZONE 3 220D T/S/L ROOM SMOKE | PS Standard Base |  01030037 | 3947574078 |
| ✓ | L3_Z3_SMK_38 SMOKEVFY | 2ND FLOOR ZONE 3 235 EAST CORRIDOR SMOKE | PS Standard Base |  01030038 | 3947578960 |
| ✓ | L3_Z3_SMK_39 SMOKEVFY | 2ND FLOOR ZONE 3 222 TELE/LAN ROOM SMOKE | PS Standard Base |  01030039 | 3947579523 |
| ✓ | L3_Z3_SMK_45 SMOKEVFY | 2ND FLOOR ZONE 3 235A EAST CORRIDOR A SMOKE | PS Standard Base |  01030045 | 3947579479 |
| ✓ | L3_Z3_ELSMK_6_46 SMOKEVFY | 2ND FLOOR ZONE 3 225B ELEVATOR 6 LOBBY SMK | PS Standard Base |  01030046 | 3947566127 |
| ✓ | L3_Z3_ELSMK_6_47 SMOKEVFY | 2ND FLOOR ZONE 3 ELEVATOR 6 LOBBY SMK | PS Standard Base |  01030047 | 3947571589 |
| ✓ | L3_Z3_SMK_48 SMOKEVFY | 2ND FLOOR ZONE 3 COURTROOM #2 SMOKE | PS Standard Base |  01030048 | 3947571145 |
| ✓ | L3_Z3_SMK_49 SMOKEVFY | 2ND FLOOR ZONE 3 COURTROOM #2 SMOKE | PS Standard Base |  01030049 | 3947577987 |
| ✓ | L3_Z3_SMK_50 SMOKEVFY | 2ND FLOOR ZONE 3 COURTROOM #2 SMOKE | PS Standard Base |  01030050 | 3947571725 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00




| | | | | |
|---------------------------------|---|---------------------|---|------------|
| ✓ L3_Z3_SMK_51 SMOKEVFY | 2ND FLOOR ZONE 3 COURTROOM #2 SMOKE | PS Standard Base |  01030051 | 3947573415 |
| ✓ L3_Z3_SMK_EF12_52 SMOKEVFY | 2ND FLOOR ZONE 3 217 WOMENS TOILET SMOKE | PS Standard Base |  01030052 | 3947571763 |
| ✓ L2_Z3_SMK_EF8_53 SMOKEVFY | 1ST FLOOR ZONE 3 122 STAFF TOILET SMK | PS Standard Base |  01030053 | 3947572258 |
| ✓ LOOP2_ISO_54 ISOLATOR | 1ST FLOOR ZN2 SLC 2 ISOLATION MODULE | IM Isolator Base |  01030054 | 3691001561 |
| ✓ LOOP2_ISO_55 ISOLATOR | 2ND FLOOR ZN3 SLC 2 ISOLATION MODULE | IM Isolator Base |  01030055 | 3691757420 |
| ✓ L3_Z1_SMK_EF11_56 SMOKEVFY | 2ND FLOOR ZONE 1 210 MENS TOILET SMOKE | PS Standard Base |  01030056 | 3947570018 |
| ✓ LOOP2_ISO_60 ISOLATOR | 1ST FLOOR ZN1 SLC 2 ISOLATION MODULE | IM Isolator Base |  01030060 | 3691016435 |
| ✓ L3_Z3_SMK_EF6_62 SMOKEVFY | 2ND FLOOR ZONE 3 218C T/S/L ROOM SMOKE | PS Standard Base |  01030062 | 3947577543 |
| ✓ L3_Z1_SMK_EF3_63 SMOKEVFY | 2ND FLOOR ZONE 1 JUDGES BATH ROOM | PS Standard Base |  01030063 | 3947577437 |

Signature Detectors/Modules Barcode Worksheet





2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---------------------------------|---|---------------------|---|------------|
| ✓ L3_Z3_SMK_EF13_64 SMOKEVFY | 2ND FLOOR ZONE 3 225 JUDGES TOILET SMOKE | PS Standard Base |  01030064 | 3947576638 |
| ✓ L2_Z1_SMK_EF6_65 SMOKEVFY | 1ST FLOOR ZONE 1 119 MENS TOILET SMOKE | PS Standard Base |  01030065 | 3947572173 |
| ✓ L2_Z2_SMK_5 SMOKEVFY | 1ST FLOOR ZONE 2 161 NORTH ENTRY SMOKE | PS Standard Base |  01030066 | 3947567933 |

Modules (Loop 1)










| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--|--|--|---|---------------------------------|
| ✓ L3_Z2_BSMK_232 SMOKE | 2ND FLOOR ZONE 2 BEAM SMOKE DETECTOR | CT2 (1) Alarm - NO latching (Class B) |  01030126 | 4947915922 |
| ✓ L3_Z2_BEAM_TROUBLE_233 SUPERVISORY | 2ND FLOOR ZONE 2 BEAM SMOKE DETECTOR TRBL | CT2 (3) Active - NO nonlatching (Class B) |  01030127 | 4947915939 |
| ✓ L2_Z2_PULL_128 PULL | 1ST FLOOR ZONE 2 NORTH ENTRANCE PULL | 278 (1) Alarm - NO latching (Class B) |  01030128 | 4894041613 |
| ✓ AHU2_L2SMOKE_DMPP_RELAY NONSUPERVISEDOUTPUT | 1ST FLR ZN 2 AHU2 ATRIUM DAMPER RELAY | CR (8) Signal - dry contact output |  01030129 | 5286678615 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|--|---|---|--|---|------------|
| ✓ | AHU2_L2SMOKE_DAMPER MONITOR | | 1ST FLOOR ZONE 2 ATRIUM DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01030130 | 4836376810 |
| ✓ | DOORELEASE_1 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZN 2 NORTH ENTRANCE DOOR RELEASE | CR (8) Signal - dry contact output |  01030131 | 5286675683 |
| ✓ | L2_Z1_DAMPER_EF2_133 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 1 114 STAFF TOILET DAMPER | CR (8) Signal - dry contact output |  01030133 | 5286678554 |
| ✓ | L2_Z1_DAMPER_EF1_134 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 1 112 ELECTRIC ROOM DAMPER | CR (8) Signal - dry contact output |  01030134 | 5286677922 |
| ✓ | DOORELEASE_2 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZN 2 NORTH ENTRANCE DOOR RELEASE | CR (8) Signal - dry contact output |  01030135 | 5286675843 |
| ✓ | AHU1_L2SMOKE_DMPP_RELAY NONSUPERVISEDOUTPUT | ● | 1ST FLR ZN 1 RELAY STAIR D DAMPER | CR (8) Signal - dry contact output |  01030136 | 5286678462 |
| ✓ | AHU1_L2SMOKE_DAMPER MONITOR | | 1ST FLOOR ZONE 1 STAIR D DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01030137 | 4836377176 |
| ✓ | L2_Z1_PULL_138 PULL | | 1ST FLOOR ZONE 1 159 VESTIBULE PULL | 278 (1) Alarm - NO latching (Class B) |  01030138 | 4891326348 |
| ✓ | DOORELEASE_3 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZN 2 NORTH ENTRANCE DOOR RELEASE | CR (8) Signal - dry contact output |  01030139 | 5286676161 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00



| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | L2_Z1_PULL_140 PULL | | 1ST FLOOR ZONE 1 157 VESTIBULE PULL | 278 (1) Alarm - NO latching (Class B) |  01030140 | 4891277305 |
| ✓ | L2_Z3_DAMPER_EF6_141 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 3 WOMENS TOILET DAMPER | CR (8) Signal - dry contact output |  01030141 | 5282835142 |
| ✓ | DOORELEASE_4 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZN 2 ENTRANCE DOOR RELEASE | CR (8) Signal - dry contact output |  01030142 | 5286675911 |
| ✓ | L2_Z3_DAMPER_EF8_143 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 3 STAFF TOILET DAMPER | CR (8) Signal - dry contact output |  01030143 | 5282835005 |
| ✓ | L2_Z3_DAMPER_EF9_145 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 3 ELECTRICAL RM DAMPER | CR (8) Signal - dry contact output |  01030145 | 5282834596 |
| ✓ | L2_Z2_PULL_146 PULL | | 1ST FLOOR ZONE 2 NORTH ENTRANCE PULL | 278 (1) Alarm - NO latching (Class B) |  01030146 | 4894040548 |
| ✓ | AHU3_L2SMOKE_DMPP_RELAY NONSUPERVISEDOUTPUT | ● | 1ST FLR ZN 3 AHU-3 STAIR E DAMPER RELAY | CR (8) Signal - dry contact output |  01030147 | 5286678936 |
| ✓ | AHU3_L2SMOKE_DAMPER MONITOR | ● | 1ST FLR ZN 3 AHU-3 STAIR E DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01030148 | 4836377671 |
| ✓ | L2_Z3_PULL_149 PULL | | 1ST FLOOR ZONE 3 163 VESTIBULE PULL | 278 (1) Alarm - NO latching (Class B) |  01030149 | 4891277787 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00







| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | MUSHROOM_SWITCH SUPERVISORY | ● | MAIN AHU SHUTDOWN SWITCH ACTIVATED | CT1 (4) Active - NO latching (Class B) |  01030150 | 4840339122 |
| ✓ | L2_Z3_PULL_151 PULL | | 1ST FLOOR ZONE 3 162C CORR EAST PULL | 278 (1) Alarm - NO latching (Class B) |  01030151 | 4891325846 |
| ✓ | L3_Z1_DAMPER_EF1_153 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 206 ELECTRIC ROOM DAMPER | CR (8) Signal - dry contact output |  01030153 | 5286675201 |
| ✓ | L3_Z1_PULL_154 PULL | | 2ND FLOOR ZONE 1 STAIR M PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01030154 | 4891259714 |
| ✓ | L3_Z1_FS_155 WATERFLOW | | 2ND FLOOR ZONE 1 STAIR F WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01030155 | 4947918022 |
| ✓ | L3_Z1_TS_156 TAMPER | | 2ND FLOOR ZONE 1 STAIR F VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01030156 | 4947918039 |
| ✓ | L3_Z1_PULL_157 PULL | | 2ND FLOOR ZONE 1 STAIR F PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01030157 | 4891329509 |
| ✓ | L3_Z1_DAMPER_EF10_159 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 201D T/S/L ROOM DAMPER | CR (8) Signal - dry contact output |  01030159 | 5286676031 |
| ✓ | L3_Z1_PULL_160 PULL | | 2ND FLOOR ZONE 1 201I VESTBULE PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01030160 | 4891308184 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | L3_Z1_DAMPER_EF3_161 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 208D KITCHEN DAMPER | CR (8) Signal - dry contact output |  01030161 | 5286676116 |
| ✓ | L3_Z1_DAMPER_EF2_162 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 207 STAFF TIOLET DAMPER | CR (8) Signal - dry contact output |  01030162 | 5286678608 |
| ✓ | L3_Z1_DAMPER_EF3_163 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 209 WORK AREA DAMPER | CR (8) Signal - dry contact output |  01030163 | 5286678264 |
| ✓ | L3_Z1_DAMPER_EF11_164 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 210 MENS TOILET DAMPER | CR (8) Signal - dry contact output |  01030164 | 5286678059 |
| ✓ | AHU2_L3SMOKE_DMPR_RELAY_2 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 211B ACTIVE FILES DAMPER | CR (8) Signal - dry contact output |  01030165 | 5282833889 |
| ✓ | AHU2_L3SMOKE_DMPR_RELAY_1 NONSUPERVISEDOUTPUT | ● | 2ND FLR ZN 1 AHU-2 ATRIUM DAMPER RELAY | CR (8) Signal - dry contact output |  01030166 | 5282834893 |
| ✓ | AHU2_L3SMOKE_DAMPER_1 MONITOR | ● | 2ND FLOOR ZONE 1 ATRIUM DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01030167 | 4836377619 |
| ✓ | AHU2_L3SMOKE_DMPR_RELAY_3 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 1 211A INACTIVE FILES DAMPER | CR (8) Signal - dry contact output |  01030168 | 5282838969 |
| ✓ | L3_Z3_DAMPER_EF9_169 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 3 221 ELECTRIC ROOM DAMPER | CR (8) Signal - dry contact output |  01030169 | 5286675690 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00









| | | | | | | |
|---|--|---|---|--|---|------------|
| ✓ | L3_Z3_DAMPER_EF8_171 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 3 219 T/S/L ROOM DAMPER | CR (8) Signal - dry contact output |  01030171 | 5286677823 |
| ✓ | L3_Z3_DAMPER_EF7_172 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 3 218F KITCHEN DAMPER | CR (8) Signal - dry contact output |  01030172 | 5286678226 |
| ✓ | L3_Z3_PULL_173 PULL | | 2ND FLOOR ZONE 3 236 VESTIBULE PULL | 278 (1) Alarm - NO latching (Class B) |  01030173 | 4891325525 |
| ✓ | AHU3_L3SMOKE_DMPR_RELAY NONSUPERVISEDOUTPUT | ● | 2ND FLR ZN 3 AHU-3 ATRIUM DAMPLER RELAY | CR (8) Signal - dry contact output |  01030174 | 5286677861 |
| ✓ | L3_Z3_PULL_175 PULL | | 2ND FLOOR ZONE 3 COURTROOM #1 PULL | 278 (1) Alarm - NO latching (Class B) |  01030175 | 4891277770 |
| ✓ | L3_Z2_PULL_176 PULL | | 2ND FLOOR ZONE 2 214 HISTORIC LOBBY PULL | 278 (1) Alarm - NO latching (Class B) |  01030176 | 4891270641 |
| ✓ | L3_Z3_TS_177 TAMPER | | 2ND FLOOR ZONE 3 STAIR G VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01030177 | 4947916943 |
| ✓ | L3_Z3_FS_178 WATERFLOW | | 2ND FLOOR ZONE 3 STAIR G WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01030178 | 4947916950 |
| ✓ | L3_Z3_PULL_179 PULL | | 2ND FLOOR ZONE 3 COURTROOM #2 PULL | 278 (1) Alarm - NO latching (Class B) |  01030179 | 4891267245 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--|--|--|---|------------|
| ✓ L3_Z3_PULL_180 PULL | 2ND FLOOR ZONE 3 COURTROOM #2 PULL | 278 (1) Alarm - NO latching (Class B) |  01030180 | 4891299123 |
| ✓ L3_Z3_DAMPER_EF12_181 NONSUPERVISEDOUTPUT | 2ND FLOOR ZONE 3 217 WOMENS TOILET DAMPER | CR (8) Signal - dry contact output |  01030181 | 5286678974 |
| ✓ ALARM_TO_EXISTING NONSUPERVISEDOUTPUT | ALARM TO EXISTING FIRE ALARM PANEL | CR (8) Signal - dry contact output |  01030182 | 5286676291 |
| ✓ TROUBLE_TO_EXISTING NONSUPERVISEDOUTPUT | TROUBLE/SUPERVISORY TO EXISTING FACP | CR (8) Signal - dry contact output |  01030183 | 5286676260 |
| ✓ SF_SPKR_189 AUDIBLE | STAIR F SPEAKER CIRCUIT | MCC1 (5) Signal - supervised output (Class B) |  01030189 | 5093503674 |
| ✓ SG_SPKR_190 AUDIBLE | STAIR G SPEAKER CIRCUIT | MCC1 (5) Signal - supervised output (Class B) |  01030190 | 5093504213 |
| ✓ L1_SPKR_SG1A AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G1A | MCC1 (5) Signal - supervised output (Class B) |  01030191 | 5093503834 |
| ✓ L1_SPKR_SG2A AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G2A | MCC1 (5) Signal - supervised output (Class B) |  01030192 | 5093504299 |
| ✓ L1_SPKR_SG3A AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G3A | MCC1 (5) Signal - supervised output (Class B) |  01030193 | 5093484331 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00








| | | | | |
|------------------------------|-------------------------------------|--|---|------------|
| ✓ L1_SPKR_SG1B AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G1B | MCC1 (5) Signal - supervised output (Class B) |  01030194 | 5093516230 |
| ✓ L1_SPKR_SG2B AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G2B | MCC1 (5) Signal - supervised output (Class B) |  01030195 | 5093504633 |
| ✓ L1_SPKR_SG3B AUDIBLE | GROUND FLOOR SPEAKER CIRCUIT G3B | MCC1 (5) Signal - supervised output (Class B) |  01030196 | 5093503681 |
| ✓ L2_SPKR_S11A AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 11A | MCC1 (5) Signal - supervised output (Class B) |  01030197 | 5093504077 |
| ✓ L2_SPKR_S12A AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 12A | MCC1 (5) Signal - supervised output (Class B) |  01030198 | 5093503773 |
| ✓ L2_SPKR_S13A AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 13A | MCC1 (5) Signal - supervised output (Class B) |  01030199 | 5093503735 |
| ✓ L2_SPKR_S11B AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 11B | MCC1 (5) Signal - supervised output (Class B) |  01030200 | 5093503742 |
| ✓ L2_SPKR_S12B AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 12B | MCC1 (5) Signal - supervised output (Class B) |  01030201 | 5093503667 |
| ✓ L2_SPKR_S13B AUDIBLE | 1ST FLOOR SPEAKER CIRCUIT 13B | MCC1 (5) Signal - supervised output (Class B) |  01030202 | 5093503766 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:19 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00








| | | | | | |
|---|-------------------------|----------------------------------|--|---|------------|
| ✓ | L3_SPKR_S21A AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 21A | MCC1 (5) Signal - supervised output (Class B) |  01030203 | 5093529544 |
| ✓ | L3_SPKR_S22A AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 22A | MCC1 (5) Signal - supervised output (Class B) |  01030204 | 5093503896 |
| ✓ | L3_SPKR_S23A AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 23A | MCC1 (5) Signal - supervised output (Class B) |  01030205 | 5093504695 |
| ✓ | L3_SPKR_S21B AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 21B | MCC1 (5) Signal - supervised output (Class B) |  01030206 | 5090316215 |
| ✓ | L3_SPKR_S22B AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 22B | MCC1 (5) Signal - supervised output (Class B) |  01030207 | 5093503841 |
| ✓ | L3_SPKR_S23B AUDIBLE | 2ND FLOOR SPEAKER CIRCUIT 23B | MCC1 (5) Signal - supervised output (Class B) |  01030208 | 5093504596 |
| ✓ | L4_SPKR_S31A AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 31A | MCC1 (5) Signal - supervised output (Class B) |  01030209 | 5093504435 |
| ✓ | L4_SPKR_S32A AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 32A | MCC1 (5) Signal - supervised output (Class B) |  01030210 | 5093503803 |
| ✓ | L4_SPKR_S33A AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 33A | MCC1 (5) Signal - supervised output (Class B) |  01030211 | 5093504398 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|----------------------------------|--|--|---|------------|
| ✓ L4_SPKR_S31B AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 31B | MCC1 (5) Signal - supervised output (Class B) |  01030212 | 5093504657 |
| ✓ L4_SPKR_S32B AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 32B | MCC1 (5) Signal - supervised output (Class B) |  01030213 | 5093504237 |
| ✓ EL1_FIREPHONE_214 FIREPHONE | ELEVATOR 1-4 LOBBY FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030214 | 5093503858 |
| ✓ EL5_FIREPHONE_215 FIREPHONE | ELEVATOR 5 LOBBY FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030215 | 5093526581 |
| ✓ EL6_FIREPHONE_216 FIREPHONE | ELEVATOR 6 LOBBY FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030216 | 5093503728 |
| ✓ SF_FIREPHONE_217 FIREPHONE | STAIRWAY F FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030217 | 5093503827 |
| ✓ SG_FIREPHONE_218 FIREPHONE | STAIRWAY G FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030218 | 5093504251 |
| ✓ FPR_FIREPHONE_219 FIREPHONE | FIRE PUMP ROOM FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01030219 | 5093504039 |
| ✓ L4_SPKR_S33B AUDIBLE | 3RD FLOOR SPEAKER CIRCUIT 33B | MCC1 (5) Signal - supervised output (Class B) |  01030220 | 5093503872 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|--|--|--|---|------------|
| ✓ | L5_SPKR_SA1A AUDIBLE | ATTIC SPEAKER CIRCUIT A1A | MCC1 (5) Signal - supervised output (Class B) |  01030221 | 5093503902 |
| ✓ | L5_SPKR_SA3A AUDIBLE | ATTIC SPEAKER CIRCUIT A3A | MCC1 (5) Signal - supervised output (Class B) |  01030222 | 5093503995 |
| ✓ | L5_SPKR_SA1B AUDIBLE | ATTIC SPEAKER CIRCUIT A1B | MCC1 (5) Signal - supervised output (Class B) |  01030223 | 5093503971 |
| ✓ | L5_SPKR_SA3B AUDIBLE | ATTIC SPEAKER CIRCUIT A3B | MCC1 (5) Signal - supervised output (Class B) |  01030224 | 5093504640 |
| ✓ | AHU3_L3SMOKE_DAMPER MONITOR | 2ND FLR ZN1 AHU-3 ATRIUM DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01030226 | 4836377459 |
| ✓ | L3_Z3_DAMPER_EF6_227 NONSUPERVISEDOUTPUT | EXHAUST FAN #6 DAMPER CONTROL RELAY | CR (8) Signal - dry contact output |  01030227 | 5286674969 |
| ✓ | AHU1_L3SMOKE_DMPP_RELAY NONSUPERVISEDOUTPUT | 2ND FLR ZN1 RELAY ATRIUM SMOKE DAMPER | CR (8) Signal - dry contact output |  01030228 | 5286676178 |
| ✓ | AHU1_L3SMOKE_DAMPER MONITOR | 2ND FLOOR ZONE 1 ATRIUM SMOKE DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01030229 | 4836377213 |
| ✓ | L3_Z3_DAMPER_EF13_230 NONSUPERVISEDOUTPUT | 2ND FLOOR EF#13 DAMPER CONTROL RELAY | CR (8) Signal - dry contact output |  01030230 | 5286678585 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00





| | | | | | | |
|---|---------------------------------------|---|--|--|---|------------|
| ✓ | RESET_234 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 2 BEAM SMOKE DETECTOR RESET | CR (8) Signal - dry contact output |  01030234 | 5286678721 |
| ✓ | L3_Z3_BSMK_235 SMOKE | | 2ND FLOOR ZONE 3 BEAM SMK COURTROOM #1 | CT2 (1) Alarm - NO latching (Class B) |  01030235 | 4947917384 |
| ✓ | L3_Z3_BEAM_TROUBLE_236 SUPERVISORY | | 2ND FLOOR ZONE 3 BEAM SMOKE COURTRM #1 TRBL | CT2 (3) Active - NO nonlatching (Class B) |  01030236 | 4947917391 |
| ✓ | RESET_237 NONSUPERVISEDOUTPUT | ● | 2ND FLOOR ZONE 3 BEAM SMOKE DETECTOR RESET | CR (8) Signal - dry contact output |  01030237 | 5286677779 |
| ✓ | L2_Z2_BSMK_238 SMOKE | | 1ST FLR ZONE 2 NORTH ENTRANCE BEAM SMOKE | CT2 (1) Alarm - NO latching (Class B) |  01030238 | 4947915281 |
| ✓ | L2_Z2_BEAM_TROUBLE_239 SUPERVISORY | | 1ST FLR ZONE 2 NORTH ENTRY BEAM SMOKE TRBL | CT2 (3) Active - NO nonlatching (Class B) |  01030239 | 4947915298 |
| ✓ | RESET_240 NONSUPERVISEDOUTPUT | ● | 1ST FLOOR ZONE 2 BEAM SMOKE DETECTOR RESET | CR (8) Signal - dry contact output |  01030240 | 5286677984 |
| ✓ | AHU2_L3SMOKE_DAMPER_2 MONITOR | | 2ND FLOOR ZONE 1 211A FILES RM DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01030241 | 4836374717 |
| ✓ | AHU2_L3SMOKE_DAMPER_3 MONITOR | | 2ND FLOOR ZONE 1 211B FILES RM DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01030242 | 4836377060 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_2

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | | |
|---|---|---|--|---------------------------------------|---|------------|
| ✓ | DOOR_RELEASE_246 NONSUPERVISEDOUTPUT | ● | 1ST FLR TEL/LAN 110 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01030246 | 5286676000 |
| ✓ | DOOR_RELEASE_247 NONSUPERVISEDOUTPUT | ● | 1ST FLR TEL/LAN 125 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01030247 | 5286675317 |
| ✓ | DOOR_RELEASE_248 NONSUPERVISEDOUTPUT | ● | 2ND FLR TEL/LAN 222 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01030248 | 5288935327 |
| ✓ | DOOR_RELEASE_249 NONSUPERVISEDOUTPUT | ● | 2ND FLR TEL/LAN 205 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01030249 | 5286675324 |

Modules (Loop 1)

| <u>Label</u> | <u>Location</u> | <u>Model</u> | <u>Device Address</u> | <u>Serial Number</u> |
|-------------------------------------|--|---------------------------------------|---|----------------------|
| Device Type | Text | Personality | Barcode Number | Barcode |
| ALARM_TO_BMS NONSUPERVISEDOUTPUT | 1ST FLR Z3 TELE/LAN ALARM TO BMS SYSTEM | CR (8) Signal - dry contact output |  01030250 | 5288934917 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--------------------------------|--|----------------------|---|---------------------------------|
| ✓ L4_Z1_SMK_EF1_1 SMOKEVFY | 3RD FLOOR ZONE 1 305 ELECTRIC ROOM SMOKE | PS Standard Base |  01040001 | 3947573149 |
| ✓ L4_Z1_SMK_2 SMOKEVFY | 3RD FLOOR ZONE 1 304 TELE/LAN ROOM SMOKE | PS Standard Base |  01040002 | 3947573156 |
| ✓ L4_Z1_SMK_3 SMOKEVFY | 3RD FLOOR ZONE 1 343A WEST CORRIDOR A SMOKE | PS Standard Base |  01040003 | 3947571206 |
| ✓ L4_Z1_SMK_4 SMOKEVFY | 3RD FLOOR ZONE 1 343A WEST CORRIDOR A SMOKE | PS Standard Base |  01040004 | 3947574115 |
| ✓ L4_Z1_EL SMK_5_5 SMOKEVFY | 3RD FLOOR ZONE 1 ELEVATOR 5 LOBBY SMK | PS Standard Base |  01040005 | 3947571428 |
| ✓ L4_Z1_ESHT_5_6 HEAT | 3RD FLOOR ZONE 1 TOP ELEVATOR 5 SHAFT HEAT | HRS Standard Base |  01040006 | 3807351979 |
| ✓ L4_Z1_ESSMK_5_7 SMOKEVFY | 3RD FLOOR ZONE 1 TOP ELEVATOR 5 SHAFT SMK | PS Standard Base |  01040007 | 3947570148 |
| ✓ L4_Z1_SMK_EF2_8 SMOKEVFY | 3RD FLOOR ZONE 1 307 WOMENS TOILET SMOKE | PS Standard Base |  01040008 | 3947577611 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---------------------------------|---|---------------------|---|------------|
| ✓ L4_Z1_SMK_EF11_9 SMOKEVFY | 3RD FLOOR ZONE 1 310 MENS TOILET SMOKE | PS Standard Base |  01040009 | 3947572418 |
| ✓ L4_Z2_SMK_10 SMOKEVFY | 3RD FLOOR ZONE 2 STAIR C SMOKE | PS Standard Base |  01040010 | 3947571565 |
| ✓ L4_Z3_SMK_EF12_11 SMOKEVFY | 3RD FLOOR ZONE 3 316 MENS TOILET SMOKE | PS Standard Base |  01040011 | 3947571404 |
| ✓ L4_Z2_SMK_12 SMOKEVFY | 3RD FLOOR ZONE 2 NORTH CORRIDOR A SMK | PS Standard Base |  01040012 | 3947577604 |
| ✓ L4_Z2_SMK_13 SMOKEVFY | 3RD FLOOR ZONE 2 315 RECEPTION/EXHIBIT SMK | PS Standard Base |  01040013 | 3947577925 |
| ✓ L4_Z2_ESSMK_3_14 SMOKEVFY | 3RD FLOOR ZONE 2 TOP ELEV 3-4 SHAFT SMOKE | PS Standard Base |  01040014 | 3947576461 |
| ✓ L4_Z2_ELSMK_1_15 SMOKEVFY | 3RD FLOOR ZONE 2 ELEV 1-4 LOBBY SMOKE | PS Standard Base |  01040015 | 3947570667 |
| ✓ L4_Z2_ESSMK_1_16 SMOKEVFY | 3RD FLOOR ZONE 2 TOP ELEV 1 SHAFT SMOKE | PS Standard Base |  01040016 | 3947376771 |
| ✓ L4_Z3_SMK_EF9_17 SMOKEVFY | 3RD FLOOR ZONE 3 320 ELECTRIC ROOM SMOKE | PS Standard Base |  01040017 | 3947570629 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | |
|--------------------------------|--|----------------------|---|------------|
| ✓ L4_Z3_SMK_EF8_18 SMOKEVFY | 3RD FLOOR ZONE 3 318 WOMENS TOILET SMOKE | PS Standard Base |  01040018 | 3947628252 |
| ✓ L4_Z3_SMK_19 SMOKEVFY | 3RD FLOOR ZONE 3 321 TELE/LAN ROOM SMOKE | PS Standard Base |  01040019 | 3947570643 |
| ✓ L4_Z3_SMK_20 SMOKEVFY | 3RD FLOOR ZONE 3 345A EAST CORRIDOR A SMOKE | PS Standard Base |  01040020 | 3947577628 |
| ✓ L4_Z3_SMK_21 SMOKEVFY | 3RD FLOOR ZONE 3 345A EAST CORRIDOR A SMOKE | PS Standard Base |  01040021 | 3947571435 |
| ✓ L4_Z3_ELSMK_6_22 SMOKEVFY | 3RD FLOOR ZONE 3 ELEVATOR 6 LOBBY SMK | PS Standard Base |  01040022 | 3947570674 |
| ✓ L4_Z3_ESSMK_6_23 SMOKEVFY | 3RD FLOOR ZONE 3 TOP ELEVATOR 6 SHAFT SMK | PS Standard Base |  01040023 | 3947570070 |
| ✓ L4_Z3_ESHT_6_24 HEAT | 3RD FLOOR ZONE 3 TOP ELEVATOR 6 SHAFT HEAT | HRS Standard Base |  01040024 | 3807348290 |
| ✓ L4_Z3_ELSMK_6_25 SMOKEVFY | 3RD FLOOR ZONE 3 ELEVATOR 6 LOBBY SMK | PS Standard Base |  01040025 | 3947573255 |
| L4_Z1_SMK_EF3_50 SMOKEVFY | 3RD FLOOR ZONE 1 306C KITCHEN SMOKE | PS Standard Base |  01040050 | 3947367052 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00








| | | | | | |
|---|--|--|--------------------------------|---|------------|
| ✓ | LOOP3_ISO_54 ISOLATOR | 1ST FLOOR ZN2 SLC 3 ISOLATION MODULE | IM Isolator Base |  01040054 | 3691012444 |
| ✓ | LOOP3_ISO_55 ISOLATOR | 1ST FLOOR ZN2 SLC 3 ISOLATION MODULE | IM Isolator Base |  01040055 | 3691017531 |
| ✓ | LOOP3_ISO_56 ISOLATOR | 3RD FLOOR ZN3 SLC 3 ISOLATION MODULE | IM Isolator Base |  01040056 | 3691005064 |
| ✓ | LOOP3_ISO_58 ISOLATOR | 3RD FLOOR ZN1 SLC 3 ISOLATION MODULE | IM Isolator Base |  01040058 | 3691011683 |
| ✓ | L4_Z3_DS_AHU7_RETURN_60 SUPERVISORY | ATTIC ZONE 3 AHU-7 RETURN DUCT SMOKE | SD Relay Base or remote LED |  01040060 | 3947962172 |
| ✓ | L4_Z3_DS_AHU7_SUPPLY_61 SUPERVISORY | ATTIC ZONE 3 AHU-7 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  01040061 | 3947963490 |
| ✓ | L4_Z3_DS_EF7_62 SUPERVISORY | 3RD FLOOR ZONE 3 EXHAUST FAN DUCT SMK | SD Relay Base or remote LED |  01040062 | 3947963766 |
| ✓ | L4_Z3_SMK_EF12_63 SMOKEVFY | 3RD FLOOR ZONE 3 337 TOILET SMOKE | PS Standard Base |  01040063 | 3947588600 |
| ✓ | L4_Z1_SMK_EF11_64 SMOKEVFY | 3RD FLOOR ZONE 1 336 TOILET SMOKE | PS Standard Base |  01040064 | 3947571190 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|----------------------------------|---|--------------------------------|---|------------|
| ✓ | L4_Z1_DS_OAHU1_65 SUPERVISORY | ATTIC ZONE 1 OAHU-1 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  01040065 | 3947963803 |
| ✓ | L4_Z1_DS_OAHU1_66 SUPERVISORY | ATTIC ZONE 1 OAHU-1 RETURN DUCT SMOKE | SD Relay Base or remote LED |  01040066 | 3947963759 |
| ✓ | L4_Z1_SMK_EF3_67 SMOKEVFY | 3RD FLOOR ZONE 1 306D P/S/L TOILET SMOKE | PS Standard Base |  01040067 | 3947572456 |
| ✓ | L4_Z1_ELSMK_5_68 SMOKEVFY | 3RD FLOOR ZONE 1 ELEV 5 LOBBY SMOKE | PS Standard Base |  01040068 | 3947570209 |
| ✓ | L4_Z2_ESHT_4_70 HEAT | 3RD FLOOR ZONE 2 TOP ELEVATOR 4 SHAFT HEAT | HRS Standard Base |  01040070 | 3807356776 |
| ✓ | L4_Z2_ESHT_3_71 HEAT | 3RD FLOOR ZONE 2 TOP ELEVATOR 3 SHAFT HEAT | HRS Standard Base |  01040071 | 3807348825 |
| ✓ | L4_Z2_ESHT_1_72 HEAT | 3RD FLOOR ZONE 2 TOP OF ELEV SHAFT 1 HEAT | HRS Standard Base |  01040072 | 3805738321 |

Modules (Loop 1)










| <u>Label</u> | <u>Location</u> | <u>Model</u> | <u>Device Address</u> | <u>Serial Number</u> |
|---|--|---------------------------------------|---|----------------------|
| Device Type | Text | Personality | Barcode Number | Barcode |
| L4_Z1_DAMPER_EF1_127 NONSUPERVISEDOUTPUT | 3RD FLOOR ZONE 1 305 ELECTRIC ROOM DAMPER | CR (8) Signal - dry contact output |  01040127 | 5286678325 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00






| | | | | | |
|---|--|---|--|---|------------|
| ✓ | AHU1_L4SMOKE_DMPR_RELAY NONSUPERVISEDOUTPUT ● | 3RD FLR ZN 1 RELAY ATRIUM SMOKE DAMPER | CR (8) Signal - dry contact output |  01040128 | 5286671777 |
| ✓ | L4_Z1_TS_129 TAMPER | 3RD FLOOR ZONE 1 TOP ELEV 5 SHAFT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040129 | 4947915700 |
| ✓ | L4_Z1_EFS_5_130 WATERFLOW | 3RD FLOOR ZONE 1 TOP ELEV 5 SHAFT FLOW | CT2 (1) Alarm - NO latching (Class B) |  01040130 | 4947915717 |
| ✓ | L4_Z1_PULL_131 PULL | 3RD FLOOR ZONE 1 STAIR F PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01040131 | 4891267238 |
| ✓ | L4_Z1_FS_132 WATERFLOW | 3RD FLOOR ZONE 1 STAIR F WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01040132 | 4947917124 |
| ✓ | L4_Z1_TS_133 TAMPER | 3RD FLOOR ZONE 1 STAIR F VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040133 | 4947917131 |
| ✓ | L4_Z1_TS_134 TAMPER | 3RD FLOOR ZONE 1 STAIR F VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040134 | 4947912983 |
| ✓ | L4_Z1_FS_135 WATERFLOW | 3RD FLOOR ZONE 1 STAIR F WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01040135 | 4947912990 |
| ✓ | L4_Z1_DAMPER_EF3_136 NONSUPERVISEDOUTPUT ● | 3RD FLOOR ZONE 1 306C KITCHEN DAMPER | CR (8) Signal - dry contact output |  01040136 | 5286678653 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:20 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|--|---|---|--|---|------------|
| ✓ | L4_Z1_DAMPER_EF2_137 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 1 307 WOMENS TOILET DAMPER | CR (8) Signal - dry contact output |  01040137 | 5286678981 |
| ✓ | AHU1_L4SMOKE_DAMPER MONITOR | | 3RD FLOOR ZN 1 AHU-1 ATRIUM DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01040138 | 4836376735 |
| ✓ | AHU1_L4SMOKE_DMPR_RELAY_1 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 1 310 MENS TOILET DAMPER | CR (8) Signal - dry contact output |  01040139 | 5286678189 |
| ✓ | L4_Z3_DAMPER_EF12_140 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 3 316 MENS TOILET DAMPER | CR (8) Signal - dry contact output |  01040140 | 5286672088 |
| ✓ | AHU2_L4SMOKE_DMPR_RELAY NONSUPERVISEDOUTPUT | ● | 3RD FLR ZN1 AHU-2 ATRIUM DAMPER RELAY | CR (8) Signal - dry contact output |  01040141 | 5286678110 |
| ✓ | AHU2_L4SMOKE_DAMPER MONITOR | | 3RD FLOOR ZONE 2 ATRIUM DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01040142 | 4836377374 |
| ✓ | L4_Z3_EFS_1_143 WATERFLOW | | 3RD FLOOR ZONE 2 TOP ELEV 1-4 SHAFT FLOW | CT2 (1) Alarm - NO latching (Class B) |  01040143 | 4947917704 |
| ✓ | L4_Z2_TS_144 TAMPER | | 3RD FLOOR ZONE 2 TOP ELEV 1-4 SHAFT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040144 | 4947917711 |
| ✓ | L4_Z3_DAMPER_EF9_145 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 3 320 ELECTRIC ROOM DAMPER | CR (8) Signal - dry contact output |  01040145 | 5286678233 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | L4_Z3_DAMPER_EF8_146 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 3 318 WOMENS TOILET DAMPER | CR (8) Signal - dry contact output |  01040146 | 5286671876 |
| ✓ | AHU3_L4SMOKE_DAMPER MONITOR | | 3RD FLR ZN 3 AHU-3 TEL/LAN RM DAMPR OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01040147 | 4836377367 |
| ✓ | AHU3_L4SMOKE_DMPR_RELAY NONSUPERVISEDOUTPUT | ● | 3RD FLR ZN 3 AHU-3 TEL/LAN RM DMPR RELAY | CR (8) Signal - dry contact output |  01040148 | 5286678950 |
| ✓ | L4_Z3_EFS_6_149 WATERFLOW | | 3RD FLOOR ZONE 3 TOP ELEV 6 SHAFT FLOW | CT2 (1) Alarm - NO latching (Class B) |  01040149 | 4947917247 |
| ✓ | L4_Z3_TS_150 TAMPER | | 3RD FLOOR ZONE 3 TOP ELEV 6 SHAFT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040150 | 4947917254 |
| ✓ | L4_Z3_PULL_151 PULL | | 3RD FLOOR ZONE 3 STAIR G PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01040151 | 4891292490 |
| ✓ | L4_Z3_TS_152 TAMPER | | 3RD FLOOR ZONE 3 STAIR G VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040152 | 4947915502 |
| ✓ | L4_Z3_FS_153 WATERFLOW | | 3RD FLOOR ZONE 3 STAIR G WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01040153 | 4947915519 |
| ✓ | L4_Z3_TS_154 TAMPER | | 3RD FLOOR ZONE 3 STAIR G VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01040154 | 4947917087 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | |
|---|---|--|--|---|------------|
| ✓ L5_Z3_FS_155 WATERFLOW | | ATTIC ZONE 3 STAIR G WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01040155 | 4947917094 |
| ✓ EF9_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #9 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040160 | 5286678929 |
| ✓ EF7_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #7 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040161 | 5286678103 |
| ✓ EF8_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #8 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040162 | 5286671548 |
| ✓ EF12_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #12 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040163 | 5286677724 |
| ✓ L4_Z3_DAMPER_EF7_166 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 2 SMOKE DAMPER RELAY | CR (8) Signal - dry contact output |  01040166 | 5286678332 |
| ✓ EF5_FAN_RELAY_168 NONSUPERVISEDOUTPUT | ● | ATTIC EF #5 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040168 | 5286679018 |
| ✓ EF3_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #3 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040169 | 5286671500 |
| ✓ EF2_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #2 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040170 | 5286671111 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00






| | | | | | | |
|---|---|---|--|---|---|------------|
| ✓ | EF11_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #11 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  01040171 | 5286670787 |
| ✓ | L4_Z3_DAMPER_173 NONSUPERVISEDOUTPUT | ● | 3RD FLOOR ZONE 3 316 MENS TOILET DAMPER | CR (8) Signal - dry contact output |  01040173 | 5286678523 |
| ✓ | DOOR_RELEASE_238 NONSUPERVISEDOUTPUT | ● | 3RD FLR TEL/LAN 321 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01040238 | 5286675706 |
| ✓ | DOOR_RELEASE_239 NONSUPERVISEDOUTPUT | ● | 3RD FLR TEL/LAN 304 DOOR LOCK CONTROL | CR (8) Signal - dry contact output |  01040239 | 5286675652 |
| ✓ | FIREPHONE_240 FIREPHONE | | ELEVATOR #6 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040240 | 5090308029 |
| ✓ | FIREPHONE_241 FIREPHONE | | ELEVATOR #5 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040241 | 5090307862 |
| ✓ | FIREPHONE_242 FIREPHONE | | ELEVATOR #4 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040242 | 5090308654 |
| ✓ | FIREPHONE_243 FIREPHONE | | ELEVATOR #3 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040243 | 5090308821 |
| ✓ | FIREPHONE_244 FIREPHONE | | ELEVATOR #2 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040244 | 5090308227 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_3

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---------------------------------|------------------------------------|--|---|------------|
| ✓ FIREPHONE_245 FIREPHONE | ELEVATOR #1 FIREMANS TELEPHONE | MCC1 (6) Telephone - three-state (Class B) |  01040245 | 5090308258 |
| ✓ NAC_246 VISIBLE | STROBE BOOSTER PANEL EP 1 AND 2 | MCC1S (25) Signal - supervised auto sync output |  01040246 | 5093366248 |
| ✓ NAC_247 VISIBLE | STROBE BOOSTER PANEL EP 3 | MCC1S (25) Signal - supervised auto sync output |  01040247 | 5093366064 |
| ✓ NAC_248 VISIBLE | STROBE BOOSTER PANEL EP 4 | MCC1S (25) Signal - supervised auto sync output |  01040248 | 5092404675 |
| ✓ NAC_249 VISIBLE | STROBE BOOSTER PANEL EP 5 | MCC1S (25) Signal - supervised auto sync output |  01040249 | 5093360895 |

Modules (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|-----------------------------|------------------------------|--|---|---------------------------------|
| ✓ NAC_250 VISIBLE | STROBE BOOSTER PANEL EP 6 | MCC1S (25) Signal - supervised auto sync output |  01040250 | 5092408277 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--|--|--------------------------------|---|---------------------------------|
| ✓ L1_Z1_DS_AHU11_SUPPLY_1 SUPERVISORY | BASEMENT ZONE 1 AHU11 SUPPLY DUCT SMK | SD Relay Base or remote LED |  01050001 | 3975995272 |
| ✓ LOOP1B_ISO_2 ISOLATOR | DATA LOOP 1B SUPPLY ISOLATION MODULE | IM Isolator Base |  01050002 | 3691757468 |
| ✓ LOOP1B_ISO_3 ISOLATOR | DATA LOOP 1B RETURN ISOLATION MODULE | IM Isolator Base |  01050003 | 3691757048 |
| ✓ LOOP1B_ISO_5 ISOLATOR | 1ST FLOOR ZN2 SLC 1B ISOLATION MODULE | IM Isolator Base |  01050005 | 3691757444 |
| ✓ LOOP1B_ISO_8 ISOLATOR | BASEMENT ZN 2 SLC 1B ISOLATION MODULE | IM Isolator Base |  01050008 | 3691758373 |
| ✓ L1_Z2_SMK_22 SMOKEVFY | BASEMENT ZONE 2 002 PREFUNCTION SMOKE | PS Standard Base |  01050022 | 3947575464 |
| ✓ L1_Z2_SMK_23 SMOKEVFY | BASEMENT ZONE 2 002 PREFUNCTION SMOKE | PS Standard Base |  01050023 | 3936923962 |
| ✓ L1_Z2_SMK_24 SMOKEVFY | BASEMENT ZONE 2 003 CORRIDOR SMOKE | PS Standard Base |  01050024 | 3936861028 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00







| | | | | |
|---|---|--------------------------------|---|------------|
| ✓ L1_Z1_SMK_25 SMOKEVFY | BASEMENT ZONE 1 010C CORRIDOR SMOKE | PS Standard Base |  01050025 | 3947575563 |
| ✓ L1_Z2_SMK_26 SMOKEVFY | BASEMENT ZONE 2 003B CORR WEST SMOKE | PS Standard Base |  01050026 | 3936860434 |
| ✓ L1_Z1_SMK_27 SMOKEVFY | BASEMENT ZONE 1 022B CORRIDOR SMOKE | PS Standard Base |  01050027 | 3947376795 |
| ✓ L1_Z1_EMRHT_5_28 HEAT | BASEMENT ZONE 1 ELEV 5 MACH RM HEAT | HRS Standard Base |  01050028 | 3807348894 |
| ✓ L1_Z1_EMRSMK_5_29 SMOKEVFY | BASEMENT ZONE 1 ELEV 5 MACH RM SMOKE | PS Standard Base |  01050029 | 3947630989 |
| ✓ L1_Z1_EMRHT_5_30 HEAT | BASEMENT ZONE 1 ELEV 5 MACH RM HEAT | HRS Standard Base |  01050030 | 3807348931 |
| ✓ L1_Z1_ESHT_5_31 HEAT | BASEMENT ZONE 1 ELEVATOR 5 PIT HEAT | HRS Standard Base |  01050031 | 3807349143 |
| ✓ L1_Z1_ELSMK_5_32 SMOKEVFY | BASEMENT ZONE 1 ELEVATOR 5 LOBBY SMK | PS Standard Base |  01050032 | 3947565960 |
| ✓ L1_Z1_DS_AHU11_RETURN_37 SUPERVISORY | BASEMENT ZONE 1 RF-8 RETURN DUCT SMK | SD Relay Base or remote LED |  01050037 | 3947961830 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00



| | | | | |
|---|---|--------------------------------|---|------------|
| ✓ L1_Z1_DS_AHU11_SUPPLY_38 SUPERVISORY | BASEMENT ZONE 1 AHU-11 SUPPLY DUCT | SD Relay Base or remote LED |  01050038 | 3947963445 |
| ✓ L1_Z1_DS_AHU12_SUPPLY_39 SUPERVISORY | BASEMENT ZONE 1 AHU-12 SUPPLY DUCT | SD Relay Base or remote LED |  01050039 | 3947961939 |
| ✓ L1_Z1_DS_AHU12_RETURN_40 SUPERVISORY | BASEMENT ZONE 1 RF-12 RETURN DUCT | SD Relay Base or remote LED |  01050040 | 3947960765 |
| ✓ L1_Z3_SMK_44 SMOKEVFY | BASEMENT ZONE 3 010A CORRIDOR SMOKE | PS Standard Base |  01050044 | 3947575501 |
| ✓ L1_Z2_SMK_45 SMOKEVFY | BASEMENT ZONE 2 003A CORR EAST SMOKE | PS Standard Base |  01050045 | 3936923818 |
| ✓ L1_Z3_SMK_46 SMOKEVFY | BASEMENT ZONE 3 022H CORRIDOR SMOKE | PS Standard Base |  01050046 | 3947566066 |
| ✓ L1_Z3_EMRHT_6_47 HEAT | BASEMENT ZONE 3 ELEV 6 MACH RM HEAT | HRS Standard Base |  01050047 | 3807352679 |
| ✓ L1_Z3_EMRSMK_6_48 SMOKEVFY | BASEMENT ZONE 3 ELEV 6 MACH RM SMOKE | PS Standard Base |  01050048 | 3947571381 |
| ✓ L1_Z3_EMRHT_6_49 HEAT | BASEMENT ZONE 3 ELEV 6 MACH RM HEAT | HRS Standard Base |  01050049 | 3805738550 |

Signature Detectors/Modules Barcode Worksheet






2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|-----------------------------------|---|----------------------|---|------------|
| ✓ L1_Z3_ESHT_6_50 HEAT | BASEMENT ZONE 3 ELEVATOR 6 PIT HEAT | HRS Standard Base |  01050050 | 3807349136 |
| ✓ L1_Z3_ELSMK_6_51 SMOKEVFY | BASEMENT ZONE 3 ELEVATOR 6 LOBBY SMK | PS Standard Base |  01050051 | 3947566110 |

Modules (Loop 1)










| Label Device Type | Location Text | Model Personality | Device Address Barcode Number | Serial Number Barcode |
|---|--|--|---|--------------------------|
| ✓ AHU12_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU12 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  01050130 | 5286675188 |
| ✓ AHU12_RECIRC_DAMPER MONITOR | BASEMENT ZONE 1 AHU12 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  01050131 | 4803263624 |
| ✓ AHU12_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU12 OUTSIDE AIR DAMPER | CR (8) Signal - dry contact output |  01050132 | 5282838464 |
| ✓ AHU12_OA_DAMPER MONITOR | BASEMENT ZONE 1 AHU12 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050133 | 4839735676 |
| ✓ AHU12_SUPPLY_ON MONITOR | BASEMENT ZONE 1 AHU12 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01050134 | 4841699065 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | |
|--|--|--|---|------------|
| ✓ AHU11_SUPPLY_ON MONITOR | BASEMENT ZONE 1 AHU11 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01050137 | 4839729774 |
| ✓ RF8_RETURN_ON MONITOR | BASEMENT ZONE 1 AHU11 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  01050138 | 4836377701 |
| ✓ AHU11_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU11 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  01050139 | 5282839027 |
| ✓ AHU11_RELIEF_DAMPER MONITOR | BASEMENT ZONE 1 AHU11 RELIEF DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  01050140 | 4839734990 |
| ✓ AHU11_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU11 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  01050141 | 5286675072 |
| ✓ AHU11_RECIRC_DAMPER MONITOR | BASEMENT ZONE 1 AHU11 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  01050142 | 4836377015 |
| ✓ AHU11_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU11 OUTSIDE AIR DAMPER | CR (8) Signal - dry contact output |  01050143 | 5282834039 |
| ✓ AHU11_OA_DAMPER MONITOR | BASEMENT ZONE 1 AHU11 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050144 | 4839735454 |
| ✓ AHU12_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | AHU12 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  01050145 | 5286678127 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|---|---|--------------------------------------|--|---|------------|
| ✓ | AHU11_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ● | AHU11 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  01050146 | 5282835128 |
| ✓ | SHUNT_TRIP_1 NONSUPERVISEDOUTPUT | ● | ELEVATOR #1 SHUNT TRIP RELAY | CR (8) Signal - dry contact output |  01050147 | 5282834213 |
| ✓ | SHUNT_TRIP_3 NONSUPERVISEDOUTPUT | ● | ELEVATOR #3 & #4 SHUNT TRIP RELAY | CR (8) Signal - dry contact output |  01050148 | 5282854907 |
| ✓ | EF20_FAN_RELAY NONSUPERVISEDOUTPUT | ● | EXHAUST FAN 20 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01050149 | 5286675836 |
| ✓ | EF16_FAN_RELAY NONSUPERVISEDOUTPUT | ● | EXHAUST FAN 16 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01050150 | 5286675980 |
| ✓ | L1_Z1_PRTS_151 TAMPER | | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050151 | 4947916363 |
| ✓ | L1_Z1_PRTS_152 TAMPER | | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050152 | 4947916370 |
| ✓ | L1_Z1_PRTS_153 TAMPER | | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050153 | 4947915465 |
| ✓ | L1_Z1_PRTS_154 TAMPER | | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050154 | 4947915472 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:21 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00




| | | | | |
|------------------------------------|---|--|---|------------|
| ✓ L1_Z1_PRTS_155 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050155 | 4947915342 |
| ✓ L1_Z1_PRTS_156 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050156 | 4947915359 |
| ✓ L1_Z1_PRTS_157 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050157 | 4947916141 |
| ✓ L1_Z1_PRTS_158 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050158 | 4947916158 |
| ✓ L1_Z1_FS_159 WATERFLOW | FIRE PUMP ROOM WATERFLOW | CT1 (1) Alarm - NO latching (Class B) |  01050159 | 4839729903 |
| ✓ RESET_160 NONSUPERVISEDOUTPUT | BASEMENT ZONE 2 BEAM SMOKE 1 RESET | CR (8) Signal - dry contact output |  01050160 | 5286675621 |
| ✓ L1_Z2_BSMK_161 SMOKE | BSMNT ZN 2 BEAM SMOKE CEREMONIAL COURTROOM | CT2 (1) Alarm - NO latching (Class B) |  01050161 | 4903313588 |
| ✓ BEAM_TROUBLE_162 SUPERVISORY | BASEMENT ZONE 2 BEAM SMOKE 1 TROUBLE | CT2 (3) Active - NO nonlatching (Class B) |  01050162 | 4903313595 |
| ✓ RESET_163 NONSUPERVISEDOUTPUT | BASEMENT ZONE 2 BEAM SMOKE 2 RESET | CR (8) Signal - dry contact output |  01050163 | 5286675423 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|---|---|--|---|------------|
| ✓ | L1_Z2_BSMK_164 SMOKE | BSMNT ZN 2 BEAM SMOKE CEREMONIAL COURTROOM | CT2 (1) Alarm - NO latching (Class B) |  01050164 | 4947916028 |
| ✓ | BEAM_TROUBLE_165 SUPERVISORY | BASEMENT ZONE 2 BEAM SMOKE 2 TROUBLE | CT2 (3) Active - NO nonlatching (Class B) |  01050165 | 4947916035 |
| ✓ | L1_Z1_TS_166 TAMPER | BASEMENT ZONE 1 STAIR F VALVE TAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050166 | 4839743510 |
| ✓ | L1_Z1_TS_167 TAMPER | BASEMENT ZONE 1 STAIR G VALVE TAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050167 | 4840339672 |
| ✓ | L1_Z1_TS_179 TAMPER | BASEMENT ZONE 1 ELEVATOR 5 PIT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050179 | 4947916202 |
| ✓ | L1_Z1_EFS_5_180 WATERFLOW | BASEMENT ZONE 1 ELEV 5 PIT WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01050180 | 4947916219 |
| ✓ | L1_Z1_EFS_5_181 WATERFLOW | BASEMENT ZONE 1 ELEV 5 MACH RM FLOW | CT2 (1) Alarm - NO latching (Class B) |  01050181 | 4947915526 |
| ✓ | L1_Z1_TS_182 TAMPER | BASEMENT ZONE 1 ELEV 5 MACH RM TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050182 | 4947915533 |
| ✓ | PRIMARY_RECALL_5 NONSUPERVISEDOUTPUT | ELEVATOR 5 PRIMARY RECALL | CR (8) Signal - dry contact output |  01050183 | 5286675348 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|---|---|--|--|---|------------|
| ✓ | ALTERNATE_RECALL_5 NONSUPERVISEDOUTPUT | ● | ELEVATOR 5 ALTERNATE RECALL | CR (8) Signal - dry contact output |  01050184 | 5286676192 |
| ✓ | EARTHQUAKE_MODE_5 NONSUPERVISEDOUTPUT | ● | ELEVATOR 5 EARTHQUAKE MODE | CR (8) Signal - dry contact output |  01050185 | 5286674921 |
| ✓ | FIREMANS_HAT_5 NONSUPERVISEDOUTPUT | ● | ELEVATOR 5 FIREMANS HAT | CR (8) Signal - dry contact output |  01050186 | 5282838990 |
| ✓ | SHUNT_TRIP_5 NONSUPERVISEDOUTPUT | ● | ELEVATOR 5 SHUNT TRIP RELAY | CR (8) Signal - dry contact output |  01050187 | 5282855126 |
| ✓ | SHUNT_TRIP_PWR_5 SUPERVISORY | | ELEVATOR 5 SHUNT TRIP PWR SUPERVISION | CT1 (3) Active - NO nonlatching (Class B) |  01050188 | 4840339009 |
| ✓ | L1_Z1_PULL_189 PULL | | BASEMENT ZONE 1 STAIR F PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01050189 | 4891331625 |
| ✓ | L2_Z1_FS_190 WATERFLOW | | 1ST FLOOR ZONE 1 STAIR F WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01050190 | 4947916189 |
| ✓ | L1_Z1_TS_191 TAMPER | | BASEMENT ZONE 1 STAIR F VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050191 | 4947916196 |
| ✓ | L1_Z1_FS_192 WATERFLOW | | BASEMENT ZONE 1 STAIR F WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01050192 | 4947916288 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--|--|--|---|------------|
| ✓ L1_Z1_TS_193 TAMPER | BASEMENT ZONE 1 STAIR F VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050193 | 4947916295 |
| ✓ L1_Z1_PULL_194 PULL | BASEMENT ZONE 1 021A CORRIDOR PULL | 278 (1) Alarm - NO latching (Class B) |  01050194 | 4891336446 |
| ✓ EF15_FAN_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 EF-15 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01050195 | 5282854990 |
| ✓ L1_Z2_PULL_196 PULL | BASEMENT ZONE 2 CEREMONIAL COURT PULL | 278 (1) Alarm - NO latching (Class B) |  01050196 | 4894060973 |
| ✓ AHU11_SUPPLY_OFF_197 NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 RF-8 SHUTDOWN RELAY | CR (8) Signal - dry contact output |  01050197 | 5282854006 |
| ✓ AHU11_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU-11 RETURN SHUTDWN | CR (8) Signal - dry contact output |  01050198 | 5282855256 |
| ✓ AHU12_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | BASEMENT ZONE 1 AHU-12 SUPPLY SHUTDWN | CR (8) Signal - dry contact output |  01050199 | 5282855065 |
| ✓ AHU11_SUPPLY_AUTO_201 MONITOR | BASEMENT ZONE 1 AHU-11 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01050201 | 4947917025 |
| ✓ RF8_RETURN_AUTO MONITOR | BASEMENT ZONE 1 RF-8 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01050202 | 4947917032 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | AHU11_ON_RELAY_203 NONSUPERVISEDOUTPUT | ● | BASEMENT ZONE 1 AHU-11 ON RELAY | CR (8) Signal - dry contact output |  01050203 | 5282834015 |
| ✓ | AHU12_SUPPLY_AUTO_204 MONITOR | ● | BASEMENT ZONE 1 AHU-12 1N AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01050204 | 4947915489 |
| ✓ | RF12_RETURN_AUTO MONITOR | ● | BASEMENT ZONE 1 RF-12 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  01050205 | 4947915496 |
| ✓ | AHU12_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | BASEMENT ZN 1 AHU-12 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  01050206 | 5282834824 |
| ✓ | FPR MONITOR | ● | FIRE PUMP RUNNING | CT2 (3) Active - NO nonlatching (Class B) |  01050210 | 4947916981 |
| ✓ | FPP SUPERVISORY | | FIRE PUMP FAULT | CT2 (3) Active - NO nonlatching (Class B) |  01050211 | 4947916998 |
| ✓ | L1_Z3_TS_212 TAMPER | | BASEMENT ZONE 3 ELEV 6 MACH RM TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050212 | 4947916660 |
| ✓ | L1_Z3_EFS_6_213 WATERFLOW | | BASEMENT ZONE 3 ELEV 6 MACH RM FLOW | CT2 (1) Alarm - NO latching (Class B) |  01050213 | 4947916677 |
| ✓ | L1_Z3_TS_214 TAMPER | | BASEMENT ZONE 3 ELEVATOR 6 PIT TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050214 | 4947917063 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00






| | | | | | |
|---|---|---|--|---|------------|
| ✓ | L1_Z3_EFS_6_215 WATERFLOW | BASEMENT ZONE 3 ELEVATOR 6 PIT FLOW | CT2 (1) Alarm - NO latching (Class B) |  01050215 | 4947917070 |
| ✓ | PRIMARY_RECALL_6 NONSUPERVISEDOUTPUT | ELEVATOR 6 PRIMARY RECALL | CR (8) Signal - dry contact output |  01050216 | 5282835364 |
| ✓ | ALTERNATE_RECALL_6 NONSUPERVISEDOUTPUT | ELEVATOR 6 ALTERNATE RECALL | CR (8) Signal - dry contact output |  01050217 | 5282834374 |
| ✓ | EARTHQUAKE_MODE_6 NONSUPERVISEDOUTPUT | ELEVATOR 6 EARTHQUAKE MODE | CR (8) Signal - dry contact output |  01050218 | 5282834619 |
| ✓ | FIREMANS_HAT_6 NONSUPERVISEDOUTPUT | ELEVATOR 6 FIREMANS HAT RELAY | CR (8) Signal - dry contact output |  01050219 | 5282834473 |
| ✓ | SHUNT_TRIP_6 NONSUPERVISEDOUTPUT | ELEVATOR 6 SHUNT TRIP RELAY | CR (8) Signal - dry contact output |  01050220 | 5282838716 |
| ✓ | L1_Z1_PRTS_221 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050221 | 4803277904 |
| ✓ | L1_Z3_PULL_224 PULL | BASEMENT ZONE 3 STAIR G PULL STATION | 278 (1) Alarm - NO latching (Class B) |  01050224 | 4891335012 |
| ✓ | L1_Z3_TS_225 TAMPER | BASEMENT ZONE 3 STAIR G VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050225 | 4903315421 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab1_MAIN_FACP 3-SSDC1: 0LOOP_1B

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--|---|--|---|------------|
| ✓ L1_Z3_FS_226 WATERFLOW | BASEMENT ZONE 3 STAIR G WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01050226 | 4903315438 |
| ✓ L1_Z3_TS_227 TAMPER | BASEMENT ZONE 3 STAIR G VALVE TAMPER | CT2 (3) Active - NO nonlatching (Class B) |  01050227 | 4950614263 |
| ✓ L2_Z3_FS_228 WATERFLOW | BASEMENT ZONE 3 STAIR G WATERFLOW | CT2 (1) Alarm - NO latching (Class B) |  01050228 | 4950614270 |
| ✓ FPS NONSUPERVISEDOUTPUT ● | BASEMENT ZN 1 REMOTE FIRE PUMP START RELAY | CR (8) Signal - dry contact output |  01050229 | 5286675935 |
| ✓ RF8_ON_233 NONSUPERVISEDOUTPUT ● | RELAY RETURN FAN 8 ON | CR (8) Signal - dry contact output |  01050233 | 5286676123 |

Modules (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|-------------------------------|--------------------------------|--|---|---------------------------------|
| ✓ L1_Z1_PRTS_250 TAMPER | FIRE PUMP ROOM VALVE TAMPER | CT1 (3) Active - NO nonlatching (Class B) |  01050250 | 4835351214 |









Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)






| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--|--|--------------------------------|---|---------------------------------|
| ✓ L5_Z1_DS_AHU4_RETURN_1 SUPERVISORY | ATTIC ZONE 1 RF-4 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110001 | 3947961885 |
| ✓ L5_Z1_DS_AHU4_SUPPLY_2 SUPERVISORY | ATTIC ZONE 1 AHU-4 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02110002 | 3947961908 |
| ✓ L5_Z1_DS_OAHU3_RETURN_3 SUPERVISORY | ATTIC ZONE 1 OAHU-3 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110003 | 3947963421 |
| ✓ L5_Z1_DS_OAHU3_RETURN_4 SUPERVISORY | ATTIC ZONE 1 OAHU-3 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110004 | 3947963711 |
| ✓ L5_Z1_DS_OAHU3_SUPPLY_5 SUPERVISORY | ATTIC ZONE 1 OAHU-3 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02110005 | 3947962202 |
| ✓ L5_Z1_DS_AHU1_RETURN_6 SUPERVISORY | ATTIC ZONE 1 RF-1 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110006 | 3947960789 |
| ✓ L5_Z1_DS_AHU1_SUPPLY_7 SUPERVISORY | ATTIC ZONE 1 AHU-1 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02110007 | 3947961878 |
| ✓ L5_Z1_DS_OAHU1_RETURN_8 SUPERVISORY | ATTIC ZONE 1 OAHU-1 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110008 | 3947962189 |

Signature Detectors/Modules Barcode Worksheet



2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---|---|--------------------------------|---|------------|
| ✓ L5_Z1_DS_AHU2_SUPPLY_9 SUPERVISORY | ATTIC ZONE 1 AHU-2 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02110009 | 3947961984 |
| ✓ L5_Z1_DS_AHU2_RETURN_10 SUPERVISORY | ATTIC ZONE 1 RF-2 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02110010 | 3947961311 |
| ✓ LOOP4_ISO_11 ISOLATOR | DATA LOOP 4 SUPPLY ISOLATION MODULE | IM Isolator Base |  02110011 | 3691001660 |
| ✓ LOOP4_ISO_12 ISOLATOR | DATA LOOP 4 RETURN ISOLATION MODULE | IM Isolator Base |  02110012 | 3691013946 |
| ✓ LOOP4_ISO_13 ISOLATOR | DATA LOOP 4 ISOLATION MODULE | IM Isolator Base |  02110013 | 3691017326 |

Modules (Loop 1)

| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--------------------------------|---|--|---|---------------------------------|
| ✓ AHU4_RETURN_ON MONITOR | ATTIC ZONE 1 AHU-4 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110126 | 4836373437 |
| ✓ AHU4_SUPPLY_ON MONITOR | ATTIC ZONE 1 AHU-4 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110127 | 4836377411 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--|--|--|---|------------|
| ✓ AHU4_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 AHU-4 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02110128 | 5286677892 |
| ✓ AHU4_SUPPLY_AUTO MONITOR | ATTIC ZONE 1 AHU-4 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110129 | 4947917186 |
| ✓ RF4_RETURN_AUTO MONITOR | ATTIC ZONE 1 RF-4 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110130 | 4947917193 |
| ✓ AHU4_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 AHU-4 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02110131 | 5286677830 |
| ✓ AHU4_RETURN_ON_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 AHU-4 RETURN ON RELAY | CR (8) Signal - dry contact output |  02110132 | 5286671920 |
| ✓ AHU4_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 AHU-4 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02110133 | 5286679094 |
| ✓ EF10_FAN_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 EF #10 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  02110134 | 5282834800 |
| ✓ OAHU3_ON MONITOR | ATTIC ZONE 1 OAHU-3 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110136 | 4836376711 |
| ✓ OAHU3_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 1 OAHU-3 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02110138 | 5286678165 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | | |
|---|---|---|--|--|---|------------|
| ✓ | AHU1_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02110142 | 5286678578 |
| ✓ | AHU1_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02110143 | 5286677731 |
| ✓ | AHU1_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02110144 | 5286671449 |
| ✓ | AHU1_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 RETUN ON RELAY | CR (8) Signal - dry contact output |  02110145 | 5286678592 |
| ✓ | AHU1_SUPPLY_AUTO MONITOR | | ATTIC ZONE 1 AHU-1 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110146 | 4947915908 |
| ✓ | RF1_RETURN_AUTO MONITOR | | ATTIC ZONE 1 RF-1 RETURN IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110147 | 4947915915 |
| ✓ | AHU1_RELIEF_DAMPER MONITOR | | ATTIC ZONE 1 AHU-1 RELIEF DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02110148 | 4836377107 |
| ✓ | AHU1_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  02110149 | 5286678646 |
| ✓ | AHU1_RECIRC_DAMPER MONITOR | | ATTIC ZONE 1 AHU-1 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02110150 | 4836376773 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | | |
|---|---|---|---|--|---|------------|
| ✓ | AHU1_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  02110151 | 5282839072 |
| ✓ | AHU1_OA_DAMPER MONITOR | | ATTIC ZONE 1 AHU-1 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  02110152 | 4836377169 |
| ✓ | AHU1_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 OUTSIDE AIR RELAY | CR (8) Signal - dry contact output |  02110153 | 5286678691 |
| ✓ | AHU1_SUPPLY_ON MONITOR | | ATTIC ZONE 1 AHU-1 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110154 | 4836376728 |
| ✓ | AHU1_RETURN_ON MONITOR | | ATTIC ZONE 1 AHU-1 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110155 | 4836376759 |
| ✓ | OAHU1_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 OAHU-1 OFF RELAY | CR (8) Signal - dry contact output |  02110157 | 5286678042 |
| ✓ | OAHU1_ON MONITOR | | ATTIC ZONE 1 OAHU-1 SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110161 | 4836376902 |
| ✓ | AHU2_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 SUPPLY FAN ON RELAY | CR (8) Signal - dry contact output |  02110162 | 5286677960 |
| ✓ | AHU2_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 RETURN FAN ON RELAY | CR (8) Signal - dry contact output |  02110163 | 5286679087 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:22 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|---|---|--|---|------------|
| ✓ AHU2_SUPPLY_AUTO MONITOR | | ATTIC ZONE 1 AHU-2 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110164 | 4947915403 |
| ✓ RF2_RETURN_AUTO MONITOR | | ATTIC ZONE 1 RF-2 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02110165 | 4947915410 |
| ✓ AHU2_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 RETURN SHUTDOWN RELAY | CR (8) Signal - dry contact output |  02110166 | 5286678905 |
| ✓ AHU2_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 OUTSIDE AIR DAMPER | CR (8) Signal - dry contact output |  02110167 | 5286672019 |
| ✓ AHU2_OA_DAMPER MONITOR | | ATTIC ZONE 1 AHU-2 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  02110168 | 4836377305 |
| ✓ AHU2_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  02110169 | 5286671173 |
| ✓ AHU2_RECIRC_DAMPER MONITOR | | ATTIC ZONE 1 AHU-2 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02110170 | 4836377589 |
| ✓ AHU2_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  02110171 | 5286678172 |
| ✓ AUU2_RELIEF_DAMPER MONITOR | | ATTIC ZONE 1 AHU-2 RELIEF DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02110172 | 4836377602 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | |
|--|--------------------------------------|--|---|------------|
| ✓ AHU2_SUPPLY_ON MONITOR | ATTIC ZONE 1 AHU-2 SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110173 | 4836376780 |
| ✓ AHU2_RETURN_ON MONITOR | ATTIC ZONE 1 AHU-2 SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02110174 | 4836376858 |
| ✓ SMOKE_EXHAUST_1_ON_RELAY NONSUPERVISEDOUTPUT ● | SMOKE EXHAUST FAN #1 ON RELAY | CR (8) Signal - dry contact output |  02110175 | 5286678707 |
| ✓ SMOKE_EXHAUST_1_OFF_RELAY NONSUPERVISEDOUTPUT ● | SMOKE EXHAUST FAN #1 OFF RELAY | CR (8) Signal - dry contact output |  02110176 | 5286670930 |
| ✓ SMOKE_EXHAUST_1_AUTO MONITOR | SMOKE EXHAUST FAN #1 IN AUTO | CT1 (3) Active - NO nonlatching (Class B) |  02110177 | 4836377442 |
| ✓ SMOKE_EXHAUST_1_ON MONITOR | SMOKE EXHAUST FAN #1 ON | CT1 (3) Active - NO nonlatching (Class B) |  02110178 | 4836376766 |
| ✓ SMOKE_EXHAUST_2_ON MONITOR | SMOKE EXHAUST FAN #2 ON | CT1 (3) Active - NO nonlatching (Class B) |  02110179 | 4836377237 |
| ✓ SMOKE_EXHAUST_2_ON_RELAY NONSUPERVISEDOUTPUT ● | SMOKE EXHAUST FAN #2 ON RELAY | CR (8) Signal - dry contact output |  02110180 | 5286678455 |
| ✓ SMOKE_EXHAUST_2_OFF_RELAY NONSUPERVISEDOUTPUT ● | SMOKE EXHAUST FAN #2 OFF RELAY | CR (8) Signal - dry contact output |  02110181 | 5286678967 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00




| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | SMOKE_EXHAUST_2_AUTO MONITOR | | SMOKE EXHAUST FAN #2 IN AUTO | CT1 (3) Active - NO nonlatching (Class B) |  02110182 | 4836376834 |
| ✓ | AHU2_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02110183 | 5286678752 |
| ✓ | AHU2_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-2 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  02110184 | 5286671746 |
| ✓ | EF4_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF #4 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  02110185 | 5286671944 |
| ✓ | AHU1_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 1 AHU-1 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  02110186 | 5282835227 |
| ✓ | EF1_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC EF#1 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  02110187 | 5286678004 |
| ✓ | SMOKE_EVAC_2_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | SMOKE EVAC FAN #2 CONTROL RELAY | CR (8) Signal - dry contact output |  02110188 | 5286678530 |
| ✓ | SMOKE_EVAC_1_DAMPER MONITOR | | SMOKE EVAC FAN #1 DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02110189 | 4836377541 |
| ✓ | SMOKE_EVAC_1_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | SMOKE EVAC FAN #1 CONTROL RELAY | CR (8) Signal - dry contact output |  02110190 | 5286677939 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_4

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---|---|--|---|------------|
| ✓ SMOKE_EVAC_2_DAMPER MONITOR | SMOKE EVAC FAN #2 DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02110191 | 4836376742 |
| ✓ AHU6_RELIEF_DAMPER MONITOR | ATTIC ZONE 3 AHU-6 RELIEF DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02110244 | 4836377206 |
| ✓ AHU6_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 AHU-6 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  02110245 | 5286672057 |







Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00

Detectors (Loop 1)








| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Base | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|--|--|--------------------------------|---|---------------------------------|
| ✓ L5_Z3_DS_AHU3_SUPPLY_1 SUPERVISORY | ATTIC ZONE 3 AHU-3 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02120001 | 3947960796 |
| ✓ L5_Z3_DS_OAHU4_RETURN_2 SMOKE | ATTIC ZONE 3 OAHU-4 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120002 | 3961817236 |
| ✓ L5_Z3_DS_OAHU4_RETURN_3 SUPERVISORY | ATTIC ZONE 3 OAHU-4 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120003 | 3961666087 |
| ✓ L5_Z3_DS_OAHU4_SUPPLY_4 SUPERVISORY | ATTIC ZONE 3 OAHU-4 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02120004 | 3947963391 |
| ✓ L5_Z3_DS_OAHU2_RETURN_5 SUPERVISORY | ATTIC ZONE 3 OAHU-2 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120005 | 3947963438 |
| ✓ L5_Z3_DS_OAHU2_RETURN_6 SUPERVISORY | ATTIC ZONE 3 OAHU-2 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120006 | 3947961946 |
| ✓ L5_Z3_DS_AHU6_SUPPLY_7 SUPERVISORY | ATTIC ZONE 3 AHU-6 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02120007 | 3947961281 |
| ✓ L5_Z3_DS_AHU6_RETURN_8 SUPERVISORY | ATTIC ZONE 3 AHU-6 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120008 | 3947961847 |

Signature Detectors/Modules Barcode Worksheet


2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|---|--|--------------------------------|---|------------|
| ✓ L5_Z3_DS_AHU5_SUPPLY_9 SUPERVISORY | ATTIC ZONE 3 AHU-5 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02120009 | 3947961144 |
| ✓ L5_Z3_DS_AHU5_RETURN_10 SUPERVISORY | ATTIC ZONE 3 AHU-5 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120010 | 3947961953 |
| ✓ LOOP_ISO_11 ISOLATOR | DATA LOOP 5 ISOLATION MODULE | IM Isolator Base |  02120011 | 3691015162 |
| ✓ LOOP5_ISO_12 ISOLATOR | DATA LOOP 5 ISOLATION MODULE | IM Isolator Base |  02120012 | 3691005477 |
| ✓ LOOP5_ISO_13 ISOLATOR | DATA LOOP 5 ISOLATION MODULE | IM Isolator Base |  02120013 | 3691005132 |
| ✓ L5_Z3_DS_OAHU2_SUPPLY_039 SUPERVISORY | ATTIC ZONE 3 OAHU-2 SUPPLY DUCT SMOKE | SD Relay Base or remote LED |  02120039 | 3947961328 |
| ✓ L5_Z3_DS_AHU3_RETURN_44 SUPERVISORY | ATTIC ZONE 3 AHU-3 RETURN DUCT SMOKE | SD Relay Base or remote LED |  02120044 | 3947960758 |

Modules (Loop 1)










| <u>Label</u> Device Type | <u>Location</u> Text | <u>Model</u> Personality | <u>Device Address</u> Barcode Number | <u>Serial Number</u> Barcode |
|----------------------------------|--------------------------------------|--|---|---------------------------------|
| ✓ AHU7_SUPPLY_AUTO MONITOR | ATTIC ZONE 3 AHU-7 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120126 | 4947916226 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | |
|--|---|--|---|------------|
| RF7_RETURN_AUTO MONITOR ✓ | ATTIC ZONE 3 RF-7 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120127 | 4947916233 |
| AHU7_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT ✓ | ATTIC ZONE 3 AHU-7 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02120128 | 5286679032 |
| AHU7_SUPPLY_ON MONITOR ✓ | ATTIC ZONE 3 AHU-7 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120129 | 4836376827 |
| AHU7_RETURN_ON MONITOR ✓ | ATTIC ZONE 3 AHU-7 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120130 | 4836377312 |
| AHU7_OA_DAMPER MONITOR ✓ | ATTIC ZONE 3 AHU-7 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  02120131 | 4836377633 |
| AHU7_OD_DAMPER_RELAY NONSUPERVISEDOUTPUT ✓ | ATTIC ZONE 3 AHU-7 OA DAMPER RELAY | CR (8) Signal - dry contact output |  02120132 | 5286679063 |
| AHU7_RECIRC_DAMPER MONITOR ✓ | ATTIC ZONE 3 AHU-7 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02120133 | 4836376841 |
| AHU7_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT ✓ | ATTIC ZONE 3 AHU-7 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  02120134 | 5286678394 |
| AHU7_RELIEF_DAMPER MONITOR ✓ | ATTIC ZONE 3 AHU-7 RELIEF DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02120135 | 4836376797 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|---|---|---|--|---|------------|
| ✓ | AHU7_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-7 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  02120136 | 5286671852 |
| ✓ | AHU7_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-7 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02120137 | 5286678219 |
| ✓ | AHU7_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-7 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02120138 | 5286677809 |
| ✓ | AHU7_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-7 RETURN ON RELAY | CR (8) Signal - dry contact output |  02120139 | 5286670701 |
| ✓ | EF13_FAN_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 EF-13 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  02120140 | 5286678899 |
| ✓ | AHU3_RETURN_ON MONITOR | | ATTIC ZONE 3 AHU-3 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120141 | 4836373734 |
| ✓ | AHU3_SUPPLY_ON MONITOR | | ATTIC ZONE 3 AHU-3 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120142 | 4836377565 |
| ✓ | AHU3_OA_DAMPER MONITOR | | ATTIC ZONE 3 AHU-3 OUTSIDE AIR DAMPER | CT1 (3) Active - NO nonlatching (Class B) |  02120143 | 4836377466 |
| ✓ | AHU3_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 OA DAMPER RELAY | CR (8) Signal - dry contact output |  02120144 | 5286678738 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00










| | | | | | | |
|---|---|---|--|--|---|------------|
| ✓ | AHU3_RECIRC_DAMPER MONITOR | | ATTIC ZONE 3 AHU-3 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02120145 | 4836376803 |
| ✓ | AHU3_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  02120146 | 5286671951 |
| ✓ | AHU3_RELIEF_DAMPER MONITOR | | ATTIC ZONE 3 AHU-3 RELIEF DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02120147 | 4836377244 |
| ✓ | AHU3_RELIEF_DAMPER_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 RELIEF DAMPER RELAY | CR (8) Signal - dry contact output |  02120148 | 5286678783 |
| ✓ | AHU3_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02120149 | 5286671241 |
| ✓ | AHU3_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02120150 | 5286669118 |
| ✓ | AHU3_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-3 RETURN ON RELAY | CR (8) Signal - dry contact output |  02120151 | 5286671968 |
| ✓ | AHU3_SUPPLY_AUTO MONITOR | | ATTIC ZONE 3 AHU-3 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120152 | 4947917667 |
| ✓ | RF3_RETURN_AUTO MONITOR | | ATTIC ZONE 3 RF-3 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120153 | 4947917674 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00








| | | | | |
|--|--|--|---|------------|
| ✓ AHU3_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 AHU-3 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02120154 | 5286671197 |
| ✓ OAHU4_ON MONITOR | ATTIC ZONE 3 OAHU-4 SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120160 | 4836377091 |
| ✓ OAHU4_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 OAHU-4 OFF RELAY | CR (8) Signal - dry contact output |  02120161 | 5286677816 |
| ✓ OAHU2_OFF_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 OAHU-2 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02120164 | 5286678301 |
| ✓ OAHU2_ON MONITOR | ATTIC ZONE 3 OAHU-2 SAIL SWITCH IN ON | CT1 (3) Active - NO nonlatching (Class B) |  02120169 | 4836377572 |
| ✓ GEN_REMOTE_START NONSUPERVISEDOUTPUT ● | GENERATOR REMOTE START RELAY | CR (8) Signal - dry contact output |  02120170 | 5282835067 |
| ✓ GR MONITOR | GENERATOR RUNNING | CT2 (3) Active - NO nonlatching (Class B) |  02120171 | 4947915588 |
| ✓ GF SUPERVISORY | GENERATOR FAULT | CT2 (3) Active - NO nonlatching (Class B) |  02120172 | 4947915595 |
| ✓ L5_Z3_PULL_173 PULL | ATTIC/ROOF ZONE 3 PULL STATION | 278 (1) Alarm - NO latching (Class B) |  02120173 | 4891242549 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | | |
|---|---|---|--|---|------------|
| ✓ | AHU6_RECIRC_DAMPER_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 AHU-6 RECIRC DAMPER RELAY | CR (8) Signal - dry contact output |  02120176 | 5286678417 |
| ✓ | AHU6_RECIRC_DAMPER MONITOR | ATTIC ZONE 3 AHU-6 RECIRC DAMPER CLOSED | CT1 (3) Active - NO nonlatching (Class B) |  02120177 | 4836377510 |
| ✓ | AHU6_OA_DAMPER_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 AHU-6 OA DAMPER RELAY | CR (8) Signal - dry contact output |  02120178 | 5286678516 |
| ✓ | AHU6_OA_DAMPER MONITOR | ATTIC ZONE 3 AHU-6 OA DAMPER OPEN | CT1 (3) Active - NO nonlatching (Class B) |  02120179 | 4836376957 |
| ✓ | AHU6_SUPPLY_ON MONITOR | ATTIC ZONE 3 AHU-6 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120180 | 4836377251 |
| ✓ | AHU6_RETURN_ON MONITOR | ATTIC ZONE 3 AHU-6 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120181 | 4836377527 |
| ✓ | AHU6_SUPPLY_AUTO MONITOR | ATTIC ZONE 3 AHU-6 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120182 | 4947917841 |
| ✓ | RF6_RETURN_AUTO MONITOR | ATTIC ZONE 3 RF-6 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120183 | 4947917858 |
| ✓ | AHU6_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT ● | ATTIC ZONE 3 AHU-6 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02120184 | 5286677908 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:23 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00







| | | | | | | |
|---|--|---|--|--|---|------------|
| ✓ | AHU6_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-6 RETURN ON RELAY | CR (8) Signal - dry contact output |  02120185 | 5286678073 |
| ✓ | AHU6_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-6 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02120186 | 5286671890 |
| ✓ | AHU6_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-6 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02120187 | 5286670985 |
| ✓ | AHU5_SUPPLY_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-5 SUPPLY OFF RELAY | CR (8) Signal - dry contact output |  02120188 | 5286671685 |
| ✓ | AHU5_RETURN_OFF_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-5 RETURN OFF RELAY | CR (8) Signal - dry contact output |  02120189 | 5286677946 |
| ✓ | AHU5_SUPPLY_AUTO MONITOR | | ATTIC ZONE 3 AHU-5 SUPPLY IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120190 | 4947917964 |
| ✓ | RF5_RETURN_AUTO MONITOR | | ATTIC ZONE 3 RF-5 IN AUTO | CT2 (3) Active - NO nonlatching (Class B) |  02120191 | 4947917971 |
| ✓ | AHU5_SUPPLY_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-5 SUPPLY ON RELAY | CR (8) Signal - dry contact output |  02120192 | 5286679100 |
| ✓ | AHU5_RETURN_ON_RELAY NONSUPERVISEDOUTPUT | ● | ATTIC ZONE 3 AHU-5 RETURN ON RELAY | CR (8) Signal - dry contact output |  02120193 | 5286766640 |

Signature Detectors/Modules Barcode Worksheet

2/6/2024 5:51:24 AM

Project: DC_COURT Version: 01.00.04 Cabinet: Cab2_AMP_CAB 3-SSDC1: 0LOOP_5

EST3 System Definition Utility : Training Demo Version 05.47.00

| | | | | |
|--|---|--|---|------------|
| ✓ AHU5_SUPPLY_ON MONITOR | ATTIC ZONE 3 AHU-5 SUPPLY SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120194 | 4836377503 |
| ✓ AHU5_RETURN_ON MONITOR | ATTIC ZONE 3 AHU-5 RETURN SAIL SWITCH ON | CT1 (3) Active - NO nonlatching (Class B) |  02120195 | 4836376971 |
| ✓ AHU6_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 AHU-6 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  02120198 | 5286678677 |
| ✓ AHU7_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 AHU-7 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  02120199 | 5286761256 |
| ✓ AHU3_SMOKE_EVAC_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 AHU-3 SMOKE EVAC RELAY | CR (8) Signal - dry contact output |  02120200 | 5286678875 |
| ✓ EF6_FAN_RELAY NONSUPERVISEDOUTPUT | ATTIC ZONE 3 EF-6 FAN CONTROL RELAY | CR (8) Signal - dry contact output |  02120201 | 5286670923 |

Total Devices - 626
 Devices Not Verified - 31
 Devices Verified in Field- 585