

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

ADDRESS	DEVICE	TYPE	DESCRIPTION/LOCATION	PASS	FAIL	COMMENTS
1-002	TRI-2/60D	SUPV.	Fire Pump Fault Bsmt South	X		NFPA 25. Functional test with BFPE Semi Annual
1-003		SUPV.	Fire Pump Run Bsmt South	X		NFPA 25. Functional test with BFPE Semi Annual
1-004	FP-11	PHOTO	Smoke Bsmt South Fire Pump Room	X		
1-005	TRI-2/60D	SUPV.	Tamper Fire Pump room Bsmt South	X		NFPA 25. Functional test with BFPE Semi Annual
1-006		SUPV.	Tamper Fire Pump room Bsmt South	X		NFPA 25. Functional test with BFPE Semi Annual
1-007	TRI-2/60D	SUPV.	Generator Run Basement South	X		Manual only > shorted the Input terminal of Fire alarm module
1-008		SUPV.	Generator Fault Basement South	X		Manual only > shorted the Input terminal of Fire alarm module
1-009	TRI-2/60D	SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-010		SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-011	TRI-2/60D	SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-012		SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-013	TRI-2/60	SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-014	FP-11	PHOTO	Smoke Bsmt South Elevator 6 Lobby	X		Test with Schindler 3/26/2023, ASME A17
1-015	FP-11	PHOTO	Smoke Bsmt South Fire Pump 004	X		
1-018	TRI-2/60	SUPV.	Tamper Bsmt South Trash/ Store Rm	X		
1-019	TRI-2/60D	FLOW	Water flow Bsmt South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
1-020		SUPV.	Tamper Bsmt South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
1-021	TRI-2/60D	SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-022		SUPV.	Tamper Bsmt South Fire Pump Rm	X		NFPA 25. Functional test with BFPE Semi Annual
1-023	TRI-2/60	SUPV.	Tamper Bsmt South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
1-026	TRI-2/60R	Relay	Bsmt. E Turnstiles Rm B10A	X		
1-027	TRI-2/60R	Relay	Bsmt. E Turnstiles Rm B10A	X		
1-059	MSI-1	PULL	Pull Bsmt South Stair 3	X		
1-060	MSI-1	PULL	Pull Bsmt South/Trash Store rm	X		
2-004	FP-11	PHOTO	Smoke 3 rd fl Elev 6 Shaft	X		Test with Schindler 3/26/2023, ASME A17 Test with Schindler
2-005	FPT-11	THERMAL	Smoke 3 rd fl Elev 6 Shaft	X		
2-007	FP-11	PHOTO	Smoke 1 st fl South Elev 6 Lobby	X		
2-008	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
2-012	TRI-2/60	SUPV.	Tamper Penthouse center elev M.Rm	X		
2-010	FP-11	PHOTO	Smoke Penthouse By AHU-6	X		
2-013	TRI-2/60D	FLOW	Water flow 3 rd fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-014		SUPV.	Tamper 3 rd fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

2-015	TRI-2/60	SUPV.	Tamper Penthouse South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-016	TRI-2/60D	FLOW	Dry system flow PentH South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-017		SUPV.	HI/LO air PentHouse South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-018	TRI-2/60	SUPV.	Tamper Penthouse South Elev M Rm.	X		Test with Schindler 3/26/2023, ASME A17
2-019	FPT-11	THERMAL	Heat PentH Center Elev Machine Rm	X		Test with Schindler 3/26/2023, ASME A17
2-020	TRI-2/60D	FLOW	Water flow 1 st fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-021		SUPV.	Tamper 1 st fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-022	FPT-11	THERMAL	Heat PentH Center Elev Machine Rm	X		Test with Schindler 3/26/2023, ASME A17
2-023	TRI-2/60D	FLOW	Water flow 2 nd fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-024		SUPV.	Tamper 2 nd fl South Stair 3	X		NFPA 25. Functional test with BFPE Semi Annual
2-025	FPT-11	PHOTO	Smoke Penthouse South by AHU-6	X		Test with Schindler 3/26/2023, ASME A17 Test with Schindler Field Change at Center Elev. Machine Room: The Module marked 2-052 in penthouse center elevator room should be 2-046 as 2-052 is marked in penthouse south elevator room also.
2-026	FPT-11	PHOTO	Smoke 2 nd fl South Elev 6 Lobby	X		
2-027	TRI-2/60R	Relay	Fire hat Penthouse centr	X		
2-030	FPT-11	THERMAL	Heat PentH Center Elev Machine Rm	X		
2-032	FPT-11	THERMAL	Heat PentH Center Elev Machine Rm	X		
2-035	FPT-11	THERMAL	Heat PentH Center Elev Machine Rm	X		
2-040	FP-11	PHOTO	Smoke PentH Center Elev Mach Rm	X		
2-041	FP-11	PHOTO	Smoke 3 rd fl South Elev 6 Lobby	X		
2-043	FP-11	PHOTO	Smoke PentH Center Elev Mach Rm	X		
2-044	TRI-2/60R	Relay	Primary recall center Elev. 3-4	X		
2-045	TRI-2/60R	Relay	Alt. recall center Elev. 3	X		
2-046	TRI-2/60R	Relay	Fire hat center Elev. 3	X		
2-048	FP-11	PHOTO	Smoke Penthouse Elev 6 Machine Rm	X		
2-049	FP-11	PHOTO	Smoke Penthouse Elev 6 Machine Rm	X		
2-050	TRI-2/60R	Relay	Fire hat Penthouse south elev. 6	X		
2-051	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
2-052	TRI-2/60R	Relay	Primary recall elev. 6	X		
2-053	TRI-2/60R	Relay	Alternate recall elev. 6	X		
2-055	MSI-1	PULL	Pull Penthouse Elev. 1-4 Machine Room	X		
2-056	MSI-1	PULL	Pull 1 st fl South by Elev 7 Lobby	X		
2-057	MSI-1	PULL	Pull 1 st fl South Stair 3	X		
2-058	MSI-1	PULL	Pull 2 nd fl South Stair 3	X		
2-059	MSI-1	PULL	Pull 3 rd fl South Stair 3	X		
2-060	MSI-1	PULL	Pull Penthouse South Stair 3	X		
3-004	FP-11	PHOTO	Smoke 1 st fl Center Elevator Lobby	X		Test with Schindler 3/26/2023 ASME A17
3-011	FP-11	PHOTO	Smoke 1 st fl Center Elevator Lobby	X		
3-012	FP-11	PHOTO	Smoke 2 nd fl Center Elevator Lobby	X		
3-019	FPT-11	THERMAL	Heat 3 rd fl Center Elevator 4 Shaft	X		

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

3-020	FPT-11	THERMAL	Heat 3 rd fl Center Elevator 3 Shaft	X		Test with Schindler 3/26/2023, ASME A17
3-021	FP-11	PHOTO	Smoke 2 nd fl Center Elevator Lobby	X		
3-022	FPT-11	THERMAL	Heat 3 rd fl Center Elevator 1 Shaft	X		
3-023	FP-11	PHOTO	Smoke 3 rd fl Center Elevator Lobby	X		
3-024	FP-11	PHOTO	Smoke 3 rd fl Center Elevator 3 Shaft	X		
3-025	FP-11	PHOTO	Smoke 3 rd fl Center Elevator 1 Shaft	X		
3-027	FPT-11	THERMAL	Heat 3 rd fl Center Elevator 2 Shaft	X		
3-028	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
3-029	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
3-030	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
3-031	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		
3-032	FP-11	PHOTO	Smoke 3 rd fl Center Elevator 2 Shaft	X		
3-033	FP-11	PHOTO	Smoke 3 rd fl Center Elevator 4 Shaft	X		
3-036	FP-11	PHOTO	Smoke 3 rd fl Center Elevator Lobby	X		
3-037	FP-11	PHOTO	Smoke 1 st fl Center security Rm 101	X		
3-039	TRI-2/60R	Relay	Security INT 1 st flr CNTR rm 101	X		
3-040	FPT-11	THERMAL	Heat Penthouse Elev 6 Machine Rm	X		Test with Schindler 3/26/2023, ASME A17
3-041	FP-11	PHOTO	Smoke Penthouse Elev 6 Machine Rm	X		
3-042	FP-11	PHOTO	Smoke Penthouse Elev 6 Machine Rm	X		
3-048	TRI-2/60R	Relay	Primary Penthouse center	X		
3-049	TRI-2/60R	Relay	Alternate Penthouse center	X		
3-050	TRI-2/60R	Relay	Center EMR shunt for Car 1-2	X		
3-051	TRI-2/60R	Relay	Center EMR shunt for Car 3-4	X		
3-055	MSI-1	PULL	Pull 1 st fl Center Front Lobby	X		
3-056	MSI-1	PULL	Pull 1 st fl Center Front Lobby	X		
3-057	MSI-1	PULL	Pull 1 st fl Center Front Lobby	X		
3-058	MSI-1	PULL	Pull 2 nd fl Center Elevator stair 5	X		
3-059	MSI-1	PULL	Pull 3 rd fl Center Elevator stair 5	X		
4-001	FP-11	PHOTO	Smoke Penthouse Cntr Mech Rm	X		Test with Schindler 3/26/2023, ASME A17
4-012	FP-11	PHOTO	Smoke 1 st Flr North Elevator Lobby	X		
4-015	FP-11	PHOTO	Smoke PHSE North Elevator 5 Mech Rm	X		
4-016	FP-11	PHOTO	Smoke PHSE North Elevator 5 Mech Rm	X		
4-017	FP-11	PHOTO	Smoke PHSE North Elevator 5 Mech Rm	X		
4-018	FP-11	PHOTO	Smoke PHSE North Elevator 5 Mech Rm	X		
4-019	FP-11	PHOTO	Smoke PHSE North Elevator 5 Mech Rm	X		
4-020	TRI-2/60	SUPV	Tamper Penthse North Elevator Mech Rm	X		
4-021	FPT-11	THERMAL	Heat PHSE North Elevator 5 Mech Rm	X		
4-023	FPT-11	THERMAL	Heat 3 rd Flr North Elev 5 Shaft	X		
4-025	FP-11	PHOTO	Smoke 2 nd Flr North Elev 5 Lobby	X		
4-035	TRI-2/60R	Relay	Fire hat PHSE N elev. 5 EMR	X		
4-036	FP-11	PHOTO	Smoke PHSE North Elev 5 Mech Rm	X		

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

4-037	FPT-11	THERMAL	HEAT PHSE North Elev 5 Mech Rm	X		Test with Schindler 3/26/2023, ASME A17 Field Change at North Elevator Room : The Heat Detector marked 4-048 in penthouse north elevator room should be 4-053 as 4-048 is fire hat module as per device list.
4-039	FP-11	PHOTO	Smoke 3 rd Flr North Elev 5 Shaft	X		
4-040	FP-11	PHOTO	Smoke 3 rd Flr North Elev 5 Shaft	X		
4-042	FP-11	PHOTO	Smoke PHSE North Elev 5 Mech Rm	X		
4-045	FPT-11	THERMAL	Heat PHSE North Elev 5 Mech Rm	X		
4-048	TRI-2/60R	Relay	Pri. PHSE N elev. 5 EMR	X		
4-049	TRI-2/60R	Relay	Alt. PHSE N elev. 5 EMR	X		
4-052	FPT-11	THERMAL	Heat PHSE North Elev 5 Mech Rm	X		
4-053	FPT-11	THERMAL	Heat PHSE North Elev 5 Mech Rm	X		
4-054	FPT-11	THERMAL	Heat PHSE North Elev 5 Mech Rm	X		
4-055	FPT-11	THERMAL	Heat PHSE North Elev 5 Mech Rm	X		
4-056	MSI-1	PULL	Pull 1 st Flr North Stair 4	X		
4-057	MSI-1	PULL	Pull 1 st Flr North Elev 5 Lobby	X		
4-058	MSI-1	PULL	Pull 2 nd Flr North Stair 4	X		
4-059	MSI-1	PULL	Pull 3 rd Flr North Stair 4	X		
4-060	MSI-1	PULL	Pull PHSE North Catwalk	X		
5-001	FP-11	PHOTO	Smoke BSMNT North Elev 5 Lobby			Test with Schindler 3/26/2023, ASME A17
5-005	FP-11	DUCT	Duct BSMNT Center AHU-4 RET	X		
5-021	FP-11	PHOTO	Smoke BSMNT Center Eng Office	X		
5-023	FP-11	DUCT	Duct BSMNT Center AHU-3 RET	x		
5-024	FP-11	DUCT	Duct BSMNT Center AHU-3 SUP	X		
5-025	FP-11	DUCT	Duct BSMNT Center AHU-1 RET	x		
5-026	FP-11	DUCT	Duct BSMNT Center AHU-1 SUP	x		
5-028	FP-11	DUCT	Duct BSMNT Center AHU-4 SUP	X		
5-029	FP-11	DUCT	Duct BSMNT Center AHU-2 RET	X		
5-030	FP-11	DUCT	Duct BSMNT Center AHU-2 SUP	X		
5-032	FP-11	DUCT	Duct BSMNT Center AHU-5 SUP	X		
5-033	FP-11	DUCT	Duct BSMNT Center AHU-5 RET	X		
5-049	TRI-2/60	SUPV	Tamp BSMNT North Stair 4			NFPA 25. Functional test with BFPE Semi Annual
5-056	MSI-1	PULL	Pull BSMNT North Elev 8 Lobby	X		
5-057	MSI-1	PULL	Pull BSMNT Center by chiller 1	X		
5-058	MSI-1	PULL	Pull BSMNT Center	X		

The following MODULES were found in the Basement Center but missing in the Device List
 5-034 Module for AHU-1
 5-042 Module for AHU-3
 5-043 Module for AHU-1
 5-044 Module for AHU-4
 5-045 Module for AHU-2

Supplementary Records

ADDRESS	TYPE	CLASS/STYLE	CIRCUIT #		PASS	FAIL	COMMENT
8-2	PAD-3	B	NAC-C1-1	BASEMENT SOUTH	X		2x 7ah Battery Replaced New 3/16/2023
		B	NAC-C1-2	BASEMENT SOUTH MID	X		
		B	NAC-C1-3	BASEMENT FAR NORTH	X		

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

		B	NAC-C1-4	BASEMENT CENTER	X		
8-2	PAD-3	B	NAC-C2-1	1 ST FLOOR CENTER	X		2x 7ah Battery > 5.83ah & 4.45ah
		B	NAC-C2-2	2 ND FLOOR CENTER	X		
		B	NAC-C2-3	3 RD FLOOR CENTER	X		
		B	NAC-C2-4	PENTHOUSE CENTER	X		
8-2	PAD-3	B	NAC-C3-1	1 ST FLOOR CENTER	X		2x 7ah Battery Replaced New 3/16/2023
		B	NAC-C3-2	2 ND FLOOR CENTER	X		
		B	NAC-C3-3	3 RD FLOOR CENTER	X		
		B	NAC-C3-4	PENTHOUSE CENTER	X		
8-2	PAD-3	B	NAC- SOUTH-1	1 ST FLOOR SOTH	X		2x 7ah Battery > 5.59ah & 8.83ah
		B	NAC- SOUTH-2	2 ND FLOOR SOUTH	X		
		B	NAC- SOUTH-3	3 RD FLOOR SOUTH	X		
		B	NAC- SOUTH-4	4 TH FLOOR SOUTH	X		
8-2	PAD-3	B	NAC- NORTH-1	1 ST FLOOR NORTH	X		2x 7ah Battery Replaced New 3/16/2023
		B	NAC-NORTH-2	2 ND FLOOR NORTH	X		
		B	NAC-NORTH-3	3 RD FLOOR NORTH	X		
		B	NAC-NORTH-4	4 TH FLOOR NORTH	X		
FACP	XLS			Basement Engr. office	X		2x 55ah Battery Replaced New 3/16/2023
VOICE EVAC				1 ST FL NEXT TO FAGP			2x 18ah Battery Replaced New 3/16/2023
LOOP-1	SLC	4		ALL FLOORS	X		
LOOP-2	SLC	4		ALL FLOORS	X		
LOOP-3	SLC	4		ALL FLOORS	X		
LOOP-4	SLC	4		ALL FLOORS	X		
LOOP-5	SLC	4		ALL FLOORS	X		
Keltron >TX		IP add. 10.6.10.40					1x 12ah Battery Replaced New 3/16/2023

Number of Deficiencies:

1. Combination Speaker/strobe devices, Strobe light works and Speaker are not working in random location.
 - a.) Basement lobby between AHU-5 and stair-4 exit
 - b.) 1st floor elev.5 lobby

DEVICE TEST RESULTS

District of Columbia Superior Court > BUILDING – A

- c.) 1st floor in front of chamber 114H
 - d.) 1st floor in front of room 117G
 - e.) 2nd floor near room 231
 - f.) 2nd floor near room 218B
 - g.) 3rd floor front of room 306G
 - h.) Penthouse outside EMR 1-4
2. (EVX-100) Emergency Microphone not working- **OK - Replaced on 3/21/2023**
 3. Batteries all Failed on Load test – **OK – Replaced on 3/21/2023**

Building A - DC Superior Court
515 5th St. N.W. Washington DC 20001

7.1, 7.2, 7.3, 7.5 and 7.11

[illegible]

Supplementary Records 1 page

Building A - DC Superior Court
515 5th St. N.W. Washington DC 20001

7.1, 7.2, 7.3, 7.5 and 7.11

8-2	PAD-3 SIEMENS SOUTH	B	Basement Level, Engineers office	27.25	X		10/14/20	.07	1.35	.01	2.99	7AH X2 Battery – PASS 5.83AH and 5.59AH 120vac Disconnect EM-1 Basement Mechanical room Ctr.
Keltron >TX IP add. 10.6.10.40			Basement Level, Engineers office	13.20	X		8/05/22					12AH X1 Battery – New Installed 3/21/23 120vac Disconnect EPB CKT.#1 Basement Mechanical room Ctr.